

DESIGN REVIEW BOARD
City of Miami Beach, Florida

MEETING DATE: July 5, 2022

PROPERTY: 7118-7140 Collins Avenue and 7121-7145 Harding Avenue

7145 Harding Avenue	02-3211-002-0570
7135 Harding Avenue	02-3211-002-0580
7131 Harding Avenue	02-3211-002-0590
7121 Harding Avenue	02-3211-002-0600
7118 Collins Avenue	02-3211-002-0630
7124 Collins Avenue	02-3211-002-0640
7134 Collins Avenue	02-3211-002-0650
7140 Collins Avenue	02-3211-002-0660

FILE NO: DRB22-0835

IN RE: An application for modifications to a previously approved Design Review Approval, which included the construction of a new multistory mixed-use residential and retail development, including one or more waivers and variances. Specifically, the applicant is requesting modifications to the elevations and floor plans.

LEGAL: Lots 1, 2, 3, 4, 9, 10, 11 and 12 in Block 8 of Normandy Beach South, according to the Plat thereof, as recorded in Plat Book 21, Page 54, of the Public Records of Miami-Dade County, Florida.

APPLICANTS: Collins & 72nd Developers, LLC**SUPPLEMENTAL ORDER**

The City of Miami Beach Design Review Board makes the following FINDINGS OF FACT, based upon the evidence, information, testimony and materials presented at the public hearing and which are part of the record for this matter:

I. Design Review

- A. The Board has jurisdiction pursuant to Section 118-252(a) of the Miami Beach Code. The property is not located within a designated local historic district and is not a individually designated historic site.
- B. Based on the plans and documents submitted with the application, testimony and information provided by the applicant, and the reasons set forth in the Planning Department Staff Report, the project as submitted is inconsistent with Design Review Criteria 9 in Section 118-251 of the Miami Beach Code.
- C. Based on the plans and documents submitted with the application, testimony and information provided by the applicant, and the reasons set forth in the Planning Department Staff Report, the project as submitted is not consistent with Sea Level Rise

A handwritten signature in black ink, appearing to be 'MR', is enclosed within a rectangular box. Above the signature, the letters 'DS' are printed.

Criteria 8 and 10 in Section 133-50(a) of the Miami Beach Code.

D. The project would be consistent with the criteria and requirements of section 118-251 if the following conditions are met:

1. All of the original conditions of approval by this Board shall remain in full force and effect under the prior Final Order dated January 3, 2017 for DRB16-0054, except as modified herein.
2. All of the conditions of approval by this Board shall remain in full force and effect under the Final Order dated June 5, 2018 for DRB18-0236, except as modified herein.
3. All of the conditions of approval by this Board shall remain in full force and effect under the Final Order dated March 2, 2021 for DRB20-0617, except as modified herein.
4. Revised elevation, site plan and floor plan drawings for the proposed project at **7118-7140 Collins Avenue and 7121 - 7145 Harding Avenue** shall be submitted to and approved by staff; at a minimum, such drawings shall incorporate the following:
 - a. As per Section 142-743(c)(1)d. of the City code, a minimum of 20% of the gross floor area of the building shall consist of amenity space, subject to the review and approval of staff.
 - b. The final details of all proposed storefront systems and associated details shall be provided for all of the structures on the project site, in a manner to be reviewed and approved by staff consistent with the Design Review Criteria and/or the directions from the Board.
 - c. All window frames shall be composed of brushed anodized aluminum frames. All windows shall consist of clear glass, incorporate the minimum tint required by the energy code, in a manner to be reviewed and approved by staff consistent with the Design Review Criteria and/or the directions from the Board.
 - d. The final details of all exterior surface finishes and materials, including samples, shall be submitted, in a manner to be reviewed and approved by staff consistent with the Design Review Criteria and/or the directions from the Board.
 - e. The design of the window display shall be further refined to include an artistic feature on the proposed wall facing the sidewalk. The final design details shall be submitted, in a manner to be reviewed and approved by staff consistent with the Design Review Criteria and/or the directions from the Board.
 - f. The final design and details, including materials, exterior finishes, glazing, and any architectural projections and features, shall be provided in a

DS
MK

- manner to be reviewed and approved by staff consistent with the Design Review Criteria and/or the directions from the Board.
- g. A copy of all pages of the recorded Final Order shall be scanned into the plans submitted for building permit, and shall be located immediately after the front cover page of the permit plans.
 - h. Prior to the issuance of a Certificate of Occupancy, the project Architect shall verify, in writing, that the subject project has been constructed in accordance with the plans approved by the Planning Department for Building Permit.
5. A revised landscape plan, prepared by a Professional Landscape Architect, registered in the State of Florida, and corresponding site plan, shall be submitted to and approved by staff. The species type, quantity, dimensions, spacing, location and overall height of all plant material shall be clearly delineated and subject to the review and approval of staff. At a minimum, such plan shall incorporate the following:
- a. Prior to the issuance of a building permit, the applicant shall submit a tree protection plan for all trees to be retained on site. Such plan shall be subject to the review and approval of staff, and shall include, but not be limited to a sturdy tree protection fence installed at the dripline of the trees prior to any construction.
 - b. In order to identify, protect and preserve mature trees on site, which are suitable for retention and relocation, a Tree Report prepared by a Certified Tree Arborist shall be submitted for the mature trees on site.
 - c. Any tree identified to be in good overall condition shall be retained, and protected in its current location if it is not in conflict with the proposed development, or it shall be relocated on site, if determined feasible, subject to the review and approval of staff. A tree care and watering plan also prepared by a Certified Arborist shall be submitted prior to the issuance of a Building Permit or Tree Removal/Relocation Permit. Subsequent to any approved relocation, a monthly report prepared by a Certified Arborist shall be provided to staff describing the overall tree performance and adjustments to the maintenance plan in order to ensure survivability, such report shall continue for a period of 18 months unless determined otherwise by staff.
 - d. A fully automatic irrigation system with 100% coverage and an automatic rain sensor in order to render the system inoperative in the event of rain. Right-of-way areas shall also be incorporated as part of the irrigation system.
 - e. The utilization of root barriers and Silva Cells, as applicable, shall be clearly delineated on the revised landscape plan. Silva Cells or approved equal should be provided under the adjacent hardscape areas for trees located in public and private property subject to the review and approval of the CMB Urban Forester. A minimum of 1,000 CuFt of good quality planting soils

DS


shall be specified per tree, or 800 CuFt per tree when combined with other trees in the same general area.

- f. The applicant shall verify, prior to the issuance of a Building Permit, the exact location of all backflow preventors and all other related devices and fixtures. The location of backflow preventors, Siamese pipes or other related devices and fixtures, if any, and how they are screened with landscape material from the right-of-way, shall be clearly indicated on the site and landscape plans, and shall be subject to the review and approval of staff.
- g. Prior to the issuance of a Certificate of Occupancy, the Landscape Architect or the project architect shall verify, in writing, that the project is consistent with the site and landscape plans approved by the Planning Department for Building Permit.

In accordance with Section 118-262, the applicant, or the city manager on behalf of the City Administration, or an affected person, Miami Design Preservation League or Dade Heritage Trust may seek review of any order of the Design Review Board by the City Commission, except that orders granting or denying a request for rehearing shall not be reviewed by the Commission.

II. Variance(s)

- A. No variance(s) were filed as part of this application.

III. General Terms and Conditions applying to both 'I. Design Review Approval and 'II. Variances' noted above.

- A. If applicable, the applicant shall comply with the electric vehicle parking requirements, pursuant to Sec. 130-39 of the City Code.
- B. All new construction over 7,000 square feet shall be required to be, at a minimum, certified as LEED Gold by USGBC. In lieu of achieving LEED Gold certification, properties can elect to pay a sustainability fee, pursuant to Chapter 133 of the City Code. This fee is set as a percentage of the cost of construction.
- C. Where one or more parcels are unified for a single development, the property owner shall execute and record a unity of title or a covenant in lieu of unity of title, as may be applicable, in a form acceptable to the City Attorney.
- D. A Construction Parking and Traffic Management Plan (CPTMP) shall be approved by the Parking Director pursuant to Chapter 106, Article II, Division 3 of the City Code, prior to the issuance of a Building Permit.
- E. The final building plans shall meet all other requirements of the Land Development Regulations of the City Code.
- F. The Supplemental Final Order shall be recorded in the Public Records of Miami-Dade County, prior to the issuance of a Building Permit.

DS
12/8

- G. Satisfaction of all conditions is required for the Planning Department to give its approval on a Certificate of Occupancy; a Temporary Certificate of Occupancy or Partial Certificate of Occupancy may also be conditionally granted Planning Departmental approval.
- H. The Supplemental Final Order is not severable, and if any provision or condition hereof is held void or unconstitutional in a final decision by a court of competent jurisdiction, the order shall be returned to the Board for reconsideration as to whether the order meets the criteria for approval absent the stricken provision or condition, and/or it is appropriate to modify the remaining conditions or impose new conditions.
- I. The conditions of approval herein are binding on the applicant, the property's owners, operators, and all successors in interest and assigns.
- J. Nothing in this order authorizes a violation of the City Code or other applicable law, nor allows a relaxation of any requirement or standard set forth in the City Code.

IT IS HEREBY ORDERED, based upon the foregoing findings of fact, the evidence, information, testimony and materials presented at the public hearing, which are part of the record for this matter, and the staff report and analysis, which are adopted herein, including the staff recommendations which were adopted by the Board, as modified at the Board hearing, that the Application for Design Review approval is GRANTED and the application for a variance is APPROVED for the above-referenced project subject to those certain conditions specified in Paragraph I, II, III of the Findings of Fact, to which the applicant has agreed.

PROVIDED, the applicant shall build substantially in accordance with the plans approved by the Design Review Board, as determined by staff, entitled "72+ Collins Hotel & Condominium", as prepared by **Revuelta Architecture International**, dated May 9, 2022, and as approved by the Design Review Board, as determined by staff.

When requesting a building permit, the plans submitted to the Building Department for permit shall be consistent with the plans approved by the Board, modified in accordance with the conditions of approval that must be satisfied prior to permit issuance, as set forth in this Order, have been met.

The issuance of the approval does not relieve the applicant from obtaining all other required Municipal, County and/or State reviews and permits, including final zoning approval. If adequate handicapped access is not provided on the Board approved plans, this approval does not mean that such handicapped access is not required. When requesting Building permit, the plans submitted to the Building Department for permit shall be consistent with the plans approved by the Board, modified in accordance with the conditions set forth in this Order.

If the Full Building Permit for the project is not issued within eighteen (18) months of the meeting date at which the original approval was granted, the application will expire and become null and void, unless the applicant makes an application to the Board for an extension of time, in accordance with the requirements and procedures of Chapter 118 of the City Code, the granting of any such extension of time shall be at the discretion of the Board. If the Full Building Permit for the project shall expire for any reason (including but not limited to construction not commencing and continuing, with required inspections, in accordance with the applicable Building Code), the application will expire and become null and void.

DS
128

Page 6 of 6
DRB22-0835—7118-7140 Collins Avenue and 7121-7145 Harding Avenue
July 5, 2022

In accordance with Chapter 118 of the City Code, the violation of any conditions and safeguards that are a part of this Order shall be deemed a violation of the land development regulations of the City Code. Failure to comply with this **Order** shall subject the application to Chapter 118 of the City Code, for revocation or modification of the application.

Dated 8/15/2022 | 3:58 PM EDT

DESIGN REVIEW BOARD
THE CITY OF MIAMI BEACH, FLORIDA

DocuSigned by:




BY: DEC3ECF2EB68404...

Michael Belush, AICP
Chief of Planning and Zoning
For Chairman

STATE OF FLORIDA)
)SS
COUNTY OF MIAMI-DADE)

The foregoing instrument was acknowledged before me this 15th day of August 20 22 by Michael Belush, Chief of Planning and Zoning of the City of Miami Beach, Florida, a Florida Municipal Corporation, on behalf of the Corporation. He is personally known to me.




Notary:
Print Name Gabriela C. Freitas
Notary Public, State of Florida
My Commission Expires: Sept. 8, 2025
Commission Number: HH173574

{NOTARIAL SEAL}

Approved As To Form: Steven Rotlustein (8/15/2022 | 3:58 PM EDT)
City Attorney's Office: E8B54D68B07C409

Filed with the Clerk of the Design Review Board on Jessica Gonzalez (8/15/2022 | 4:12 PM EDT)
10FC3F3E9D654A5

DS
