




RD Architects
1800 SW 1st Avenue, Suite 607, Miami, Florida 33129
F: 786.762.2679 P: 305.831.9079 C: 305.282.0005
Email: rda@rda-archint.com
www.rda@rda-archint.com

AA26002510
STRUCTURAL ENGINEER:

CONSULTANT:

KEY PLAN



SIGNATURE / DATE / SEAL

Victor H. Rodriguez,
Registered Architect
State of Florida # AR0094965
786.762.2679 vhrdriguez@rda-archint.com

PERMIT SET

Table with 2 columns: Issue, Issue Date / For. Row 1: (1) 08.28.2016 / Design Review Board

DDCI Project #: 1615.00

Drawn by: URB
Approved by: VHR

SHEET INDEX

SCALE:
SHEET NO.

A-7.7

System No. W-L-3065
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 0 and 3/4 Hr (See Item 3)
W-L-3065
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. March 15, 2012
Page: 1 of 2

3. Cables - Aggregate cross-sectional area of cable in opening to be max 45 percent of the cross-sectional area of the opening...
W-L-3065
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. March 15, 2012
Page: 2 of 2

System No. W-L-2377
F Ratings - 1 and 2 Hr (See Items 1 and 3)
T Ratings - 1 and 2 Hr (See Items 1 and 3)
L - Rating at Ambient - Less than 1 CFM/Sq Ft
L - Rating at 400°F - 4 CFM/Sq Ft
W-L-2377
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. June 15, 2004
Page: 1 of 2

System No. W-L-2377
F Ratings - 1 and 2 Hr (See Items 1 and 3)
T Ratings - 1 and 2 Hr (See Items 1 and 3)
L - Rating at Ambient - Less than 1 CFM/Sq Ft
L - Rating at 400°F - 4 CFM/Sq Ft
W-L-2377
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. June 15, 2004
Page: 2 of 2

System No. W-L-8065
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 0 Hr
W-L-8065
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. October 08, 2007
Page: 1 of 3

System No. W-L-8065
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 0 Hr
W-L-8065
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. October 08, 2007
Page: 2 of 3

System No. W-L-8065
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 0 Hr
W-L-8065
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. October 08, 2007
Page: 3 of 3

System No. W-L-1095
F Ratings - 1 & 2 Hr (See Item 1)
T Ratings - 1 & 2 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFM/Sq Ft
L Rating At 400 F - 4 CFM/Sq ft
W-L-1095
Hilti Firestop Systems
Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. January 02, 1997
Page: 1 of 1

THE DESIGNS INDICATED IN THESE DRAWINGS ARE PROPERTY OF RD Architects. ALL COPYRIGHTS RESERVED © 2016