



August 07, 2023

FINAL DRB SUBMITTAL NARRATIVE LANDSCAPE COMMENTS

DRB22-0897

Job address: 1656 Alton Rd Miami Beach, FL 33139-2426

3. Provide a suspended paver system such as Silva Cells or equal for all ground floor trees planted adjacent to hardscape areas. Revise the landscape plans and show the limits of the suspended paver system and also provide the planting detail.

Response:

-We have provided a suspended paver system for the ground floor trees directly adjacent to the hardscape area. See sheet L-5 for details on the proposed suspended paver system.

A handwritten signature in black ink, appearing to read "Carolina Monteiro".

Carolina Monteiro, RLA

CLAD, LLC

(786) 253-7017

carolina@cladlandscape.com

Office contact:
+1 (786) 536-6076

@cladlandscape
www.cladlandscape.com
info@cladlandscape.com

8020 NE 4th Ave.
Studio 113
Miami, FL 33138