## PERMIT CORRECTIONS REPORT (BR2308351)

460 S S SHORE DR **PERMIT ADDRESS:** 

Miami Beach, FL 33141

**APPLICATION DATE:** 08/07/2023 0.00 **DESCRIPTION:** BVB20000687 /Sea wall Repair SQUARE FEET:

**EXPIRATION DATE: VALUATION:** \$8,900.00

**CONTACTS** Name Company **Address** 

Mario Tamayo Ciasa Engineering USA dba MA 20335 20335 West Country Club Drive, 2303 Applicant

aventura. FL 33180

**PARCEL:** 

MARIO TAMAYO [CGC151088: CIASA ENGINEERING USA IN 20335 WEST COUNTRY CLUB DRIVE, #2303 Contractor -

General

0232030070920

AVENTURA, FL 33180

460 S S SHORE DR FERNANDO FIGUEROA NORMANDY 460 LLC Owner MIAMI BEACH, FL -3314

**Application Review** Version: 2 Date Received: 08/15/2023 **Date Completed: 08/21/2023** Status: Pass

CHRISTINA PIERRE Ph: email: ChristinaPierre@miamibeachfl.go Permit Intake Review Status: Pass Assigned: 8/15/23 Completed: 8/21/23

Bldg - PR - Building - Residential -Date Received: 08/21/2023 **Date Completed: 08/31/2023** Status: Fail Version: 1

Marine Opt IN

**Building Review - R** Juan Bistolfi Ph: email: JuanBistolfi@miamibeachfl.gov Status: Pass Assigned: 8/21/23 Completed: 8/22/23

Electrical Review - R Status: Not Requir Assigned: 8/21/23 Completed: 8/21/23 Diego Martinez Ph: email: DiegoMartinez@miamibeachfl.gov

**Environmental** Status: Fail Assigned: 8/21/23 Completed: 8/22/23 Jordan Heinlein Ph: email: JordanHeinlein@miamibeachfl.gov Review - R

**Permit Landscape** Status: Not Requir(Assigned: 8/21/23 Completed: 8/22/23 Enrique Nunez Ph: email: EnriqueNunez@miamibeachfl.gov

Review Opt In

Planning Review - R Status: Pass Assigned: 8/21/23 Completed: 8/27/23 Irina Villegas Ph: email: irinavillegas@miamibeachfl.gov Opt In

**Public Works** Status: Fail Assigned: 8/21/23 Completed: 8/31/23 Eugene Egemba Ph: email: Eugene Egemba@miamibeachfl.gov

(Building Permits) -

R

Correction: General Correction

Comments:

Denied 08/30/2023. Provide the top of cap elevation for the seawall. If the top of cap elevation is less than 4.0 NAVD (5.26 NGVD) you will be required to raise the seawall to 4.0 NAVD. Note: All existing seawalls that require repairs, but the repairs are considered less than substantial and existing seawalls that fall below an elevation that incurs flooding to adjacent property and/ or public right of way shall have a minimum elevation of 4.0 feet NAVD88 if designed and constructed to accommodate a minimum elevation of 5.7 feet NAVD88. Note: Substantial repair or rehabilitation means, a) Any improvement and/or repairs to the existing seawall with a cost of \$300 or more per linear foot. (CMB Municode sec. 54-62; ORDINANCE NO. 2021- 4393).

Structural Review - R Status: Partial Fail Assigned: 8/21/23 Completed: 8/22/23 Jaime Cynamon Ph: email: JaimeCynamon@miamibeachfl.gov

Correction: General Correction

Comments:

BR2308351 - 08/22/2023 - Rev#1 by JHEC - EOR: Andres Perez, PE

460 S Shore Dr - BVB20000687 - Sea wall Repair.

Please address the comments listed below (FBC 7th edition - 2020, sections 107.3.5 8 & 1604.4):

1) Obtain county approval for the repair to the seawall (CMDC Sect. 14-48, class I permit).

Thank you. Contact info:

Reviewer: Jaime Cynamon - JaimeCynamon@miamibeachfl.gov, Ph.: (305)673-7610 ext. 26760

Supervisor: Adalberto Viciedo - Adalberto Viciedo @miamibeachfl.gov

**Submittal Version** Status: Fail Assigned: 8/31/23 Completed: 8/31/23 Rose Hernandez Ph: email: rosehernandez@miamibeachfl.gov Complete

Correction: Pending Uploads

Comments:

Submittal cycle has failed due to one or more failed review(s). If you need to resubmit plans, you must re-submit the entire set for the discipline requesting corrections, even if there are sheets with no corrections

If you have a question or concern on a review comment, you may email the reviewer directly. Or you may schedule an in-person

appointment at www.miamibeachfl.gov/buildingappt

Group Review - R

**Urban Forestry** Status: Pass Assigned: 8/21/23 Completed: 8/22/23 Jorge Nunez Ph: email: JorgeNunez@miamibeachfl.gov

August 31, 2023 Page 1 of 1