
Sidewalk Assessment Report

City of Miami Beach, Florida



Prepared for:

MIAMIBEACH

Prepared by:

Kimley»Horn

August 2023

Table of Contents

Table of Contents 2
Chapter 1 Introduction 3
Chapter 2 Methodology 3
2.1 Sidewalk Assessment Approach 3
2.2 Curb Ramp Assessment Approach 5
2.3 Recommended Treatments 6
Chapter 3 Sidewalk and Ramp Assessment Results 7
3.1 Sidewalk Condition Results 7
3.2 Sidewalk Prioritization Results 10
3.3 Curb Ramp Assessment Results 15
Chapter 4 Conclusion 15
4.1 Plan Approach 15
4.2 Continuous Plan Updates 15
Appendix A – Sidewalk Inventory and Condition
Appendix B – Distress Priority Rankings
Appendix C – Curb Ramp Inventory Condition

Chapter 1 Introduction

The City of Miami Beach executed a Sidewalk and Pavement Assessment to investigate the condition of its street, sidewalk, and curb ramp networks. The assessment will provide the City with asset inventories, conditions, repair treatment alternatives, estimated costs, and project priorities. This **Sidewalk Assessment Report** discusses the results from the sidewalk and curb ramp portion of the assessment. The results of the street pavement portion of the assessment are discussed within the Pavement Assessment Report.

Throughout the City, sidewalk conditions were identified based on condition data collected, such as visible damage or perceived non-conformance with design standards, resulting in a Sidewalk Condition Index (SCI) value. The SCI was combined with a Network Priority Index (NPI) to determine segments that had the greatest need for improvement and would provide the greatest community benefit when improved. Curb ramps were inventoried and assessed across multiple categories related to navigability.

A total of 203 miles of existing sidewalk and 5,047 curb ramps were assessed and analyzed.

Chapter 2 Methodology

2.1 Sidewalk Assessment Approach

The City of Miami Beach sidewalk network was evaluated using a modified PASER (Pavement Surface Evaluation and Rating) methodology. Visual observation of the sidewalk conditions were rated by inspection personnel on a scale of 10 (Failed) to 100 (Excellent) in multiples of 10. Observational factors that influenced the rating system include visible distresses, panel cracking, spalling, joint faulting, vegetation/debris, traversability, and general treatment. **Table 1** defines the assessment characteristics utilized.

Table 1 – Sidewalk PASER Rating Evaluation Criteria

Surface Rating	Condition and Visible Distress	General Treatment Measures
100	**New Construction** Visible Distress: None	No maintenance required
90	**Recent Construction; Like New** Visible Distress: Minor wearing of surface	No maintenance required
80	**Like New** Visible Distress: Little to no ¼" raised or depressed areas (< 2%) Up to 10% of the sidewalk panels with cracks or moderate spalling. Little to no debris/vegetation within sidewalk. Distresses causing little to no hindrance to traversability.	Little or no maintenance required Seal open cracks
70	**First Signs of Aging** Visible Distress: Similar to Rating 60, but with some criteria slightly better.	Replacement of individual panels with significant defects Grinding offset surfaces Seal open cracks and other routine maintenance
60	**Shows Signs of Aging** Visible Distress: Limited ¼" raised or depressed areas (2% - 5%) Up to 25% of the sidewalk panels with cracks or moderate spalling. Up to 10% covered by debris/vegetation. Distresses causing localized hindrance to traversability.	Replacement of individual panels with significant defects Grinding offset surfaces Seal open cracks and other routine maintenance
50	**Surface Aging** Visible Distress: Similar to Rating 40, but with some criteria slightly better.	Replacement of multiple panels or Extensive grinding offset surfaces
40	**Significant Aging** Visible Distress: Frequent ¼" raised or depressed areas (6%-10%) 25% to 50% of the sidewalk panels with cracks or moderate to severe spalling. Up to 25% covered by debris/vegetation. Distresses causing hindrance to traversability for most users.	Replacement of multiple panels or Extensive grinding offset surfaces
30	**Moderate Deterioration** Visible Distress: Similar to Rating 20, but with some criteria slightly better.	Replacement of extensive sections of sidewalk
20	**Severe Deterioration** Visible Distress: Frequent ¼" raised or depressed areas (> 10%) Up to 50% of the sidewalk panels severely cracked or with severe spalling. 25% - 50% covered by debris/vegetation. Distresses causing severe hindrance to traversability.	Majority of sidewalk segment needs full replacement.
10	**Failed** Visible Distress: Frequent ¼" raised or depressed areas (> 10%) Over 50% of the sidewalk panels severely cracked or with severe spalling. Over 50% covered by debris/vegetation. Sidewalk is not traversable due to distresses.	Total replacement

Sidewalk areas that exhibited localized distresses requiring near-term repairs were also measured to determine a length of distressed area, or a damage length. The damage length was used to adjust the initial PASER rating to calculate a sidewalk condition index (SCI).

$$SCI = PASER\ Rating - \left(\left(\frac{damage\ length}{sidewalk\ length}\right) \times\ 100\right)$$

If the resultant SCI value was less than zero, the PASER rating was reduced by 10 and no damage factor was applied. The SCI represents the condition of the sidewalk and will be scored on a 0-to-100-point scale with four associated ratings, as seen in **Table 2**. Sidewalk segments received a condition rating of "U.C." when they were observed to be under construction at the time of inspection and a rating of "N.A." when they were not accessible.

Table 2 – Sidewalk Condition Index (SCI) Categories

SCI Range	Condition Category
90-100	**Excellent**
60-89	**Good**
40-59	**Fair**
0-39	**Poor**
-	**U.C./N.A.**

2.2 Curb Ramp Assessment Approach

Curb ramps were inventoried and assessed for visual adequacy with regard to several categories related to navigability including detectable warnings, landing area, slope, and vertical discontinuity. Ramps that appeared visually "adequate" in all categories were assessed as "Adequate" overall. Failing to meet one category resulted in an overall rating of "Not Adequate". Curb Ramp assessment criteria are shown in **Table 3**. The results of the curb ramp inventory assessment are included in **Appendix C** and are also accessible via GIS shapefile and Excel table delivered to the City.

Table 3 – Curb Ramp Assessment Criteria

Condition	Criteria
Adequate	Detectable warning must be present, truncated dome-style, and in apparent good operating condition. Cast-in-place, glue down mats, and stamped concrete were all considered adequate. Warnings that are damaged and in need of repair are marked "Damaged".
	A 4' x 4' turn space is provided at the top of a perpendicular ramp or at the bottom of a parallel ramp.
	The slope of the ramp, estimated visually only, appears to be easily traversable by wheelchair (required is <8.33%).
	There is a flush transition between sidewalk/ramp and no visibly discernible vertical discontinuity is present.
Not Adequate	A ramp is present, but any one of the above criteria is not met.

2.3 Recommended Treatments

Sidewalk repair treatments are summarized in two categories: (1) **Global Sidewalk Reconstruction** and (2) **Isolated Sidewalk Repairs.**

Global Sidewalk Reconstruction includes the replacement of the entire sidewalk segment. Sidewalk segment condition (SCI) is an indication of the average condition along the entire segment and is used to indicate whether global reconstruction is required.

Isolated Sidewalk Repairs consist of localized replacement of partial and whole sidewalk panels or multiple panels. Isolated repairs are applied to areas of localized distresses, as was used in the SCI calculation. These distress repairs are typically applied to such distresses as buckling, faulting, spalling, shattered slabs, and anything outside of these classifications that appeared to present an immediate safety hazard for pedestrians.

Curb Ramp Repairs consist of detectable warning replacement, for missing or damaged detectable warning surfaces, and full ramp replacement, for any of the other assessment criteria not being met.

There may be localized sidewalk areas that require isolated repair while the overall sidewalk segment is in generally good condition. For this reason, it is important to consider repairs at both the global and localized level in order to maintain safe conditions. Sidewalk and ramp treatments are shown with planning-level unit costs in **Table 4**. Unit costs incorporate cost data from projects recently completed in Miami Beach and historical price trends throughout the state of Florida.

Table 4 – Sidewalk and Ramp Treatment Type Unit Costs

Treatment Type	Unit Cost	Unit
Global Sidewalk Reconstruction - Concrete	$70	SY
Global Sidewalk Reconstruction - Brick Pavers	$100	SY
Isolated Sidewalk Repairs	$135	SY
Curb Ramp - Not Adequate - Replace	$2,500	Ramp
Curb Ramp - Replace Detectable Warning (2' x 4')	$350	Ramp

Chapter 3 Sidewalk and Ramp Assessment Results

3.1 Sidewalk Condition Results

Approximately 203 miles of City-maintained sidewalks were visually inspected and rated in April 2023. The results of the inspection were analyzed to calculate a Sidewalk Condition Index (SCI). The average SCI of the sidewalk network is 82, which corresponds to a rating of **Good**. Sidewalk conditions are summarized in **Figure 1.** Sidewalk condition and distress repair locations are visually represented in **Figures 2a and 2b**. Individual sidewalk segment conditions are summarized in **Appendix A**.




Figure 1 – Sidewalk Condition Distribution




Figure 2a – Sidewalk Condition Index and Distress Repair Locations



Figure 2b – Sidewalk Condition Index and Distress Repair Locations

3.2 Sidewalk Prioritization Results

Sidewalk repairs were prioritized based on a combination of the SCI and Network Priority Index (NPI). SCI values were based on condition data collected, such as visible damage or perceived non-conformance with design standards. NPI was calculated based on two categories: (1) the physical proximity (**accessibility**) to activity generators such as schools, bus stops, parks, and other community attractors or destinations, and (2) the **connectivity** aspect to the sidewalk network. After weighting SCI and NPI, a total Priority Ranking Score (PRS) was determined to order segments.

The prioritization factors were determined in close coordination with the City to accurately reflect the City's vision for sidewalk repairs. These criteria were applied to individual sidewalk segments with an SCI of 70 or below. In total, there were **104 sidewalk segments** with an SCI of 70 or below. These 104 sidewalk segments totaled **7.7 miles** in length and approximately **$2.1 million** in global reconstruction costs. The segments were grouped into five priority groupings of similar cost based on preliminary ranges of NPI values. Additionally, the prioritization factors were applied to the localized severe distress areas as is shown in **Appendix B**. There was a total of **358 localized distress repairs** totaling approximately **$418,000**.

The separate Microsoft excel deliverable contains the condition and prioritization results for all sidewalk segments, distress repair locations, and curb ramps. The City may

Table 5 summarizes the criteria factors used in the prioritization analysis. **Tables 6** and **7** summarize the results of the sidewalk segment prioritization.

Table 5 – Sidewalk Prioritization Factors

Step 1: Determine Sidewalk Condition Index (SCI) Score		
Only those segments below SCI 70 are recommended and prioritized.		
SCI Score		**0 to 100**
Step 2: Determine Network Priority Index (NPI) Score		
Accessibility	**Buffer Distance**	**Points**
Schools	1/8 mile	20
Transit Stops	1/8 mile	20
Parks	1/8 mile	10
Commercial Zoning District	0 mile	20
Beach Access and Public Parking	1/8 mile	10
Connectivity	**Buffer Distance**	**Points**
Key Streets (Arterial, Collector)	-	10
Parallel Facilities	-	10
NPI Score		**0 to 100**
Step 3: Determine Priority Ranking Score (PRS)		
Category	**Recommended Distribution**	**Possible Score**
Sidewalk Condition Index (SCI) Score	60%	
Network Priority Index (NPI) Score	40%	
Total Priority Ranking Score (PRS)		**0 to 100**

Once prioritization factors were applied, and the NPI and PRS were determined for each segment, the sidewalk segments were then ranked in order of highest PRS to lowest and grouped into manageable, balanced, groupings based on PRS ranges and resulting cost. With approximately $2 million on total sidewalk segment repairs, a target was set for five groups of approximately $400 thousand each. The PRS value ranges in the table below result in five priority groupings to be utilized for future sidewalk segment rehabilitation. Due to the nature of the PRS calculation, which includes both SCI and NPI at weighted percentages, there are a range of sidewalk conditions (SCI) in each resulting Priority Group. The City may choose to use the accompanying excel file deliverable to adjust SCI/NPI weight percentages and PRS ranges, and thus resulting sidewalk groupings. This will allow the City to develop a plan that is realistic and implementable based on changing needs and potential budgetary constraints in future years.

Table 6 – Sidewalk Prioritization Priority Grouping Summary

PRS Range	Priority Group	Segments	Length (mi)	Cost	SCI min	SCI max
49 ≤ x	1	14	1.2	$405,000	10	58
43 ≤ x < 49	2	30	1.9	$466,900	37	68
40 ≤ x < 43	3	22	1.3	$374,300	50	69
36 ≤ x < 40	4	19	1.5	$390,500	40	69
x < 36	5	19	1.7	$458,800	60	69
Totals		**104**	**7.7**	**$2,095,500**	**-**	**-**

**Please note PRS were chosen with the goal of achieving a balanced budget across groupings. The PRS Range values in the table above hold no other significance to the analysis.*

Table 7 – Sidewalk Segment Prioritization

Segment ID	Street	Street From	Street To	Neighborhood	Length (ft)	Width (ft)	SCI	NPI	Priority Ranking Score	Cost	Rank	Priority Group
SW_3042	195-ALTON RAMPOF	I 195 RAMPOF	ALTON RD	Bayshore D	1,095	10	10	50	74.0	$85,200	1	1
SW_0732	WAYNE AVE	BRUCE ST	MICHAEL ST	North Shore B	586	9	20	50	68.0	$41,100	2	1
SW_1629	20TH ST	PARK AVE	WASHINGTON AVE	City Center B	279	5	30	60	66.0	$10,900	3	1
SW_2063	NORMANDY DR	VERSAILLES CT	VICHY DR	Normandy Isles A	444	10	34	60	63.6	$34,600	4	1
SW_3150	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	117	11	40	60	60.0	$10,100	5	1
SW_1302	71ST ST	RUE NOTRE DAME	VICHY DR	Normandy Isles A	570	11	40	50	56.0	$48,800	6	1
SW_2047	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	618	10	40	50	56.0	$48,100	6	1
SW_2780	MICHIGAN AVE	19TH ST	ALTON RD	Lower North Bay Road A	275	8	43	50	54.2	$17,200	8	1
SW_1114	BONITA DR	INDIAN CREEK DR	BONITA DR	North Shore D	261	3	50	60	54.0	$6,100	9	1
SW_0062	WASHINGTON AVE	2ND ST	3RD ST	Flamingo/Lummus A	408	12	56	60	50.4	$38,100	10	1
SW_1611	12TH ST	12TH ST	PENNSYLVANIA AVE	Flamingo/Lummus F	335	6	50	50	50.0	$15,700	11	1
SW_0058	85TH ST	BYRON AVE	CRESPI BLVD	North Shore A	85	5	50	50	50.0	$3,400	11	1
SW_2846	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Venetian Islands A	113	5	30	20	50.0	$4,400	11	1
SW_1021	BIARRITZ DR	EAST END	RUE NOTRE DAME	Normandy Isles A	1,060	5	58	60	49.2	$41,300	14	1
SW_1874	DREXEL AVE	15TH ST	16TH ST	Flamingo/Lummus D	514	5	66	70	48.4	$20,000	15	2
SW_0734	5TH ST	WASHINGTON AVE	COLLINS CT	South Pointe A	35	13	60	60	48.0	$3,600	16	2
SW_0342	7TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	148	9	60	60	48.0	$10,400	16	2
SW_0256	9TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	336	5	60	60	48.0	$13,100	16	2
SW_0264	9TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	334	6	60	60	48.0	$15,600	16	2
SW_1374	ALTON RD	52ND ST	53RD ST	La Gorce B	102	7	40	30	48.0	$5,600	16	2
SW_1837	DREXEL AVE	SOUTH END	ESPANOLA WAY	Flamingo/Lummus D	194	17	60	60	48.0	$25,700	16	2
SW_0019	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	735	4	60	60	48.0	$22,900	16	2
SW_1644	PARK AVE	20TH ST	21ST ST	City Center B	259	6	60	60	48.0	$12,100	16	2
SW_3156	PINE TREE DR	63RD ST	PINE TREE DR CIR	La Gorce A	226	5	40	30	48.0	$8,800	16	2
SW_1265	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	116	12	61	60	47.4	$10,900	25	2
SW_0023	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	329	6	62	60	46.8	$15,400	26	2
SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	317	6	57	50	45.8	$14,800	27	2
SW_2861	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Venetian Islands A	309	5	37	20	45.8	$12,100	27	2
SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	346	8	64	60	45.6	$21,600	29	2
SW_0333	ALTON RD	ALTON RD	SUNSET DR	Lower North Bay Road A	179	6	58	50	45.2	$8,400	30	2
SW_2666	BONITA DR	71ST ST	NW END	North Shore D	68	6	65	60	45.0	$3,200	31	2
SW_1578	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	182	6	59	50	44.6	$8,500	32	2
SW_2959	BAY RD	I 195	43RD ST	Nautilus G	628	5	59	50	44.6	$24,500	32	2
SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Nautilus A	745	5	66	60	44.4	$29,000	34	2
SW_0559	RUE VERSAILLES	BAY DR	BIARRITZ DR	Normandy Isles A	257	6	66	60	44.4	$12,000	34	2
SW_2984	ADAMS AVE	43RD CT	44TH CT	Nautilus G	363	4	53	40	44.2	$11,300	36	2
SW_0741	5TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	182	11	60	50	44.0	$15,600	37	2
SW_0943	WEST AVE	13TH ST	MONAD TER	Flamingo/Lummus E	96	6	60	50	44.0	$4,500	37	2

Segment ID	Street	Street From	Street To	Neighborhood	Length (ft)	Width (ft)	SCI	NPI	Priority Ranking Score	Cost	Rank	Priority Group
SW_0031	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	727	4	67	60	43.8	$22,700	39	2
SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	685	7	67	60	43.8	$37,300	39	2
SW_0015	BAY RD	18TH ST	20TH ST	Sunset Harbor A	678	6	68	60	43.2	$31,700	41	2
SW_0134	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	502	6	68	60	43.2	$23,500	41	2
SW_3100	LINCOLN RD	LINCOLN CT	WEST END	West Avenue and Bay Road A	85	8	68	60	43.2	$5,300	41	2
SW_3034	MICHIGAN AVE	43RD ST	43RD CT	Nautilus G	538	4	68	60	43.2	$16,800	41	2
SW_0795	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	352	7	69	60	42.6	$19,200	45	3
SW_2965	ALTON RD	43RD ST	I 195	Nautilus G	813	5	69	60	42.6	$31,700	45	3
SW_0682	JEFFERSON AVE	15TH ST	16TH ST	Flamingo/Lummus D	505	5	56	40	42.4	$19,700	47	3
SW_0748	COLLINS AVE	76TH ST	77TH ST	North Shore C	276	5	63	50	42.2	$10,800	48	3
SW_3031	44TH CT	NAUTILUS DR	ALTON RD	Nautilus G	225	5	50	30	42.0	$8,800	49	3
SW_0027	51ST ST	51ST ST	ALTON RD	La Gorce B	24	4	50	30	42.0	$800	49	3
SW_1388	53RD ST	EAST END	ALTON RD	La Gorce B	108	5	50	30	42.0	$4,200	49	3
SW_2727	56TH ST	LA GORCE DR	WEST END	La Gorce D	78	5	50	30	42.0	$3,100	49	3
SW_3148	BAY DR	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	102	6	50	30	42.0	$4,800	49	3
SW_2300	COLLINS AVE	60TH ST	63RD ST	North Shore F	35	8	50	30	42.0	$2,200	49	3
SW_0584	HAWTHORNE AVE	BAYSIDE LN	CRESPI BLVD	Biscayne Point A	392	5	64	50	41.6	$15,300	55	3
SW_1287	MERIDIAN AVE	6TH ST	7TH ST	Flamingo/Lummus G	415	6	65	50	41.0	$19,400	56	3
SW_0965	FLAMINGO WAY	WEST AVE	BAY RD	West Avenue and Bay Road A	329	5	59	40	40.6	$12,800	57	3
SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	1,310	4	66	50	40.4	$40,800	58	3
SW_0106	5TH ST	BEACH WALK	OCEAN DR	Flamingo/Lummus B	293	17	60	40	40.0	$38,800	59	3
SW_2085	BEACH WALK	8TH ST	BEACH WALK	Flamingo/Lummus B	505	18	60	40	40.0	$70,700	59	3
SW_1952	BYRON AVE	82ND ST	82ND TER	North Shore A	279	5	60	40	40.0	$10,900	59	3
SW_2674	CARLYLE AVE	INDIAN CREEK DR	71ST ST	North Shore D	225	6	60	40	40.0	$10,500	59	3
SW_1346	COLLINS AVE	23RD ST	24TH ST	City Center B	377	13	60	40	40.0	$38,200	59	3
SW_1485	COLLINS AVE	23RD ST	24TH ST	City Center B	51	7	60	40	40.0	$2,800	59	3
SW_2448	INDIAN CREEK DR	COLLINS AVE	43RD ST	Oceanfront A	74	10	60	40	40.0	$5,800	59	3
SW_2454	INDIAN CREEK DR	43RD ST	42ND ST	Oceanfront A	38	10	60	40	40.0	$3,000	59	3
SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	909	5	67	50	39.8	$35,400	67	4
SW_2849	ALTON RD	60TH ST	62ND ST	La Gorce B	655	5	54	30	39.6	$25,500	68	4
SW_3159	ALTON RD	48TH ST	LAKEVIEW DR	La Gorce B	170	6	54	30	39.6	$8,000	68	4
SW_0758	5TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	299	15	68	50	39.2	$34,900	70	4
SW_1495	JEFFERSON AVE	6TH ST	7TH ST	Flamingo/Lummus G	411	5	68	50	39.2	$16,000	70	4
SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	761	6	68	50	39.2	$35,600	70	4
SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	394	6	69	50	38.6	$18,400	73	4
SW_0686	BAY DR	BREST ESPLANADE	RUE VERSAILLES	Normandy Isles A	852	5	69	50	38.6	$33,200	73	4
SW_1702	COLLINS AVE	74TH ST	75TH ST	North Shore C	399	11	69	50	38.6	$34,200	73	4
SW_0718	HARDING AVE	67TH ST	69TH ST	North Shore E	1,244	6	69	50	38.6	$58,100	73	4
SW_2667	PINE TREE DR	SHERIDAN AVE	28TH ST	Bayshore A	415	5	63	40	38.2	$16,200	77	4
SW_3175	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	117	5	50	20	38.0	$4,600	78	4

Segment ID	Street	Street From	Street To	Neighborhood	Length (ft)	Width (ft)	SCI	NPI	Priority Ranking Score	Cost	Rank	Priority Group
SW_0196	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	319	8	64	40	37.6	$19,900	79	4
SW_0258	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	303	7	60	30	36.0	$16,500	80	4
SW_2962	BAY RD	I 195	43RD ST	Nautilus G	321	5	60	30	36.0	$12,500	80	4
SW_0600	BAYSIDE LN	SOUTH END	HAWTHORNE AVE	Biscayne Point A	102	5	60	30	36.0	$4,000	80	4
SW_1234	LINCOLN LN	MERIDIAN CT	MERIDIAN AVE	City Center A	112	6	60	30	36.0	$5,300	80	4
SW_3189	PINE TREE DR	37TH ST	35TH ST	Bayshore C	116	5	40	0	36.0	$4,600	80	4
SW_3190	PINE TREE DR	37TH ST	35TH ST	Bayshore C	161	6	40	0	36.0	$7,600	80	4
SW_0697	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	63	6	67	40	35.8	$3,000	86	5
SW_2449	TROUVILLE ESPLANADE	MARSEILLE DR	NORMANDY DR	Normandy Isles A	242	6	63	30	34.2	$11,300	87	5
SW_0571	HAWTHORNE AVE	CRESPI BLVD	79TH ST	Biscayne Point A	358	4	64	30	33.6	$11,200	88	5
SW_2068	BEACH WALK	BEACH WALK	10TH ST	Flamingo/Lummus B	620	19	60	20	32.0	$91,700	89	5
SW_2796	ALTON RD	57TH ST	56TH ST	La Gorce B	615	5	67	30	31.8	$24,000	90	5
SW_1169	EUCLID AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	190	6	67	30	31.8	$8,900	90	5
SW_0448	RUE BORDEAUX	BAY DR	BIARRITZ DR	Normandy Isles A	262	5	62	20	30.8	$10,200	92	5
SW_2072	TROUVILLE ESPLANADE	TROUVILLE ESPLANADE	CALAIS DR	Normandy Isles A	139	6	69	30	30.6	$6,500	93	5
SW_2945	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	Venetian Islands A	325	5	63	20	30.2	$12,700	94	5
SW_0617	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	Venetian Islands A	267	7	63	20	30.2	$14,600	94	5
SW_2309	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	245	6	66	20	28.4	$11,500	96	5
SW_1198	GARY AVE	MICHAEL ST	BRUCE ST	Biscayne Point B	36	6	60	10	28.0	$1,700	97	5
SW_1926	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	554	5	67	20	27.8	$21,600	98	5
SW_2896	DI LIDO DR	VENETIAN DI LIDO WAY	5TH DI LIDO TER	Venetian Islands A	291	5	68	20	27.2	$11,400	99	5
SW_1093	SHORE DR	BAY DR	RAY ST	Normandy Shores A	1,497	6	66	10	24.4	$69,900	100	5
SW_2958	1ST RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	240	5	60	0	24.0	$9,400	101	5
SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	1,527	6	67	10	23.8	$71,300	102	5
SW_1144	SHORE DR	MITCHELL ST	SARAZEN ST	Normandy Shores A	1,404	5	68	10	23.2	$54,600	103	5
SW_1208	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	342	5	66	0	20.4	$13,300	104	5

3.3 Curb Ramp Assessment Results

A total of 5,047 curb ramps were inventoried and visually assessed as part of this study. Of the ramps assessed, **156 ramps** were found to be **Not Adequate** due to a criterion not being met other than the detectable warning alone. An additional **1,980 curb ramps** were found to be adequate in all categories other than the **detectable warning** being either missing or damaged. The summary of these results with associated planning-level repair costs can be seen in **Table 8** below.

Table 8 – Curb Ramp Assessment Summary

	Detectable Warning Replacement	Not Adequate Ramp Replacement
Total Curb Ramps	1,980	156
Total Cost	$693,000	$390,000

Chapter 4 Conclusion

4.1 Plan Approach

The results for the sidewalk prioritization showed a range of geographic locations, distributed throughout various neighborhoods. In addition, there were several segments within the same roadway or within a vicinity of each other. Though sidewalk segments were grouped into five different levels, the City can choose sidewalk segments across all levels and do not need to follow an exact sequential ranking order. The intent of identifying the five priority groupings of sidewalk segments was to give the City the freedom to identify and assemble sidewalk segment projects “à la carte”. The timeline for the sidewalk improvements will be subject to the City‘s yearly budget, scheduling of pavement projects and equipment use, and other City development projects. The City can use the prioritized list to effectively advance implementation of high priority sidewalks and adjust annually based on the available resources and funding.

4.2 Continuous Plan Updates

The goal for the sidewalk maintenance plan is for the City to address the five priority groupings of sidewalk segments during the first several years of the program. As new sidewalk projects are implemented, the sidewalk segments that did not rank in the 5 priority groupings will need to be re-evaluated. The full list of 203 miles of segments provided in **Appendix A** can be used to identify sidewalk improvement projects. It is recommended that the City reassesses the condition of the sidewalk network every five years. Any changes to prioritization metrics in NPI should be addressed on five-year intervals as well, to ensure that the sidewalks with the highest safety needs and benefits are being addressed based on current data.

Appendix A:
Sidewalk Inventory and Condition



Kimley»Horn

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0287	10TH ST	MICHIGAN AVE	LENOX AVE	PCC	325	5	1,626	90	Excellent
SW_0293	10TH ST	LENOX AVE	ALTON RD	PCC	337	5	1,686	89	Good
SW_0300	10TH ST	MICHIGAN AVE	LENOX AVE	PCC	332	6	1,995	80	Good
SW_0306	10TH ST	LENOX AVE	ALTON RD	PCC	342	6	2,055	89	Good
SW_0421	10TH ST	OCEAN CT	COLLINS AVE	PCC	151	8	1,208	80	Good
SW_0425	10TH ST	OCEAN DR	OCEAN CT	PCC	147	8	1,175	80	Good
SW_0428	10TH ST	COLLINS AVE	COLLINS CT	PCC	145	8	1,156	90	Excellent
SW_0435	10TH ST	COLLINS CT	WASHINGTON AVE	PCC	149	8	1,194	90	Excellent
SW_1005	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	PCC	319	5	1,593	90	Excellent
SW_1015	10TH ST	EUCLID CT	MERIDIAN AVE	PCC	309	6	1,855	90	Excellent
SW_1025	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	PCC	318	5	1,591	90	Excellent
SW_1035	10TH ST	EUCLID CT	MERIDIAN AVE	PCC	323	6	1,939	90	Excellent
SW_1132	10TH ST	ALTON CT	WEST AVE	PCC	150	6	901	80	Good
SW_1133	10TH ST	ALTON RD	ALTON CT	PCC	160	6	958	90	Excellent
SW_1151	10TH ST	WEST AVE	WEST END	PCC	258	6	1,547	90	Excellent
SW_1170	10TH ST	ALTON RD	ALTON CT	PCC	171	5	855	80	Good
SW_1190	10TH ST	ALTON CT	WEST AVE	PCC	30	5	151	90	Excellent
SW_1202	10TH ST	ALTON CT	WEST AVE	PCC	106	14	1,484	90	Excellent
SW_1398	10TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	308	5	1,539	90	Excellent
SW_1417	10TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	303	6	1,817	90	Excellent
SW_1418	10TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	317	6	1,902	80	Good
SW_1424	10TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	322	5	1,609	90	Excellent
SW_1675	10TH ST	WASHINGTON AVE	WASHINGTON CT	PCC	321	7	2,245	90	Excellent
SW_1689	10TH ST	WASHINGTON AVE	WASHINGTON CT	PCC	316	6	1,894	80	Good
SW_2000	10TH ST	BEACH SVRD	BEACH WALK	BR	117	24	2,803	90	Excellent
SW_2007	10TH ST	BEACH SVRD	BEACH WALK	BR	76	30	2,274	90	Excellent
SW_3065	10TH ST	COLLINS AVE	COLLINS CT	PCC	163	6	978	90	Excellent
SW_3066	10TH ST	COLLINS CT	WASHINGTON AVE	PCC	150	8	1,200	90	Excellent
SW_3070	10TH ST	OCEAN DR	OCEAN CT	PCC	164	8	1,313	90	Excellent
SW_3079	10TH ST	OCEAN CT	COLLINS AVE	PCC	142	7	991	80	Good
SW_0325	11TH ST	MICHIGAN AVE	LENOX AVE	PCC	349	5	1,744	90	Excellent
SW_0331	11TH ST	LENOX AVE	ALTON RD	PCC	428	6	2,568	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0526	11TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	371	6	2,225	90	Excellent
SW_0533	11TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	351	5	1,756	90	Excellent
SW_0538	11TH ST	MICHIGAN AVE	LENOX AVE	PCC	390	7	2,727	90	Excellent
SW_0540	11TH ST	LENOX AVE	ALTON RD	PCC	368	7	2,578	90	Excellent
SW_0836	11TH ST	EUCLID CT	MERIDIAN AVE	PCC	328	6	1,966	90	Excellent
SW_0847	11TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	324	6	1,946	80	Good
SW_0894	11TH ST	COLLINS AVE	COLLINS CT	PCC	150	9	1,350	80	Good
SW_0908	11TH ST	COLLINS CT	WASHINGTON AVE	PCC	144	8	1,152	90	Excellent
SW_0910	11TH ST	OCEAN DR	OCEAN CT	PCC	161	8	1,289	90	Excellent
SW_0919	11TH ST	COLLINS AVE	COLLINS CT	PCC	155	8	1,237	80	Good
SW_0931	11TH ST	OCEAN CT	COLLINS AVE	PCC	159	8	1,272	90	Excellent
SW_0945	11TH ST	COLLINS CT	WASHINGTON AVE	PCC	161	8	1,286	80	Good
SW_0956	11TH ST	OCEAN CT	COLLINS AVE	PCC	151	9	1,363	90	Excellent
SW_0966	11TH ST	OCEAN DR	OCEAN CT	PCC	159	8	1,274	80	Good
SW_1040	11TH ST	ALTON RD	ALTON CT	PCC	160	6	961	90	Excellent
SW_1041	11TH ST	ALTON CT	WEST AVE	PCC	154	6	927	90	Excellent
SW_1051	11TH ST	ALTON RD	ALTON CT	PCC	168	6	1,008	90	Excellent
SW_1070	11TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	317	5	1,587	90	Excellent
SW_1071	11TH ST	ALTON CT	WEST AVE	PCC	151	5	756	80	Good
SW_1079	11TH ST	EUCLID CT	MERIDIAN AVE	PCC	318	6	1,909	90	Excellent
SW_1432	11TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	319	5	1,596	90	Excellent
SW_1436	11TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	325	5	1,624	90	Excellent
SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	PCC	439	7	3,075	90	Excellent
SW_1658	11TH ST	WASHINGTON AVE	WASHINGTON CT	PCC	420	6	2,517	80	Good
SW_1966	11TH ST	BEACH WALK	OCEAN DR	PCC	178	12	2,139	80	Good
SW_0065	12TH ST	LENOX CT	ALTON RD	PCC	341	6	2,045	90	Excellent
SW_0070	12TH ST	12TH ST	LENOX AVE	PCC	335	5	1,677	80	Good
SW_0583	12TH ST	LENOX AVE	LENOX CT	PCC	366	6	2,196	80	Good
SW_0717	12TH ST	MICHIGAN AVE	12TH ST	PCC	433	5	2,165	90	Excellent
SW_0827	12TH ST	COLLINS CT	WASHINGTON AVE	PCC	127	8	1,019	80	Good
SW_0840	12TH ST	COLLINS AVE	COLLINS CT	PCC	141	8	1,130	80	Good
SW_0851	12TH ST	OCEAN DR	OCEAN CT	PCC	159	7	1,115	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0861	12TH ST	OCEAN CT	COLLINS AVE	PCC	158	5	790	90	Excellent
SW_0862	12TH ST	COLLINS AVE	COLLINS CT	PCC	144	9	1,300	80	Good
SW_0863	12TH ST	OCEAN CT	COLLINS AVE	PCC	156	7	1,090	80	Good
SW_0870	12TH ST	COLLINS CT	WASHINGTON AVE	PCC	137	9	1,231	90	Excellent
SW_0878	12TH ST	EUCLID AVE	EUCLID CT	PCC	317	6	1,902	90	Excellent
SW_0891	12TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	PCC	314	6	1,886	80	Good
SW_0893	12TH ST	OCEAN DR	OCEAN CT	PCC	156	7	1,091	90	Excellent
SW_0903	12TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	312	6	1,873	70	Good
SW_0915	12TH ST	EUCLID CT	MERIDIAN AVE	PCC	315	4	1,262	80	Good
SW_1010	12TH ST	ALTON RD	ALTON CT	PCC	334	6	2,007	90	Excellent
SW_1050	12TH ST	ALTON RD	ALTON CT	PCC	329	6	1,977	80	Good
SW_1602	12TH ST	WASHINGTON AVE	DREXEL AVE	PCC	130	7	908	80	Good
SW_1611	12TH ST	12TH ST	PENNSYLVANIA AVE	PCC	335	6	2,008	50	Fair
SW_1618	12TH ST	WASHINGTON AVE	DREXEL AVE	PCC	154	7	1,080	80	Good
SW_1637	12TH ST	DREXEL AVE	12TH ST	PCC	360	5	1,801	80	Good
SW_1950	12TH ST	BEACH WALK	OCEAN DR	PCC	189	10	1,888	80	Good
SW_0093	13TH ST	MICHIGAN AVE	13TH ST	PCC	335	4	1,338	90	Excellent
SW_0100	13TH ST	LENOX AVE	LENOX CT	PCC	335	4	1,341	90	Excellent
SW_0109	13TH ST	MICHIGAN AVE	13TH ST	PCC	347	4	1,389	90	Excellent
SW_0114	13TH ST	LENOX AVE	LENOX CT	PCC	337	4	1,348	80	Good
SW_0744	13TH ST	COLLINS CT	WASHINGTON AVE	PCC	142	6	852	90	Excellent
SW_0753	13TH ST	OCEAN DR	OCEAN CT	PCC	165	8	1,319	80	Good
SW_0761	13TH ST	COLLINS AVE	COLLINS CT	PCC	151	7	1,056	90	Excellent
SW_0768	13TH ST	OCEAN CT	COLLINS AVE	PCC	148	7	1,039	80	Good
SW_0779	13TH ST	COLLINS AVE	COLLINS CT	PCC	144	10	1,442	90	Excellent
SW_0789	13TH ST	OCEAN CT	COLLINS AVE	PCC	142	8	1,137	80	Good
SW_0799	13TH ST	COLLINS CT	WASHINGTON AVE	PCC	148	9	1,330	80	Good
SW_0808	13TH ST	OCEAN DR	OCEAN CT	PCC	157	8	1,260	90	Excellent
SW_0953	13TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	316	6	1,896	80	Good
SW_0954	13TH ST	ALTON RD	ALTON CT	PCC	340	6	2,043	70	Good
SW_0964	13TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	316	6	1,893	90	Excellent
SW_0972	13TH ST	EUCLID AVE	EUCLID CT	PCC	315	6	1,890	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0981	13TH ST	EUCLID CT	MERIDIAN AVE	PCC	313	4	1,253	90	Excellent
SW_0983	13TH ST	ALTON RD	ALTON CT	PCC	334	5	1,672	90	Excellent
SW_1541	13TH ST	DREXEL CT	PENNSYLVANIA AVE	PCC	338	5	1,691	70	Good
SW_1553	13TH ST	WASHINGTON AVE	DREXEL AVE	PCC	202	5	1,009	80	Good
SW_1560	13TH ST	DREXEL CT	PENNSYLVANIA AVE	PCC	338	6	2,029	80	Good
SW_1578	13TH ST	WASHINGTON AVE	DREXEL AVE	PCC	182	6	1,090	59	Fair
SW_1918	13TH ST	BEACH WALK	OCEAN DR	PCC	141	10	1,406	80	Good
SW_1925	13TH ST	BEACH WALK	OCEAN DR	PCC	69	10	687	90	Excellent
SW_0798	14TH CT	ALTON CT	WEST AVE	PCC	148	6	889	70	Good
SW_0817	14TH CT	ALTON RD	ALTON CT	PCC	163	7	1,142	80	Good
SW_0837	14TH CT	ALTON RD	ALTON CT	PCC	175	6	1,052	80	Good
SW_0838	14TH CT	ALTON CT	WEST AVE	PCC	151	6	906	80	Good
SW_1049	14TH PL	PENNSYLVANIA CT	EUCLID AVE	PCC	309	6	1,856	80	Good
SW_1059	14TH PL	PENNSYLVANIA CT	EUCLID AVE	PCC	308	6	1,846	80	Good
SW_1069	14TH PL	EUCLID AVE	EUCLID CT	PCC	311	5	1,554	80	Good
SW_1080	14TH PL	EUCLID AVE	EUCLID CT	PCC	312	5	1,562	80	Good
SW_1203	14th PLACE	OCEAN DR	OCEAN CT	PCC	152	4	608	90	Excellent
SW_0147	14TH ST	MICHIGAN AVE	MICHIGAN CT	PCC	338	4	1,351	90	Excellent
SW_0157	14TH ST	LENOX CT	ALTON RD	PCC	356	4	1,422	90	Excellent
SW_0164	14TH ST	MICHIGAN CT	LENOX AVE	PCC	335	4	1,338	90	Excellent
SW_0175	14TH ST	LENOX AVE	LENOX CT	PCC	336	4	1,342	90	Excellent
SW_0693	14TH ST	OCEAN CT	COLLINS AVE	PCC	154	9	1,382	80	Good
SW_0694	14TH ST	COLLINS AVE	COLLINS CT	PCC	162	9	1,459	80	Good
SW_0703	14TH ST	OCEAN DR	OCEAN CT	PCC	158	8	1,266	90	Excellent
SW_0710	14TH ST	COLLINS CT	WASHINGTON AVE	PCC	146	10	1,458	80	Good
SW_0850	14TH ST	ALTON CT	WEST AVE	PCC	153	6	919	90	Excellent
SW_0892	14TH ST	ALTON RD	ALTON CT	PCC	159	6	951	70	Good
SW_0907	14TH ST	ALTON CT	WEST AVE	PCC	158	6	951	90	Excellent
SW_0916	14TH ST	ALTON RD	ALTON CT	PCC	153	6	920	90	Excellent
SW_0994	14TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	310	5	1,549	70	Good
SW_1007	14TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	314	6	1,885	70	Good
SW_1008	14TH ST	EUCLID CT	MERIDIAN AVE	PCC	307	6	1,845	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1011	14TH ST	BAY RD	WEST END	PCC	320	7	2,241	90	Excellent
SW_1012	14TH ST	WEST AVE	BAY RD	PCC	396	8	3,166	90	Excellent
SW_1026	14TH ST	EUCLID CT	MERIDIAN AVE	PCC	319	5	1,593	80	Good
SW_1027	14TH ST	WEST AVE	BAY RD	PCC	330	6	1,978	90	Excellent
SW_1161	14TH ST	OCEAN CT	COLLINS AVE	PCC	143	8	1,144	80	Good
SW_1171	14TH ST	OCEAN DR	OCEAN CT	PCC	149	7	1,045	90	Excellent
SW_1488	14TH ST	WASHINGTON AVE	DREXEL AVE	PCC	303	5	1,514	80	Good
SW_1505	14TH ST	DREXEL AVE	DREXEL CT	PCC	363	5	1,814	80	Good
SW_1513	14TH ST	WASHINGTON AVE	DREXEL AVE	PCC	259	5	1,294	80	Good
SW_1524	14TH ST	DREXEL AVE	DREXEL CT	PCC	334	5	1,671	80	Good
SW_1832	14TH ST	BEACH WALK	OCEAN DR	PCC	24	12	284	70	Good
SW_1839	14TH ST	BEACH WALK	OCEAN DR	PCC	28	11	306	70	Good
SW_1849	14TH ST	BEACH WALK	OCEAN DR	PCC	235	16	3,761	90	Excellent
SW_1911	14TH ST	BEACH WALK	OCEAN DR	PCC	46	12	552	90	Excellent
SW_2209	14TH ST	COLLINS CT	WASHINGTON AVE	PCC	154	6	926	90	Excellent
SW_2214	14TH ST	COLLINS AVE	COLLINS CT	PCC	155	7	1,085	80	Good
SW_0995	14TH TER	WEST AVE	BAY RD	PCC	334	5	1,671	80	Good
SW_1038	14TH TER	WEST AVE	BAY RD	PCC	174	5	870	70	Good
SW_3104	14TH TER	WEST AVE	BAY RD	PCC	162	5	812	-	U.C./N.A.
SW_0208	15TH ST	MICHIGAN AVE	LENOX AVE	PCC	316	6	1,894	90	Excellent
SW_0216	15TH ST	LENOX AVE	LENOX CT	PCC	342	9	3,082	80	Good
SW_0230	15TH ST	MICHIGAN AVE	LENOX AVE	PCC	324	5	1,621	80	Good
SW_0254	15TH ST	LENOX CT	ALTON RD	PCC	344	5	1,719	80	Good
SW_0702	15TH ST	ALTON RD	ALTON CT	PCC	157	8	1,257	84	Good
SW_0708	15TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	314	5	1,568	80	Good
SW_0716	15TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	305	5	1,524	80	Good
SW_0725	15TH ST	ALTON CT	WEST AVE	PCC	157	8	1,258	80	Good
SW_0736	15TH ST	ALTON RD	ALTON CT	PCC	153	9	1,376	80	Good
SW_0737	15TH ST	ALTON CT	WEST AVE	PCC	153	8	1,220	80	Good
SW_0763	15TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	309	5	1,546	90	Excellent
SW_0780	15TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	307	5	1,535	80	Good
SW_0848	15TH ST	WEST AVE	BAY RD	PCC	326	7	2,282	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0879	15TH ST	WEST AVE	BAY RD	PCC	310	8	2,477	80	Good
SW_1180	15TH ST	PENNSYLVANIA AVE	EUCLID AVE	PCC	313	6	1,880	90	Excellent
SW_1189	15TH ST	EUCLID AVE	MERIDIAN AVE	PCC	316	5	1,579	90	Excellent
SW_1201	15TH ST	PENNSYLVANIA AVE	EUCLID AVE	PCC	317	5	1,584	80	Good
SW_1211	15TH ST	EUCLID AVE	MERIDIAN AVE	PCC	322	5	1,608	90	Excellent
SW_1227	15TH ST	OCEAN DR	COLLINS AVE	PCC	254	10	2,536	80	Good
SW_1383	15TH ST	WASHINGTON AVE	DREXEL AVE	PCC	331	5	1,653	90	Excellent
SW_1390	15TH ST	WASHINGTON AVE	DREXEL AVE	PCC	328	10	3,276	80	Good
SW_1420	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	PCC	337	5	1,686	87	Good
SW_1425	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	PCC	337	5	1,685	80	Good
SW_2190	15TH ST	BEACH WALK	OCEAN DR	PCC	289	13	3,755	90	Excellent
SW_2251	15TH ST	OCEAN DR	COLLINS AVE	PCC	259	12	3,112	90	Excellent
SW_2260	15TH ST	BEACH WALK	OCEAN DR	PCC	164	11	1,799	80	Good
SW_2261	15TH ST	BEACH WALK	OCEAN DR	PCC	154	11	1,692	80	Good
SW_0651	15TH TER	ALTON CT	WEST AVE	PCC	150	6	899	70	Good
SW_0653	15TH TER	ALTON RD	ALTON CT	PCC	99	6	597	90	Excellent
SW_0676	15TH TER	ALTON RD	ALTON CT	PCC	165	5	825	90	Excellent
SW_0692	15TH TER	ALTON CT	WEST AVE	PCC	155	5	774	70	Good
SW_0760	15TH TER	WEST AVE	BAY RD	PCC	329	5	1,647	80	Good
SW_0807	15TH TER	WEST AVE	BAY RD	PCC	330	5	1,651	80	Good
SW_3105	15TH TER	ALTON RD	ALTON CT	PCC	67	6	405	70	Good
SW_0262	16TH ST	MICHIGAN AVE	LENOX AVE	PCC	335	5	1,677	80	Good
SW_0273	16TH ST	LENOX CT	ALTON RD	PCC	331	8	2,648	90	Excellent
SW_0279	16TH ST	MICHIGAN AVE	LENOX AVE	PCC	338	6	2,031	90	Excellent
SW_0288	16TH ST	LENOX AVE	LENOX CT	PCC	333	10	3,330	80	Good
SW_0509	16TH ST	ALTON RD	ALTON CT	PCC	156	7	1,091	90	Excellent
SW_0510	16TH ST	ALTON CT	WEST AVE	PCC	151	6	908	80	Good
SW_0550	16TH ST	ALTON RD	ALTON CT	PCC	158	6	950	71	Good
SW_0552	16TH ST	ALTON CT	WEST AVE	PCC	151	6	903	70	Good
SW_0556	16TH ST	WEST AVE	BAY RD	PCC	337	6	2,024	80	Good
SW_0701	16TH ST	BAY RD	WEST END	BR	282	10	2,821	90	Excellent
SW_0743	16TH ST	WEST AVE	BAY RD	PCC	334	5	1,672	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0792	16TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	311	5	1,555	90	Excellent
SW_0809	16TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	311	5	1,555	70	Good
SW_0819	16TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	313	5	1,563	90	Excellent
SW_0841	16TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	310	5	1,552	70	Good
SW_1231	16TH ST	PENNSYLVANIA AVE	EUCLID AVE	PCC	311	5	1,556	90	Excellent
SW_1240	16TH ST	EUCLID AVE	MERIDIAN AVE	PCC	313	5	1,567	90	Excellent
SW_1250	16TH ST	PENNSYLVANIA AVE	EUCLID AVE	PCC	310	5	1,551	90	Excellent
SW_1259	16TH ST	EUCLID AVE	MERIDIAN AVE	PCC	316	6	1,898	80	Good
SW_1317	16TH ST	WASHINGTON AVE	DREXEL AVE	PCC	372	7	2,601	80	Good
SW_1325	16TH ST	WASHINGTON AVE	DREXEL AVE	PCC	340	5	1,700	73	Good
SW_1354	16TH ST	DREXEL AVE	PENNSYLVANIA AVE	PCC	336	6	2,015	80	Good
SW_1376	16TH ST	DREXEL AVE	PENNSYLVANIA AVE	PCC	334	5	1,672	90	Excellent
SW_2075	16TH ST	COLLINS AVE	WASHINGTON AVE	PCC	455	11	5,005	80	Good
SW_2084	16TH ST	COLLINS AVE	WASHINGTON AVE	PCC	450	34	15,296	80	Good
SW_0148	17TH ST	WEST AVE	BAY RD	PCC	341	5	1,704	80	Good
SW_0182	17TH ST	ALTON CT	WEST AVE	PCC	334	6	2,003	80	Good
SW_0183	17TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	311	10	3,113	80	Good
SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	317	6	1,901	57	Fair
SW_0344	17TH ST	LENOX CT	ALTON RD	PCC	325	6	1,950	90	Excellent
SW_0356	17TH ST	MICHIGAN AVE	LENOX AVE	PCC	340	5	1,699	80	Good
SW_0368	17TH ST	MICHIGAN AVE	LENOX AVE	PCC	335	5	1,674	90	Excellent
SW_0386	17TH ST	LENOX AVE	LENOX CT	PCC	326	5	1,632	90	Excellent
SW_0932	17TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	323	5	1,616	80	Good
SW_0947	17TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	311	5	1,555	90	Excellent
SW_1162	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	PCC	250	10	2,497	-	U.C./N.A.
SW_1379	17TH ST	JAMES AVE	WASHINGTON AVE	PCC	308	10	3,075	80	Good
SW_1393	17TH ST	JAMES AVE	WASHINGTON AVE	PCC	316	5	1,578	80	Good
SW_1554	17TH ST	ALTON RD	ALTON CT	PCC	162	9	1,458	90	Excellent
SW_1561	17TH ST	ALTON CT	WEST AVE	PCC	148	6	887	90	Excellent
SW_1568	17TH ST	WEST AVE	BAY RD	PCC	116	7	814	90	Excellent
SW_1923	17TH ST	JACKIE GLEASON DR	DREXEL AVE	PCC	362	12	4,349	80	Good
SW_1939	17TH ST	JACKIE GLEASON DR	DREXEL AVE	PCC	374	10	3,740	70	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1940	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	PCC	336	6	2,019	80	Good
SW_1941	17TH ST	COLLINS AVE	JAMES AVE	PCC	279	6	1,672	90	Excellent
SW_1949	17TH ST	COLLINS AVE	JAMES AVE	PCC	261	7	1,825	70	Good
SW_1958	17TH ST	PENNSYLVANIA AVE	CONVENTION CENTER DR	PCC	341	7	2,385	80	Good
SW_1986	17TH ST	CONVENTION CENTER DR	MERIDIAN CT	PCC	349	7	2,442	80	Good
SW_2005	17TH ST	MERIDIAN CT	MERIDIAN AVE	PCC	248	9	2,233	70	Good
SW_2015	17TH ST	PENNSYLVANIA AVE	CONVENTION CENTER DR	PCC	154	10	1,535	80	Good
SW_2016	17TH ST	BEACH WALK	COLLINS AVE	PCC	1,112	7	7,787	80	Good
SW_2033	17TH ST	BEACH WALK	COLLINS AVE	PCC	273	29	7,930	90	Excellent
SW_2050	17TH ST	CONVENTION CENTER DR	MERIDIAN CT	PCC	193	10	1,932	80	Good
SW_2066	17TH ST	MERIDIAN CT	MERIDIAN AVE	PCC	279	9	2,509	90	Excellent
SW_3125	17TH ST	JACKIE GLEASON DR	DREXEL AVE	PCC	181	13	2,354	80	Good
SW_0023	18TH ST	WEST AVE	BAY RD	PCC	329	6	1,971	62	Good
SW_0028	18TH ST	BAY RD	PURDY AVE	PCC	165	10	1,648	80	Good
SW_0072	18TH ST	ALTON RD	WEST AVE	PCC	330	8	2,641	80	Good
SW_0096	18TH ST	BAY RD	PURDY AVE	PCC	181	6	1,085	80	Good
SW_0115	18TH ST	ALTON RD	WEST AVE	PCC	240	8	1,921	80	Good
SW_0137	18TH ST	WEST AVE	BAY RD	PCC	332	5	1,661	90	Excellent
SW_0434	18TH ST	MICHIGAN AVE	LENOX AVE	PCC	364	5	1,819	90	Excellent
SW_0449	18TH ST	MICHIGAN AVE	LENOX AVE	PCC	410	5	2,052	90	Excellent
SW_0918	18TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	341	5	1,704	90	Excellent
SW_0957	18TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	344	5	1,721	90	Excellent
SW_0987	18TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	305	5	1,524	80	Good
SW_0997	18TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	322	5	1,608	80	Good
SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	PCC	726	6	4,354	85	Good
SW_1404	18TH ST	JAMES AVE	WASHINGTON AVE	PCC	313	5	1,564	90	Excellent
SW_1405	18TH ST	JAMES AVE	WASHINGTON AVE	PCC	317	5	1,587	90	Excellent
SW_1867	18TH ST	COLLINS AVE	JAMES AVE	PCC	377	7	2,636	77	Good
SW_1875	18TH ST	COLLINS AVE	JAMES AVE	PCC	363	7	2,544	90	Excellent
SW_1910	18TH ST	BEACH SVRD	BEACH WALK	PCC	159	17	2,711	90	Excellent
SW_1932	18TH ST	BEACH WALK	COLLINS AVE	BR	205	21	4,308	80	Good
SW_1965	18TH ST	BEACH WALK	COLLINS AVE	PCC	1,182	8	9,458	77	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2139	18TH ST	DADE BLVD	ALTON RD	PCC	102	6	615	90	Excellent
SW_2164	18TH ST	DADE BLVD	ALTON RD	PCC	37	10	374	90	Excellent
SW_3042	195-ALTON RAMPOF	I 195 RAMPOF	ALTON RD	AC	1,095	10	10,948	10	Poor
SW_0968	19TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	353	5	1,766	80	Good
SW_1044	19TH ST	MERIDIAN AVE	JEFFERSON AVE	PCC	308	4	1,231	90	Excellent
SW_1073	19TH ST	CONVENTION CENTER DR	MERIDIAN AVE	PCC	255	10	2,547	90	Excellent
SW_1272	19TH ST	MICHIGAN AVE	ALTON RD	PCC	64	5	322	90	Excellent
SW_1441	19TH ST	JAMES AVE	PARK AVE	PCC	238	5	1,188	90	Excellent
SW_1451	19TH ST	PARK AVE	WASHINGTON AVE	PCC	78	5	390	80	Good
SW_1477	19TH ST	PARK AVE	WASHINGTON AVE	PCC	72	9	648	80	Good
SW_1490	19TH ST	JAMES AVE	PARK AVE	PCC	219	6	1,311	70	Good
SW_1491	19TH ST	LIBERTY AVE	JAMES AVE	PCC	93	7	652	80	Good
SW_1812	19TH ST	COLLINS AVE	LIBERTY AVE	PCC	317	6	1,899	90	Excellent
SW_1822	19TH ST	COLLINS AVE	LIBERTY AVE	PCC	354	5	1,769	90	Excellent
SW_1838	19TH ST	LIBERTY AVE	JAMES AVE	PCC	90	5	451	90	Excellent
SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	PCC	730	7	5,112	78	Good
SW_2811	19TH ST	MICHIGAN AVE	ALTON RD	PCC	667	5	3,336	77	Good
SW_2933	1ST DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,222	90	Excellent
SW_2934	1ST DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	242	5	1,209	90	Excellent
SW_2957	1ST RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	240	5	1,199	80	Good
SW_2958	1ST RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	240	5	1,202	60	Good
SW_0039	1ST ST	MERIDIAN AVE	WASHINGTON AVE	BR	40	14	556	90	Excellent
SW_0229	1ST ST	BEACH SVRD	OCEAN DR	BR	173	7	1,208	90	Excellent
SW_0234	1ST ST	BEACH SVRD	OCEAN DR	BR	261	10	2,613	80	Good
SW_0235	1ST ST	OCEAN CT	COLLINS AVE	PCC	145	5	725	80	Good
SW_0240	1ST ST	OCEAN DR	OCEAN CT	BR	126	5	632	80	Good
SW_0275	1ST ST	COLLINS CT	WASHINGTON AVE	PCC	139	10	1,392	80	Good
SW_0290	1ST ST	COLLINS CT	WASHINGTON AVE	PCC	137	9	1,229	90	Excellent
SW_0295	1ST ST	COLLINS AVE	COLLINS CT	PCC	144	8	1,150	90	Excellent
SW_0303	1ST ST	COLLINS AVE	COLLINS CT	PCC	147	9	1,322	90	Excellent
SW_0327	1ST ST	BEACH SVRD	OCEAN DR	BR	165	12	1,985	90	Excellent
SW_0334	1ST ST	BEACH SVRD	OCEAN DR	BR	259	13	3,369	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0357	1ST ST	OCEAN CT	COLLINS AVE	PCC	142	7	995	90	Excellent
SW_0431	1ST ST	MERIDIAN AVE	JEFFERSON AVE	PCC	336	7	2,354	87	Good
SW_0439	1ST ST	JEFFERSON AVE	MERIDIAN AVE	BR	37	8	295	90	Excellent
SW_0470	1ST ST	WASHINGTON AVE	MERIDIAN AVE	PCC	213	14	2,986	90	Excellent
SW_0515	1ST ST	MERIDIAN AVE	WASHINGTON AVE	PCC	205	7	1,432	90	Excellent
SW_0517	1ST ST	MERIDIAN AVE	WASHINGTON AVE	BR	32	11	347	90	Excellent
SW_0522	1ST ST	JEFFERSON AVE	MERIDIAN AVE	BR	36	9	328	90	Excellent
SW_0530	1ST ST	JEFFERSON AVE	MERIDIAN AVE	PCC	335	8	2,682	90	Excellent
SW_0633	1ST ST	ALTON RD	JEFFERSON AVE	PCC	140	10	1,396	90	Excellent
SW_0642	1ST ST	JEFFERSON AVE	ALTON RD	PCC	65	13	840	90	Excellent
SW_0652	1ST ST	JEFFERSON AVE	ALTON RD	PCC	193	9	1,739	90	Excellent
SW_0679	1ST ST	JEFFERSON AVE	ALTON RD	BR	35	9	317	90	Excellent
SW_1538	1ST ST	OCEAN DR	OCEAN CT	PCC	116	6	697	90	Excellent
SW_0001	20TH ST	SUNSET DR	WEST AVE	PCC	163	13	2,123	90	Excellent
SW_0002	20TH ST	SUNSET DR	WEST AVE	PCC	177	6	1,061	90	Excellent
SW_0012	20TH ST	SUNSET DR	WEST AVE	PCC	358	7	2,507	90	Excellent
SW_0021	20TH ST	WEST AVE	BAY RD	PCC	390	6	2,339	75	Good
SW_0033	20TH ST	BAY RD	PURDY AVE	PCC	256	6	1,533	70	Good
SW_0052	20TH ST	PURDY AVE	BAY RD	PCC	169	18	3,047	70	Good
SW_0061	20TH ST	BAY RD	WEST AVE	PCC	362	11	3,987	80	Good
SW_1492	20TH ST	LIBERTY AVE	PARK AVE	PCC	320	5	1,602	90	Excellent
SW_1494	20TH ST	WASHINGTON AVE	WEST END	PCC	226	6	1,359	90	Excellent
SW_1517	20TH ST	LIBERTY AVE	PARK AVE	PCC	329	6	1,972	77	Good
SW_1621	20TH ST	PARK AVE	WASHINGTON AVE	PCC	253	5	1,266	90	Excellent
SW_1629	20TH ST	PARK AVE	WASHINGTON AVE	PCC	279	5	1,396	30	Poor
SW_1766	20TH ST	COLLINS AVE	LIBERTY AVE	PCC	304	8	2,435	80	Good
SW_1775	20TH ST	COLLINS AVE	LIBERTY AVE	PCC	309	7	2,162	90	Excellent
SW_1866	20TH ST	BEACH WALK	COLLINS AVE	PCC	385	15	5,779	90	Excellent
SW_1883	20TH ST	BEACH WALK	COLLINS AVE	PCC	390	7	2,730	80	Good
SW_1892	20TH ST	BEACH WALK	COLLINS AVE	BR	302	31	9,362	90	Excellent
SW_1589	21ST ST	LIBERTY AVE	PARK AVE	PCC	302	6	1,812	70	Good
SW_1660	21ST ST	PARK AVE	WASHINGTON AVE	PCC	376	5	1,879	70	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1669	21ST ST	PARK AVE	WASHINGTON AVE	PCC	403	8	3,223	80	Good
SW_1690	21ST ST	LIBERTY AVE	PARK AVE	PCC	304	10	3,043	90	Excellent
SW_1707	21ST ST	COLLINS AVE	LIBERTY AVE	PCC	324	11	3,569	90	Excellent
SW_1717	21ST ST	COLLINS AVE	LIBERTY AVE	PCC	306	6	1,834	80	Good
SW_1759	21ST ST	MIAMI BEACH DR	COLLINS AVE	PCC	396	10	3,963	90	Excellent
SW_1785	21ST ST	MIAMI BEACH DR	COLLINS AVE	PCC	417	7	2,918	80	Good
SW_1804	21ST ST	BEACH WALK	MIAMI BEACH DR	PCC	81	38	3,065	90	Excellent
SW_2819	21ST ST	ALTON RD	BAY RD	PCC	281	5	1,407	80	Good
SW_2820	21ST ST	ALTON RD	BAY RD	PCC	257	4	1,027	90	Excellent
SW_1612	22ND ST	BEACH WALK	MIAMI BEACH DR	BR	109	9	977	90	Excellent
SW_1619	22ND ST	COLLINS AVE	LIBERTY AVE	PCC	312	12	3,750	90	Excellent
SW_1638	22ND ST	COLLINS AVE	LIBERTY AVE	PCC	326	11	3,583	80	Good
SW_1639	22ND ST	LIBERTY AVE	PARK AVE	PCC	279	8	2,229	90	Excellent
SW_1668	22ND ST	LIBERTY AVE	PARK AVE	PCC	324	10	3,240	80	Good
SW_1682	22ND ST	MIAMI BEACH DR	COLLINS AVE	PCC	398	9	3,586	90	Excellent
SW_1684	22ND ST	PARK AVE	WASHINGTON CT	PCC	225	5	1,123	90	Excellent
SW_1698	22ND ST	MIAMI BEACH DR	COLLINS AVE	PCC	418	9	3,759	90	Excellent
SW_1718	22ND ST	PARK AVE	WASHINGTON CT	PCC	194	6	1,161	80	Good
SW_1476	23RD ST	PARK AVE	DADE BLVD	PCC	110	10	1,100	70	Good
SW_1489	23RD ST	LIBERTY AVE	PARK AVE	PCC	316	10	3,161	70	Good
SW_1569	23RD ST	COLLINS AVE	LIBERTY AVE	PCC	291	11	3,205	80	Good
SW_1579	23RD ST	COLLINS AVE	EAST END	BR	565	15	8,473	90	Excellent
SW_1588	23RD ST	COLLINS AVE	LIBERTY AVE	PCC	316	15	4,733	80	Good
SW_1685	23RD ST	LIBERTY AVE	PARK AVE	PCC	276	10	2,759	90	Excellent
SW_1739	23RD ST	PARK AVE	DADE BLVD	PCC	113	9	1,021	70	Good
SW_2488	23RD ST	PRAIRIE AVE	MERIDIAN AVE	PCC	347	5	1,733	90	Excellent
SW_2538	23RD ST	PRAIRIE AVE	MERIDIAN AVE	PCC	372	5	1,858	80	Good
SW_2822	23RD ST	ALTON RD	BAY RD	PCC	245	5	1,225	90	Excellent
SW_2829	23RD ST	ALTON RD	BAY RD	PCC	250	5	1,249	80	Good
SW_0678	24TH ST	PROMENADE ST	COLLINS AVE	PCC	352	11	3,869	80	Good
SW_1440	24TH ST	FLAMINGO DR	PINE TREE DR	PCC	368	5	1,842	80	Good
SW_1535	24TH ST	PROMENADE ST	COLLINS AVE	PCC	405	12	4,862	78	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1555	24TH ST	PROMENADE ST	COLLINS AVE	BR	199	19	3,773	90	Excellent
SW_2257	24TH ST	FLAMINGO DR	PINE TREE DR	PCC	394	7	2,759	90	Excellent
SW_2280	24TH TER	FLAMINGO PL	PINE TREE DR	PCC	148	4	592	80	Good
SW_2359	24TH TER	FLAMINGO DR	FLAMINGO PL	PCC	180	4	720	80	Good
SW_2331	25TH ST	FLAMINGO PL	PINE TREE DR	PCC	159	4	638	80	Good
SW_2389	25TH ST	FLAMINGO DR	FLAMINGO PL	PCC	299	4	1,194	90	Excellent
SW_2498	25TH ST	FLAMINGO PL	PINE TREE DR	PCC	159	4	634	70	Good
SW_2565	25TH ST	FLAMINGO DR	FLAMINGO PL	PCC	285	4	1,139	80	Good
SW_2634	25TH ST	PROMENADE ST	COLLINS AVE	PCC	174	12	2,091	90	Excellent
SW_2656	25TH ST	PROMENADE ST	COLLINS AVE	PCC	202	7	1,416	100	Excellent
SW_2735	25TH ST	PROMENADE ST	COLLINS AVE	PCC	194	7	1,359	90	Excellent
SW_1595	26TH ST	PROMENADE ST	COLLINS AVE	PCC	173	6	1,035	90	Excellent
SW_1714	26TH ST	INDIAN CREEK DR	COLLINS AVE	PCC	140	5	702	80	Good
SW_1732	26TH ST	INDIAN CREEK DR	COLLINS AVE	PCC	35	6	208	100	Excellent
SW_2536	26TH ST	FLAMINGO PL	PINE TREE DR	PCC	197	4	789	90	Excellent
SW_2577	26TH ST	PROMENADE ST	COLLINS AVE	PCC	291	6	1,745	80	Good
SW_2579	26TH ST	FLAMINGO DR	FLAMINGO PL	PCC	241	4	965	90	Excellent
SW_2592	26TH ST	PROMENADE ST	COLLINS AVE	PCC	173	5	863	90	Excellent
SW_2610	26TH ST	PROMENADE ST	COLLINS AVE	PCC	85	6	513	90	Excellent
SW_2633	26TH ST	INDIAN CREEK DR	COLLINS AVE	PCC	54	11	589	100	Excellent
SW_2684	26TH ST	FLAMINGO DR	FLAMINGO PL	PCC	238	5	1,190	90	Excellent
SW_2688	26TH ST	FLAMINGO PL	PINE TREE DR	PCC	168	7	1,179	75	Good
SW_2503	27TH ST	PROMENADE ST	COLLINS AVE	PCC	279	5	1,396	80	Good
SW_2516	27TH ST	PROMENADE ST	COLLINS AVE	PCC	289	5	1,444	80	Good
SW_2555	27TH ST	PROMENADE ST	COLLINS AVE	PCC	172	10	1,719	90	Excellent
SW_2591	27TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	373	4	1,492	80	Good
SW_2606	27TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	354	5	1,768	90	Excellent
SW_2831	27TH ST	ALTON RD	BAY RD	PCC	254	5	1,271	80	Good
SW_2832	27TH ST	ALTON RD	BAY RD	PCC	256	5	1,278	80	Good
SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	PCC	498	6	2,988	80	Good
SW_2433	28TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	132	5	659	86	Good
SW_2476	28TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	248	4	994	88	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2509	28TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	143	6	857	90	Excellent
SW_2533	28TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	241	6	1,445	90	Excellent
SW_2613	28TH ST	PRAIRIE AVE	MERIDIAN AVE	PCC	320	5	1,602	90	Excellent
SW_2651	28TH ST	PRAIRIE AVE	PRAIRIE AVE	PCC	173	6	1,036	90	Excellent
SW_2669	28TH ST	FLAMINGO DR	PINE TREE DR	PCC	52	5	262	90	Excellent
SW_2691	28TH ST	FLAMINGO DR	PINE TREE DR	PCC	105	4	421	80	Good
SW_2320	29TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	246	5	1,232	90	Excellent
SW_2322	29TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	175	5	873	80	Good
SW_2373	29TH ST	PROMENADE ST	29TH ST	PCC	166	8	1,331	90	Excellent
SW_2395	29TH ST	BOARD WALK	PROMENADE ST	BR	258	24	6,203	90	Excellent
SW_2415	29TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	154	6	923	90	Excellent
SW_2420	29TH ST	PROMENADE ST	29TH ST	BR	62	6	375	90	Excellent
SW_2432	29TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	239	6	1,431	80	Good
SW_2443	29TH ST	COLLINS AVE	29TH ST	BR	251	6	1,506	90	Excellent
SW_2834	29TH ST	ALTON RD	BAY RD	PCC	253	5	1,267	80	Good
SW_2835	29TH ST	ALTON RD	BAY RD	PCC	265	5	1,327	80	Good
SW_3021	29TH ST	BAY RD	LAKE AVE	PCC	198	5	991	90	Excellent
SW_3188	29TH ST	COLLINS AVE	29TH ST	PCC	192	6	1,152	90	Excellent
SW_2930	2ND DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,220	80	Good
SW_2931	2ND DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	245	5	1,226	90	Excellent
SW_2954	2ND RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	234	5	1,171	80	Good
SW_2955	2ND RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	244	5	1,222	90	Excellent
SW_0018	2ND ST	MICHIGAN AVE	ALTON RD	PCC	56	5	280	80	Good
SW_0103	2ND ST	OCEAN DR	OCEAN CT	PCC	126	7	885	90	Excellent
SW_0294	2ND ST	BEACH SVRD	OCEAN DR	PCC	310	9	2,791	90	Excellent
SW_0318	2ND ST	COLLINS AVE	COLLINS CT	PCC	157	5	786	90	Excellent
SW_0323	2ND ST	COLLINS CT	WASHINGTON AVE	PCC	148	7	1,036	100	Excellent
SW_0341	2ND ST	OCEAN DR	OCEAN CT	PCC	137	5	687	90	Excellent
SW_0345	2ND ST	COLLINS CT	WASHINGTON AVE	PCC	159	6	952	90	Excellent
SW_0349	2ND ST	COLLINS AVE	COLLINS CT	PCC	169	5	847	90	Excellent
SW_0424	2ND ST	EUCLID CT	MERIDIAN AVE	PCC	283	6	1,700	90	Excellent
SW_0433	2ND ST	EUCLID CT	MERIDIAN AVE	PCC	304	7	2,131	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0680	2ND ST	JEFFERSON CT	MICHIGAN AVE	PCC	392	6	2,351	85	Good
SW_0687	2ND ST	MERIDIAN CT	JEFFERSON AVE	PCC	346	6	2,076	90	Excellent
SW_0706	2ND ST	JEFFERSON AVE	JEFFERSON CT	PCC	347	5	1,734	79	Good
SW_0714	2ND ST	MERIDIAN CT	JEFFERSON AVE	PCC	326	5	1,628	70	Good
SW_0733	2ND ST	MERIDIAN CT	JEFFERSON AVE	PCC	477	6	2,864	90	Excellent
SW_1724	2ND ST	OCEAN CT	COLLINS AVE	PCC	145	8	1,162	90	Excellent
SW_2171	2ND ST	OCEAN CT	COLLINS AVE	PCC	151	12	1,815	90	Excellent
SW_1820	30TH ST	PINE TREE DR	SHERIDAN AVE	PCC	240	5	1,199	90	Excellent
SW_2254	30TH ST	BOARD WALK	COLLINS AVE	PCC	278	5	1,389	80	Good
SW_2274	30TH ST	BOARD WALK	COLLINS AVE	PCC	358	4	1,432	90	Excellent
SW_2285	30TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	423	5	2,114	76	Good
SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	431	6	2,585	90	Excellent
SW_2467	30TH ST	BOARD WALK	COLLINS AVE	PCC	106	9	956	90	Excellent
SW_2188	31ST ST	BOARD WALK	COLLINS AVE	PCC	320	5	1,600	80	Good
SW_2204	31ST ST	COLLINS AVE	INDIAN CREEK DR	PCC	369	6	2,214	89	Good
SW_2212	31ST ST	BOARD WALK	COLLINS AVE	PCC	278	5	1,389	73	Good
SW_2220	31ST ST	COLLINS AVE	INDIAN CREEK DR	PCC	376	5	1,881	80	Good
SW_2477	31ST ST	BOARD WALK	COLLINS AVE	PCC	137	11	1,506	90	Excellent
SW_1636	32ND ST	BOARD WALK	COLLINS AVE	PCC	207	9	1,863	90	Excellent
SW_2057	32ND ST	COLLINS AVE	INDIAN CREEK DR	PCC	258	6	1,551	90	Excellent
SW_2080	32ND ST	BOARD WALK	COLLINS AVE	PCC	310	6	1,858	90	Excellent
SW_2115	32ND ST	BOARD WALK	COLLINS AVE	PCC	305	6	1,833	80	Good
SW_2146	32ND ST	COLLINS AVE	INDIAN CREEK DR	PCC	259	7	1,815	90	Excellent
SW_1993	33RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	210	5	1,048	90	Excellent
SW_2022	33RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	223	5	1,114	90	Excellent
SW_2720	33RD ST	FLAMINGO DR	PINE TREE DR	PCC	376	5	1,878	90	Excellent
SW_2729	33RD ST	FLAMINGO DR	PINE TREE DR	PCC	369	5	1,845	80	Good
SW_0493	34TH ST	PRAIRIE AVE	CHASE AVE	PCC	400	5	1,999	90	Excellent
SW_0820	34TH ST	GARDEN AVE	ALTON RD	PCC	260	5	1,299	70	Good
SW_1705	34TH ST	PINE TREE DR	SHERIDAN AVE	PCC	374	5	1,871	90	Excellent
SW_1887	34TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	138	5	689	90	Excellent
SW_1896	34TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	66	5	332	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1915	34TH ST	BOARD WALK	COLLINS AVE	PCC	287	9	2,583	90	Excellent
SW_1937	34TH ST	BOARD WALK	COLLINS AVE	PCC	245	5	1,224	90	Excellent
SW_1945	34TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	208	5	1,040	90	Excellent
SW_2297	34TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	314	5	1,568	80	Good
SW_2384	34TH ST	ROYAL PALM AVE	PRAIRIE AVE	PCC	162	5	808	90	Excellent
SW_2391	34TH ST	ROYAL PALM AVE	PRAIRIE AVE	PCC	195	5	975	80	Good
SW_2452	34TH ST	BOARD WALK	COLLINS AVE	PCC	305	10	3,053	90	Excellent
SW_2573	34TH ST	PRAIRIE AVE	CHASE AVE	PCC	431	5	2,153	90	Excellent
SW_2594	34TH ST	CHASE AVE	CHASE AVE	PCC	78	5	390	80	Good
SW_2771	34TH ST	GARDEN AVE	ALTON RD	PCC	616	5	3,082	80	Good
SW_0490	35TH ST	FLAMINGO DR	PINE TREE DR	PCC	812	5	4,061	79	Good
SW_0502	35TH ST	FLAMINGO DR	PINE TREE DR	PCC	349	5	1,746	76	Good
SW_1771	35TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	229	5	1,147	90	Excellent
SW_1782	35TH ST	BOARD WALK	COLLINS AVE	PCC	223	6	1,339	90	Excellent
SW_1783	35TH ST	BOARD WALK	COLLINS AVE	PCC	45	5	225	90	Excellent
SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	230	5	1,149	90	Excellent
SW_1826	35TH ST	BOARD WALK	COLLINS AVE	PCC	265	5	1,327	72	Good
SW_2435	35TH ST	BOARD WALK	COLLINS AVE	PCC	205	9	1,845	90	Excellent
SW_3187	35TH ST	BOARD WALK	COLLINS AVE	PCC	200	9	1,797	90	Excellent
SW_3191	35TH ST	FLAMINGO DR	PINE TREE DR	PCC	254	5	1,270	100	Excellent
SW_1648	36TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	318	6	1,909	90	Excellent
SW_1664	36TH ST	BOARD WALK	COLLINS AVE	PCC	343	7	2,404	70	Good
SW_1712	36TH ST	BOARD WALK	COLLINS AVE	BR	28	5	140	90	Excellent
SW_1721	36TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	313	5	1,566	90	Excellent
SW_1731	36TH ST	BOARD WALK	COLLINS AVE	PCC	92	6	553	90	Excellent
SW_1745	36TH ST	BOARD WALK	COLLINS AVE	PCC	146	5	729	80	Good
SW_2137	36TH ST	BOARD WALK	COLLINS AVE	PCC	115	9	1,032	90	Excellent
SW_0529	37TH ST	ROYAL PALM AVE	PRAIRIE AVE	PCC	371	5	1,854	90	Excellent
SW_1208	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	342	5	1,710	66	Good
SW_1352	37TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	314	5	1,570	80	Good
SW_1357	37TH ST	PINE TREE DR	SHERIDAN AVE	PCC	380	5	1,898	80	Good
SW_1397	37TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	314	5	1,568	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1415	37TH ST	BOARD WALK	COLLINS AVE	PCC	258	6	1,547	90	Excellent
SW_1455	37TH ST	BOARD WALK	COLLINS AVE	PCC	311	5	1,553	90	Excellent
SW_2180	37TH ST	BOARD WALK	COLLINS AVE	PCC	105	12	1,258	90	Excellent
SW_2232	37TH ST	PRAIRIE AVE	CHASE AVE	PCC	316	5	1,582	90	Excellent
SW_2332	37TH ST	ROYAL PALM AVE	PRAIRIE AVE	PCC	373	4	1,491	90	Excellent
SW_2471	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	333	5	1,663	80	Good
SW_2619	37TH ST	PINE TREE DR	SHERIDAN AVE	PCC	382	5	1,911	80	Good
SW_2695	37TH ST	PRAIRIE AVE	CHASE AVE	PCC	332	5	1,662	90	Excellent
SW_1209	38TH ST	BOARD WALK	COLLINS AVE	PCC	314	6	1,881	90	Excellent
SW_1235	38TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	345	6	2,069	90	Excellent
SW_1285	38TH ST	BOARD WALK	COLLINS AVE	PCC	258	6	1,549	80	Good
SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	354	6	2,125	80	Good
SW_2230	38TH ST	BOARD WALK	COLLINS AVE	PCC	101	13	1,314	90	Excellent
SW_0991	39TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	353	6	2,115	80	Good
SW_1127	39TH ST	BOARD WALK	COLLINS AVE	PCC	302	5	1,510	90	Excellent
SW_1148	39TH ST	BOARD WALK	COLLINS AVE	PCC	248	6	1,487	80	Good
SW_2276	39TH ST	BOARD WALK	COLLINS AVE	PCC	122	13	1,581	90	Excellent
SW_2298	39TH ST	MERIDIAN AVE	GARDEN AVE	PCC	328	4	1,311	80	Good
SW_2561	39TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	353	5	1,766	90	Excellent
SW_2623	39TH ST	MERIDIAN AVE	GARDEN AVE	PCC	358	10	3,581	80	Good
SW_2791	39TH ST	GARDEN AVE	ALTON RD	PCC	230	5	1,148	80	Good
SW_2800	39TH ST	GARDEN AVE	ALTON RD	PCC	214	6	1,283	90	Excellent
SW_2927	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,221	90	Excellent
SW_2928	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	241	5	1,207	82	Good
SW_2845	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	126	5	630	90	Excellent
SW_2848	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	247	5	1,234	80	Good
SW_3175	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	117	5	585	50	Fair
SW_0077	3RD ST	COLLINS CT	WASHINGTON AVE	PCC	155	7	1,087	80	Good
SW_0085	3RD ST	COLLINS AVE	COLLINS CT	PCC	158	4	632	80	Good
SW_0090	3RD ST	COLLINS AVE	COLLINS CT	PCC	153	5	767	80	Good
SW_0111	3RD ST	COLLINS CT	WASHINGTON AVE	PCC	145	6	868	80	Good
SW_0143	3RD ST	OCEAN CT	COLLINS AVE	PCC	154	6	923	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0150	3RD ST	OCEAN DR	OCEAN CT	PCC	127	6	763	100	Excellent
SW_0165	3RD ST	OCEAN CT	COLLINS AVE	PCC	162	5	809	80	Good
SW_0740	3RD ST	JEFFERSON CT	MICHIGAN AVE	PCC	355	7	2,484	90	Excellent
SW_0757	3RD ST	JEFFERSON CT	MICHIGAN AVE	PCC	341	8	2,730	89	Good
SW_0784	3RD ST	EUCLID AVE	EUCLID CT	PCC	361	7	2,530	80	Good
SW_0795	3RD ST	EUCLID AVE	EUCLID CT	PCC	352	7	2,462	69	Good
SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	PCC	346	8	2,770	64	Good
SW_1003	3RD ST	MERIDIAN AVE	MERIDIAN CT	PCC	334	8	2,671	90	Excellent
SW_2315	3RD ST	OCEAN DR	OCEAN CT	PCC	131	6	785	90	Excellent
SW_0637	40TH ST	FLAMINGO DR	PINE TREE DR	PCC	141	4	564	70	Good
SW_0899	40TH ST	BOARD WALK	COLLINS AVE	PCC	242	5	1,212	90	Excellent
SW_0961	40TH ST	BOARD WALK	COLLINS AVE	PCC	315	5	1,573	80	Good
SW_1680	40TH ST	BOARD WALK	COLLINS AVE	PCC	100	7	697	90	Excellent
SW_2231	40TH ST	PRAIRIE CT	CHASE AVE	PCC	323	5	1,617	79	Good
SW_2304	40TH ST	ROYAL PALM AVE	PRAIRIE AVE	BR	349	6	2,095	90	Excellent
SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	BR	491	6	2,946	80	Good
SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	316	5	1,578	88	Good
SW_2620	40TH ST	PINE TREE DR	SHERIDAN AVE	PCC	197	6	1,182	90	Excellent
SW_2635	40TH ST	PINE TREE DR	SHERIDAN AVE	PCC	184	5	921	90	Excellent
SW_2640	40TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	311	5	1,555	90	Excellent
SW_2679	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	485	5	2,423	80	Good
SW_2683	40TH ST	MERIDIAN AVE	GARDEN AVE	PCC	369	5	1,843	80	Good
SW_2686	40TH ST	ROYAL PALM AVE	PRAIRIE AVE	PCC	345	5	1,727	90	Excellent
SW_2733	40TH ST	PRAIRIE CT	CHASE AVE	PCC	301	7	2,110	80	Good
SW_2749	40TH ST	MERIDIAN AVE	GARDEN AVE	PCC	334	5	1,671	80	Good
SW_0581	41ST ST	CHASE AVE	MERIDIAN AVE	BR	194	9	1,742	90	Excellent
SW_0618	41ST ST	GARDEN AVE	I 195	BR	472	11	5,194	80	Good
SW_0644	41ST ST	BOARD WALK	COLLINS AVE	PCC	269	5	1,343	90	Excellent
SW_0783	41ST ST	BOARD WALK	COLLINS AVE	PCC	262	6	1,573	90	Excellent
SW_1575	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	BR	586	4	2,343	70	Good
SW_1656	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	BR	538	9	4,843	70	Good
SW_1722	41ST ST	PRAIRIE AVE	CHASE AVE	BR	369	9	3,322	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1723	41ST ST	BOARD WALK	COLLINS AVE	PCC	98	6	588	90	Excellent
SW_1800	41ST ST	PINE TREE DR	PINE TREE DR	BR	204	5	1,019	75	Good
SW_1828	41ST ST	PINE TREE DR	SHERIDAN AVE	BR	375	5	1,877	80	Good
SW_2163	41ST ST	PRAIRIE AVE	CHASE AVE	BR	647	5	3,234	78	Good
SW_2453	41ST ST	INDIAN CREEK DR	PINE TREE DR	BR	410	4	1,638	90	Excellent
SW_2465	41ST ST	INDIAN CREEK DR	PINE TREE DR	BR	326	14	4,567	100	Excellent
SW_2511	41ST ST	INDIAN CREEK DR	PINE TREE DR	BR	748	9	6,736	90	Excellent
SW_2515	41ST ST	INDIAN CREEK DR	PINE TREE DR	PCC	35	5	176	90	Excellent
SW_2556	41ST ST	PINE TREE DR	PINE TREE DR	BR	177	4	706	90	Excellent
SW_2559	41ST ST	MERIDIAN AVE	JEFFERSON AVE	BR	210	15	3,157	80	Good
SW_2622	41ST ST	CHASE AVE	MERIDIAN AVE	BR	534	11	5,877	80	Good
SW_2638	41ST ST	JEFFERSON AVE	GARDEN AVE	BR	284	17	4,820	80	Good
SW_2692	41ST ST	COLLINS AVE	INDIAN CREEK DR	PCC	268	6	1,610	90	Excellent
SW_2699	41ST ST	PINE TREE DR	SHERIDAN AVE	BR	390	6	2,341	80	Good
SW_2704	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	BR	990	4	3,961	80	Good
SW_2719	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	BR	708	5	3,540	70	Good
SW_2740	41ST ST	COLLINS AVE	INDIAN CREEK DR	PCC	245	5	1,225	88	Good
SW_2785	41ST ST	JEFFERSON AVE	GARDEN AVE	BR	143	11	1,578	80	Good
SW_2794	41ST ST	MERIDIAN AVE	JEFFERSON AVE	PCC	185	8	1,478	90	Excellent
SW_2810	41ST ST	GARDEN AVE	I 195	PCC	549	7	3,841	80	Good
SW_3037	41ST ST	CHASE AVE	MERIDIAN AVE	BR	154	11	1,692	80	Good
SW_3039	41ST ST	CHASE AVE	MERIDIAN AVE	BR	226	6	1,357	80	Good
SW_0173	42ND ST	JEFFERSON AVE	NAUTILUS DR	PCC	308	6	1,845	80	Good
SW_0252	42ND ST	JEFFERSON AVE	NAUTILUS DR	PCC	353	8	2,820	90	Excellent
SW_0281	42ND ST	MERIDIAN AVE	JEFFERSON AVE	PCC	490	6	2,939	80	Good
SW_0384	42ND ST	COLLINS AVE	INDIAN CREEK DR	PCC	214	5	1,071	90	Excellent
SW_0455	42ND ST	COLLINS AVE	INDIAN CREEK DR	PCC	207	5	1,035	80	Good
SW_0629	42ND ST	BOARD WALK	COLLINS AVE	BR	328	9	2,956	90	Excellent
SW_0634	42ND ST	BOARD WALK	COLLINS AVE	PCC	421	5	2,107	90	Excellent
SW_1681	42ND ST	PINE TREE DR	SHERIDAN AVE	PCC	304	6	1,821	-	U.C./N.A.
SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	749	7	5,241	90	Excellent
SW_1930	42ND ST	ROYAL PALM AVE	POST AVE	PCC	144	5	721	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1946	42ND ST	POST AVE	PRAIRIE AVE	PCC	237	6	1,419	80	Good
SW_1947	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	474	5	2,371	79	Good
SW_1955	42ND ST	PINE TREE DR	SHERIDAN AVE	PCC	607	5	3,033	90	Excellent
SW_2023	42ND ST	POST AVE	PRAIRIE AVE	PCC	233	5	1,165	80	Good
SW_2064	42ND ST	ROYAL PALM AVE	POST AVE	PCC	111	5	557	80	Good
SW_2788	42ND ST	MERIDIAN AVE	JEFFERSON AVE	PCC	351	5	1,755	90	Excellent
SW_3182	42ND ST	PINE TREE DR	PINE TREE DR	PCC	41	7	289	90	Excellent
SW_3183	42ND ST	PINE TREE DR	PINE TREE DR	PCC	29	11	315	90	Excellent
SW_3184	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	278	5	1,390	90	Excellent
SW_2866	43RD CT	MERIDIAN AVE	ADAMS AVE	PCC	268	4	1,071	76	Good
SW_2869	43RD CT	JEFFERSON AVE	MICHIGAN AVE	PCC	1,032	4	4,128	89	Good
SW_2981	43RD CT	ADAMS AVE	JEFFERSON AVE	PCC	230	4	921	80	Good
SW_0404	43RD ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	453	5	2,265	90	Excellent
SW_0426	43RD ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	435	5	2,177	90	Excellent
SW_0598	43RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	206	6	1,233	85	Good
SW_0599	43RD ST	BOARD WALK	COLLINS AVE	PCC	277	6	1,659	80	Good
SW_0607	43RD ST	BOARD WALK	COLLINS AVE	BR	104	11	1,140	90	Excellent
SW_0611	43RD ST	BOARD WALK	COLLINS AVE	PCC	269	6	1,612	80	Good
SW_0612	43RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	211	6	1,267	80	Good
SW_2162	43RD ST	ROYAL PALM AVE	POST AVE	PCC	116	5	582	90	Excellent
SW_2247	43RD ST	ROYAL PALM AVE	POST AVE	PCC	136	5	678	90	Excellent
SW_2870	43RD ST	MICHIGAN AVE	NAUTILUS DR	PCC	203	4	814	90	Excellent
SW_2872	43RD ST	MICHIGAN AVE	NAUTILUS DR	PCC	210	4	841	90	Excellent
SW_2893	43RD ST	ALTON RD	ALTON RD	PCC	143	6	857	73	Good
SW_2899	43RD ST	ALTON RD	MOUNT SINAI HOSPITAL PR	PCC	232	5	1,160	90	Excellent
SW_2903	43RD ST	MOUNT SINAI HOSPITAL PR	MOUNT SINAI HOSPITAL PR	PCC	216	5	1,082	90	Excellent
SW_2975	44TH CT	NAUTILUS DR	ALTON RD	PCC	1,476	5	7,380	80	Good
SW_2978	44TH CT	ADAMS AVE	JEFFERSON AVE	PCC	235	4	940	80	Good
SW_2986	44TH CT	MERIDIAN AVE	ADAMS AVE	PCC	244	4	975	80	Good
SW_2989	44TH CT	MERIDIAN AVE	ADAMS AVE	PCC	256	4	1,023	80	Good
SW_2995	44TH CT	ADAMS AVE	JEFFERSON AVE	PCC	217	4	868	80	Good
SW_3005	44TH CT	MICHIGAN AVE	NAUTILUS DR	PCC	135	4	541	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3029	44TH CT	MICHIGAN AVE	NAUTILUS DR	PCC	150	4	601	80	Good
SW_3031	44TH CT	NAUTILUS DR	ALTON RD	PCC	225	5	1,127	50	Fair
SW_0631	44TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	24	7	170	80	Good
SW_0635	44TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	212	6	1,275	90	Excellent
SW_1981	44TH ST	PINE TREE DR	SHERIDAN AVE	PCC	293	5	1,463	90	Excellent
SW_1995	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	20	5	102	90	Excellent
SW_1996	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	305	5	1,524	90	Excellent
SW_2013	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	297	5	1,484	90	Excellent
SW_2098	44TH ST	PINE TREE DR	SHERIDAN AVE	PCC	1,581	5	7,906	80	Good
SW_2286	44TH ST	POST AVE	PRAIRIE AVE	PCC	301	5	1,504	90	Excellent
SW_2312	44TH ST	ROYAL PALM AVE	POST AVE	PCC	276	5	1,381	80	Good
SW_2326	44TH ST	POST AVE	PRAIRIE AVE	PCC	296	5	1,478	90	Excellent
SW_2388	44TH ST	ROYAL PALM AVE	POST AVE	PCC	283	5	1,414	90	Excellent
SW_2742	44TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	213	7	1,491	80	Good
SW_2751	44TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	42	6	253	90	Excellent
SW_2921	44TH ST	ALTON RD	BAY RD	PCC	205	5	1,025	78	Good
SW_2922	44TH ST	ALTON RD	BAY RD	PCC	191	5	954	80	Good
SW_0438	45TH ST	PINE TREE DR	SHERIDAN AVE	PCC	1,026	5	5,128	80	Good
SW_2106	45TH ST	PINE TREE DR	SHERIDAN AVE	PCC	291	5	1,454	80	Good
SW_2116	45TH ST	SHERIDAN AVE	ROYAL PALM AVE	PCC	301	5	1,505	90	Excellent
SW_2374	45TH ST	POST AVE	PRAIRIE AVE	PCC	269	5	1,345	90	Excellent
SW_2421	45TH ST	POST AVE	PRAIRIE AVE	PCC	847	5	4,233	90	Excellent
SW_2485	45TH ST	ROYAL PALM AVE	POST AVE	PCC	893	5	4,463	90	Excellent
SW_2626	45TH ST	ROYAL PALM AVE	POST AVE	PCC	272	5	1,361	90	Excellent
SW_2997	45TH ST	ALTON RD	BAY RD	PCC	209	5	1,043	90	Excellent
SW_3179	45TH ST	PINE TREE DR	PINE TREE DR	PCC	32	6	191	90	Excellent
SW_3180	45TH ST	PINE TREE DR	PINE TREE DR	PCC	35	5	177	90	Excellent
SW_0532	46TH ST	46TH XOVR	ROYAL PALM AVE	PCC	439	5	2,194	90	Excellent
SW_0562	46TH ST	46TH XOVR	ROYAL PALM AVE	PCC	410	5	2,051	90	Excellent
SW_0574	46TH ST	ROYAL PALM AVE	POST AVE	PCC	590	5	2,952	90	Excellent
SW_1889	46TH ST	BOARD WALK	COLLINS AVE	BR	261	13	3,398	90	Excellent
SW_2434	46TH ST	POST AVE	PRAIRIE AVE	PCC	249	5	1,246	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2468	46TH ST	POST AVE	PRAIRIE AVE	PCC	247	5	1,235	90	Excellent
SW_2646	46TH ST	ROYAL PALM AVE	POST AVE	PCC	276	5	1,379	90	Excellent
SW_2776	46TH ST	NAUTILUS CT	NAUTILUS DR	PCC	151	5	754	80	Good
SW_2884	46TH ST	ADAMS AVE	JEFFERSON AVE	PCC	279	5	1,396	70	Good
SW_2895	46TH ST	NAUTILUS DR	ALTON RD	PCC	256	5	1,279	80	Good
SW_2897	46TH ST	MICHIGAN AVE	NAUTILUS CT	PCC	274	5	1,368	80	Good
SW_2904	46TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	242	5	1,212	80	Good
SW_2908	46TH ST	MERIDIAN AVE	ADAMS AVE	PCC	259	5	1,297	90	Excellent
SW_2910	46TH ST	MERIDIAN AVE	ADAMS AVE	PCC	230	4	921	90	Excellent
SW_2911	46TH ST	ADAMS AVE	JEFFERSON AVE	PCC	220	4	881	80	Good
SW_2913	46TH ST	JEFFERSON AVE	MICHIGAN AVE	PCC	235	4	938	80	Good
SW_3019	46TH ST	NAUTILUS DR	ALTON RD	PCC	242	5	1,211	90	Excellent
SW_2844	47TH CT	48TH ST	MICHIGAN AVE	PCC	584	5	2,920	70	Good
SW_2847	47TH CT	MICHIGAN AVE	ALTON RD	PCC	499	5	2,494	80	Good
SW_2867	47TH CT	MICHIGAN AVE	ALTON RD	PCC	469	5	2,344	80	Good
SW_2868	47TH CT	48TH ST	MICHIGAN AVE	PCC	436	4	1,743	70	Good
SW_0586	47TH ST	ROYAL PALM AVE	POST AVE	PCC	299	5	1,494	90	Excellent
SW_0592	47TH ST	PRAIRIE AVE	MERIDIAN AVE	PCC	203	7	1,422	90	Excellent
SW_0606	47TH ST	PINE TREE DR	47TH CT	PCC	393	5	1,967	80	Good
SW_0608	47TH ST	PRAIRIE AVE	MERIDIAN AVE	PCC	145	6	868	90	Excellent
SW_0627	47TH ST	PINE TREE DR	47TH CT	PCC	188	5	940	70	Good
SW_0632	47TH ST	PRAIRIE AVE	MERIDIAN AVE	PCC	125	6	751	90	Excellent
SW_0641	47TH ST	PRAIRIE AVE	MERIDIAN AVE	BR	206	7	1,445	90	Excellent
SW_0648	47TH ST	PRAIRIE AVE	MERIDIAN AVE	BR	207	8	1,660	90	Excellent
SW_0668	47TH ST	PRAIRIE AVE	MERIDIAN AVE	PCC	199	6	1,193	90	Excellent
SW_0674	47TH ST	POST AVE	PRAIRIE AVE	PCC	177	6	1,062	80	Good
SW_2526	47TH ST	POST AVE	PRAIRIE AVE	PCC	633	5	3,166	90	Excellent
SW_2805	47TH ST	MERIDIAN AVE	MICHIGAN AVE	PCC	811	5	4,054	80	Good
SW_2841	47TH ST	MERIDIAN AVE	MICHIGAN AVE	PCC	789	5	3,943	80	Good
SW_2874	47TH ST	MICHIGAN AVE	ALTON RD	PCC	403	5	2,016	80	Good
SW_2886	47TH ST	MICHIGAN AVE	ALTON RD	PCC	385	5	1,923	80	Good
SW_2979	47TH ST	ALTON RD	BAY RD	PCC	218	4	871	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2982	47TH ST	ALTON RD	BAY RD	PCC	194	5	972	90	Excellent
SW_3160	47TH ST	MICHIGAN AVE	ALTON RD	PCC	44	5	219	-	U.C./N.A.
SW_3161	47TH ST	MICHIGAN AVE	ALTON RD	PCC	131	5	656	80	Good
SW_3162	47TH ST	MICHIGAN AVE	ALTON RD	PCC	91	5	453	-	U.C./N.A.
SW_3163	47TH ST	MICHIGAN AVE	ALTON RD	PCC	137	7	961	80	Good
SW_2857	48TH ST	47TH CT	ALTON RD	PCC	702	5	3,508	80	Good
SW_2859	48TH ST	47TH CT	ALTON RD	PCC	1,179	6	7,075	90	Excellent
SW_2987	48TH ST	ALTON RD	BAY RD	PCC	74	5	370	80	Good
SW_2988	48TH ST	ALTON RD	BAY RD	PCC	114	5	568	90	Excellent
SW_2991	48TH ST	ALTON RD	BAY RD	PCC	66	8	526	90	Excellent
SW_0107	49TH ST	LAKEVIEW DR	CHEROKEE AVE	PCC	669	5	3,347	89	Good
SW_0135	49TH ST	CHEROKEE AVE	DELAWARE AVE	PCC	634	5	3,172	90	Excellent
SW_0205	49TH ST	LAKEVIEW DR	CHEROKEE AVE	PCC	657	5	3,283	80	Good
SW_0212	49TH ST	CHEROKEE AVE	DELAWARE AVE	PCC	643	5	3,214	90	Excellent
SW_0223	49TH ST	CHEROKEE AVE	DELAWARE AVE	PCC	13	6	80	80	Good
SW_2924	4TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,222	80	Good
SW_2925	4TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	245	5	1,224	80	Good
SW_2852	4TH RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	246	5	1,230	80	Good
SW_2854	4TH RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	PCC	240	5	1,198	87	Good
SW_0030	4TH ST	MICHIGAN AVE	MICHIGAN CT	PCC	359	7	2,512	80	Good
SW_0041	4TH ST	LENOX AVE	ALTON RD	PCC	175	7	1,227	90	Excellent
SW_0046	4TH ST	OCEAN DR	EAST END	PCC	280	6	1,680	80	Good
SW_0048	4TH ST	LENOX AVE	ALTON RD	PCC	187	5	934	90	Excellent
SW_0054	4TH ST	MICHIGAN AVE	MICHIGAN CT	PCC	232	6	1,389	-	U.C./N.A.
SW_0073	4TH ST	OCEAN DR	EAST END	PCC	283	6	1,700	80	Good
SW_0138	4TH ST	COLLINS CT	WASHINGTON AVE	PCC	145	8	1,163	90	Excellent
SW_0154	4TH ST	COLLINS AVE	COLLINS CT	PCC	144	8	1,151	80	Good
SW_0200	4TH ST	OCEAN CT	COLLINS AVE	PCC	153	9	1,375	90	Excellent
SW_0236	4TH ST	OCEAN DR	OCEAN CT	PCC	122	9	1,098	90	Excellent
SW_0681	4TH ST	COLLINS AVE	COLLINS CT	PCC	141	8	1,132	80	Good
SW_0688	4TH ST	COLLINS CT	WASHINGTON AVE	PCC	146	8	1,170	80	Good
SW_0785	4TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	150	6	901	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0913	4TH ST	WASHINGTON AVE	EUCLID AVE	PCC	108	5	541	90	Excellent
SW_1047	4TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	309	6	1,851	80	Good
SW_1078	4TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	314	5	1,569	80	Good
SW_1094	4TH ST	EUCLID AVE	EUCLID CT	PCC	317	5	1,586	80	Good
SW_1106	4TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	304	6	1,825	80	Good
SW_1117	4TH ST	EUCLID AVE	EUCLID CT	PCC	313	6	1,879	80	Good
SW_1128	4TH ST	WASHINGTON AVE	EUCLID AVE	PCC	114	6	687	90	Excellent
SW_2681	4TH ST	OCEAN DR	OCEAN CT	PCC	119	8	952	90	Excellent
SW_2718	4TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	160	5	802	80	Good
SW_3013	4TH ST	OCEAN CT	COLLINS AVE	PCC	152	8	1,219	90	Excellent
SW_3127	4TH ST	MICHIGAN AVE	MICHIGAN CT	PCC	100	6	598	80	Good
SW_0047	50TH ST	CHEROKEE AVE	DELAWARE AVE	PCC	621	5	3,104	80	Good
SW_0082	50TH ST	LAKEVIEW DR	CHEROKEE AVE	PCC	726	5	3,628	80	Good
SW_0246	50TH ST	CHEROKEE AVE	DELAWARE AVE	PCC	628	5	3,141	90	Excellent
SW_0320	50TH ST	LAKEVIEW DR	CHEROKEE AVE	PCC	710	5	3,551	80	Good
SW_0027	51ST ST	51ST ST	ALTON RD	PCC	24	4	94	50	Fair
SW_0036	51ST ST	51ST ST	ALTON RD	PCC	239	5	1,195	90	Excellent
SW_0057	51ST ST	CHEROKEE AVE	51ST ST	PCC	297	5	1,487	90	Excellent
SW_0443	51ST ST	LAKEVIEW DR	BLACK HAWK AVE	PCC	413	5	2,065	90	Excellent
SW_0456	51ST ST	BLACK HAWK AVE	CHEROKEE AVE	PCC	424	5	2,122	90	Excellent
SW_0483	51ST ST	BLACK HAWK AVE	CHEROKEE AVE	PCC	19	5	96	100	Excellent
SW_0534	51ST ST	ALTON RD	BAY RD	PCC	336	5	1,681	79	Good
SW_1103	51ST ST	LA GORCE DR	LAKEVIEW DR	PCC	373	5	1,865	77	Good
SW_2119	51ST ST	CHEROKEE AVE	51ST ST	PCC	22	5	110	100	Excellent
SW_2155	51ST ST	CHEROKEE AVE	51ST ST	PCC	422	5	2,108	90	Excellent
SW_2361	51ST ST	LAKEVIEW DR	BLACK HAWK AVE	PCC	409	5	2,047	90	Excellent
SW_2530	51ST ST	ALTON RD	BAY RD	PCC	324	5	1,621	88	Good
SW_2549	51ST ST	51ST ST	ALTON RD	PCC	121	4	486	82	Good
SW_2550	51ST ST	BLACK HAWK AVE	CHEROKEE AVE	PCC	408	5	2,038	80	Good
SW_2724	51ST ST	LA GORCE DR	LAKEVIEW DR	PCC	258	5	1,290	90	Excellent
SW_2730	51ST ST	LAKEVIEW DR	LAKEVIEW DR	PCC	51	4	204	100	Excellent
SW_2747	51ST ST	CHEROKEE AVE	51ST ST	PCC	356	4	1,422	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2386	52ND ST	PINE TREE DR	LA GORCE DR	PCC	305	5	1,523	90	Excellent
SW_2438	52ND ST	PINE TREE DR	LA GORCE DR	PCC	295	4	1,178	80	Good
SW_2587	52ND ST	LA GORCE DR	WEST END	PCC	43	5	214	90	Excellent
SW_2757	52ND ST	ALTON RD	BAY RD	PCC	262	5	1,308	90	Excellent
SW_2758	52ND ST	ALTON RD	BAY RD	PCC	257	6	1,542	80	Good
SW_1388	53RD ST	EAST END	ALTON RD	PCC	108	5	539	50	Fair
SW_2339	53RD ST	PINE TREE DR	LA GORCE DR	PCC	290	5	1,450	90	Excellent
SW_2351	53RD ST	PINE TREE DR	LA GORCE DR	PCC	289	5	1,447	90	Excellent
SW_2786	53RD ST	ALTON RD	BAY RD	PCC	272	5	1,361	90	Excellent
SW_2802	53RD ST	ALTON RD	BAY RD	PCC	274	5	1,372	90	Excellent
SW_2278	54TH ST	PINE TREE DR	LA GORCE DR	PCC	287	5	1,434	80	Good
SW_2295	54TH ST	PINE TREE DR	LA GORCE DR	PCC	286	5	1,432	83	Good
SW_2520	54TH ST	ALTON RD	BAY RD	PCC	249	5	1,245	86	Good
SW_2823	54TH ST	ALTON RD	BAY RD	PCC	271	5	1,354	90	Excellent
SW_2245	55TH ST	PINE TREE DR	LA GORCE DR	PCC	279	5	1,397	90	Excellent
SW_2266	55TH ST	PINE TREE DR	LA GORCE DR	PCC	275	5	1,377	90	Excellent
SW_0166	56TH ST	ALTON RD	BAY RD	PCC	275	5	1,376	90	Excellent
SW_0213	56TH ST	ALTON RD	BAY RD	PCC	259	5	1,293	80	Good
SW_2198	56TH ST	PINE TREE DR	LA GORCE DR	PCC	280	5	1,401	90	Excellent
SW_2206	56TH ST	PINE TREE DR	LA GORCE DR	PCC	288	5	1,440	90	Excellent
SW_2727	56TH ST	LA GORCE DR	WEST END	PCC	78	5	391	50	Fair
SW_2114	57TH ST	PINE TREE DR	LA GORCE DR	PCC	282	5	1,411	90	Excellent
SW_2127	57TH ST	PINE TREE DR	LA GORCE DR	PCC	286	5	1,428	90	Excellent
SW_2682	57TH ST	LA GORCE DR	WEST END	PCC	48	5	240	80	Good
SW_2689	57TH ST	LA GORCE DR	WEST END	PCC	46	5	230	70	Good
SW_2803	57TH ST	ALTON RD	BAY RD	PCC	293	5	1,466	80	Good
SW_2839	57TH ST	ALTON RD	BAY RD	PCC	137	5	683	90	Excellent
SW_3158	57TH ST	ALTON RD	BAY RD	PCC	117	5	587	70	Good
SW_0271	58TH ST	ALTON RD	BAY RD	PCC	279	4	1,114	80	Good
SW_0277	58TH ST	ALTON RD	BAY RD	PCC	260	5	1,299	90	Excellent
SW_2049	58TH ST	PINE TREE DR	LA GORCE DR	PCC	307	6	1,844	88	Good
SW_2083	58TH ST	PINE TREE DR	LA GORCE DR	PCC	286	4	1,145	88	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1532	59TH ST	ALTON RD	BAY RD	PCC	273	5	1,366	90	Excellent
SW_1539	59TH ST	PINE TREE DR	LA GORCE DR	PCC	285	5	1,424	90	Excellent
SW_1650	59TH ST	ALTON RD	BAY RD	PCC	258	5	1,291	80	Good
SW_1983	59TH ST	PINE TREE DR	LA GORCE DR	PCC	308	5	1,539	80	Good
SW_0466	5TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	245	5	1,224	90	Excellent
SW_0546	5TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,218	90	Excellent
SW_0064	5TH ST	MAC ARTHUR CSWY	LENOX AVE	PCC	299	11	3,292	80	Good
SW_0078	5TH ST	LENOX AVE	ALTON RD	PCC	167	10	1,673	80	Good
SW_0083	5TH ST	LENOX AVE	ALTON RD	PCC	170	9	1,531	80	Good
SW_0089	5TH ST	BEACH SVRD	BEACH WALK	BR	100	18	1,808	90	Excellent
SW_0099	5TH ST	MICHIGAN CT	MICHIGAN AVE	PCC	348	10	3,481	90	Excellent
SW_0106	5TH ST	BEACH WALK	OCEAN DR	PCC	293	17	4,987	60	Good
SW_0255	5TH ST	COLLINS AVE	OCEAN CT	PCC	319	8	2,552	70	Good
SW_0260	5TH ST	OCEAN CT	OCEAN DR	PCC	238	7	1,667	70	Good
SW_0270	5TH ST	OCEAN DR	OCEAN CT	PCC	155	17	2,639	70	Good
SW_0410	5TH ST	MICHIGAN CT	LENOX AVE	PCC	226	10	2,265	90	Excellent
SW_0445	5TH ST	COLLINS CT	WASHINGTON AVE	PCC	148	15	2,223	90	Excellent
SW_0566	5TH ST	OCEAN CT	COLLINS AVE	PCC	151	20	3,025	70	Good
SW_0707	5TH ST	WASHINGTON AVE	COLLINS CT	PCC	17	6	104	90	Excellent
SW_0715	5TH ST	WASHINGTON AVE	COLLINS CT	PCC	276	10	2,758	90	Excellent
SW_0723	5TH ST	COLLINS CT	COLLINS AVE	PCC	290	9	2,610	80	Good
SW_0734	5TH ST	WASHINGTON AVE	COLLINS CT	PCC	35	13	457	60	Good
SW_0741	5TH ST	WASHINGTON AVE	EUCLID AVE	PCC	182	11	1,999	60	Good
SW_0758	5TH ST	EUCLID CT	MERIDIAN AVE	PCC	299	15	4,483	68	Good
SW_0833	5TH ST	EUCLID AVE	WASHINGTON AVE	PCC	153	31	4,729	80	Good
SW_0876	5TH ST	EUCLID CT	EUCLID AVE	PCC	327	9	2,945	90	Excellent
SW_0939	5TH ST	MERIDIAN CT	MERIDIAN AVE	PCC	333	10	3,331	90	Excellent
SW_1014	5TH ST	MICHIGAN AVE	JEFFERSON CT	PCC	342	10	3,425	74	Good
SW_1188	5TH ST	MERIDIAN AVE	MERIDIAN CT	PCC	304	11	3,341	88	Good
SW_1200	5TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	319	10	3,188	80	Good
SW_1416	5TH ST	MAC ARTHUR CSWY	LENOX AVE	PCC	42	5	208	90	Excellent
SW_3063	5TH ST	COLLINS AVE	COLLINS CT	PCC	158	7	1,107	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3110	5TH ST	MICHIGAN CT	LENOX AVE	PCC	115	5	576	70	Good
SW_0624	60TH ST	PINE TREE DR	LA GORCE DR	PCC	288	5	1,442	90	Excellent
SW_0670	60TH ST	PINE TREE DR	LA GORCE DR	PCC	287	5	1,436	80	Good
SW_1890	60TH ST	ALTON RD	BAY RD	PCC	267	5	1,333	80	Good
SW_1908	60TH ST	ALTON RD	BAY RD	PCC	267	5	1,337	80	Good
SW_0570	61ST ST	PINE TREE DR	LA GORCE DR	PCC	307	5	1,535	80	Good
SW_0596	61ST ST	PINE TREE DR	LA GORCE DR	PCC	294	5	1,471	90	Excellent
SW_2513	62ND ST	LA GORCE DR	ALTON RD	PCC	573	5	2,863	87	Good
SW_0365	63RD ST	AQUA AVE	PINE TREE DR	PCC	679	6	4,075	70	Good
SW_0380	63RD ST	INDIAN CREEK DR	AQUA AVE	PCC	419	5	2,097	90	Excellent
SW_0427	63RD ST	INDIAN CREEK DR	AQUA AVE	PCC	179	4	718	90	Excellent
SW_0430	63RD ST	INDIAN CREEK DR	AQUA AVE	PCC	389	5	1,947	90	Excellent
SW_0454	63RD ST	PINE TREE DR	AQUA AVE	PCC	627	5	3,136	90	Excellent
SW_0508	63RD ST	PINE TREE DR	AQUA AVE	PCC	27	5	133	70	Good
SW_2118	63RD ST	ALTON RD	BAY RD	PCC	293	5	1,464	90	Excellent
SW_2138	63RD ST	ALTON RD	BAY RD	PCC	318	5	1,592	80	Good
SW_2149	63RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	500	8	4,000	80	Good
SW_2165	63RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	41	7	290	90	Excellent
SW_2200	63RD ST	COLLINS AVE	INDIAN CREEK DR	PCC	98	9	880	80	Good
SW_2210	63RD ST	INDIAN CREEK DR	COLLINS AVE	PCC	203	7	1,422	80	Good
SW_2323	63RD ST	INDIAN CREEK DR	AQUA AVE	PCC	35	6	208	90	Excellent
SW_2327	63RD ST	INDIAN CREEK DR	AQUA AVE	PCC	101	12	1,208	80	Good
SW_2377	63RD ST	LA GORCE DR	ALTON RD	PCC	199	9	1,795	90	Excellent
SW_2459	63RD ST	ALTON RD	LA GORCE DR	PCC	260	5	1,301	80	Good
SW_2701	63RD ST	LA GORCE DR	PINE TREE DR	PCC	259	5	1,293	80	Good
SW_2713	63RD ST	PINE TREE DR	LA GORCE DR	PCC	275	5	1,373	88	Good
SW_2077	65TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	312	7	2,184	70	Good
SW_2093	65TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	304	7	2,125	77	Good
SW_0712	67TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	313	15	4,689	80	Good
SW_1961	67TH ST	COLLINS AVE	INDIAN CREEK DR	PCC	309	13	4,022	77	Good
SW_0025	69TH ST	COLLINS AVE	HARDING AVE	PCC	251	7	1,759	90	Excellent
SW_0343	69TH ST	ABBOTT AVE	BYRON AVE	PCC	281	9	2,526	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0346	69TH ST	ABBOTT AVE	BYRON AVE	PCC	250	5	1,252	90	Excellent
SW_1885	69TH ST	COLLINS AVE	HARDING AVE	PCC	264	7	1,850	90	Excellent
SW_1936	69TH ST	BEACH WALK	COLLINS AVE	PCC	303	8	2,424	100	Excellent
SW_1953	69TH ST	BEACH WALK	COLLINS AVE	PCC	210	16	3,352	90	Excellent
SW_2037	69TH ST	BEACH WALK	COLLINS AVE	PCC	1,428	10	14,280	80	Good
SW_2335	69TH ST	HARDING AVE	ABBOTT AVE	PCC	251	5	1,257	90	Excellent
SW_2344	69TH ST	HARDING AVE	ABBOTT AVE	PCC	255	7	1,784	80	Good
SW_2481	69TH ST	INDIAN CREEK DR	WEST END	PCC	173	5	866	80	Good
SW_2531	69TH ST	BYRON AVE	INDIAN CREEK DR	PCC	133	6	799	90	Excellent
SW_2711	69TH ST	BYRON AVE	INDIAN CREEK DR	PCC	136	9	1,224	90	Excellent
SW_0698	6TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,220	90	Excellent
SW_2588	6TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	245	5	1,225	80	Good
SW_0104	6TH ST	LENOX CT	ALTON RD	PCC	162	5	811	90	Excellent
SW_0113	6TH ST	LENOX AVE	LENOX CT	PCC	170	5	849	90	Excellent
SW_0119	6TH ST	LENOX AVE	LENOX CT	PCC	171	6	1,029	90	Excellent
SW_0124	6TH ST	MICHIGAN CT	LENOX AVE	PCC	337	5	1,686	70	Good
SW_0132	6TH ST	LENOX CT	ALTON RD	PCC	160	6	958	80	Good
SW_0140	6TH ST	MICHIGAN CT	LENOX AVE	BR	337	6	2,023	90	Excellent
SW_0286	6TH ST	OCEAN CT	COLLINS AVE	PCC	147	5	733	70	Good
SW_0296	6TH ST	OCEAN DR	OCEAN CT	PCC	145	5	726	70	Good
SW_0305	6TH ST	COLLINS AVE	COLLINS CT	PCC	160	5	801	80	Good
SW_0319	6TH ST	COLLINS CT	WASHINGTON AVE	PCC	156	5	780	80	Good
SW_0396	6TH ST	MICHIGAN CT	LENOX AVE	PCC	399	5	1,997	90	Excellent
SW_0765	6TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	290	6	1,741	80	Good
SW_0786	6TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	123	6	737	90	Excellent
SW_0805	6TH ST	EUCLID AVE	EUCLID CT	PCC	327	5	1,633	80	Good
SW_0824	6TH ST	EUCLID CT	MERIDIAN AVE	PCC	331	7	2,314	74	Good
SW_1230	6TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	316	6	1,897	80	Good
SW_1238	6TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	330	5	1,652	78	Good
SW_1239	6TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	314	6	1,885	90	Excellent
SW_1258	6TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	310	6	1,860	80	Good
SW_1326	6TH ST	ALTON RD	WEST AVE	PCC	250	6	1,502	-	U.C./N.A.

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1366	6TH ST	ALTON RD	WEST AVE	PCC	294	7	2,059	100	Excellent
SW_2141	6TH ST	BEACH WALK	OCEAN DR	PCC	105	13	1,365	90	Excellent
SW_2685	6TH ST	OCEAN CT	COLLINS AVE	PCC	149	5	747	70	Good
SW_3064	6TH ST	OCEAN DR	OCEAN CT	PCC	150	6	898	70	Good
SW_3076	6TH ST	COLLINS CT	WASHINGTON AVE	PCC	158	5	790	80	Good
SW_3077	6TH ST	COLLINS AVE	COLLINS CT	PCC	156	6	937	90	Excellent
SW_3114	6TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	173	4	693	80	Good
SW_0131	71ST ST	BYRON AVE	CARLYLE AVE	PCC	247	9	2,221	90	Excellent
SW_0144	71ST ST	ABBOTT AVE	ABBOTT CT	PCC	113	11	1,248	-	U.C./N.A.
SW_0198	71ST ST	ABBOTT CT	BYRON AVE	PCC	132	14	1,845	70	Good
SW_0297	71ST ST	ABBOTT CT	BYRON AVE	PCC	142	10	1,422	90	Excellent
SW_0339	71ST ST	ABBOTT AVE	ABBOTT CT	PCC	110	10	1,097	81	Good
SW_0442	71ST ST	TROUVILLE ESPLANADE	RUE BORDEAUX	PCC	839	5	4,195	79	Good
SW_0500	71ST ST	NORMANDY DR	BIARRITZ DR	PCC	36	11	392	80	Good
SW_0564	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	PCC	201	5	1,004	80	Good
SW_0713	71ST ST	BIARRITZ DR	BIARRITZ DR	PCC	164	7	1,147	80	Good
SW_0829	71ST ST	RUE VENDOME	NORMANDY DR	PCC	266	12	3,193	80	Good
SW_0912	71ST ST	VERSAILLES CT	RUE VENDOME	PCC	236	8	1,892	90	Excellent
SW_0969	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	PCC	814	6	4,883	70	Good
SW_1186	71ST ST	INDIAN CREEK DR	BONITA DR	PCC	240	10	2,400	70	Good
SW_1265	71ST ST	VICHY DR	RUE VERSAILLES	PCC	116	12	1,391	61	Good
SW_1302	71ST ST	RUE NOTRE DAME	VICHY DR	PCC	570	11	6,274	40	Fair
SW_1380	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	PCC	909	5	4,544	80	Good
SW_1630	71ST ST	BONITA DR	NORMANDY DR	PCC	70	22	1,535	90	Excellent
SW_1789	71ST ST	TROUVILLE ESPLANADE	RUE BORDEAUX	PCC	845	4	3,382	80	Good
SW_1797	71ST ST	BEACH WALK	COLLINS AVE	PCC	263	9	2,363	88	Good
SW_1806	71ST ST	COLLINS AVE	HARDING AVE	PCC	262	8	2,093	80	Good
SW_1807	71ST ST	COLLINS AVE	HARDING AVE	PCC	258	10	2,578	80	Good
SW_1811	71ST ST	BEACH WALK	COLLINS AVE	PCC	265	7	1,856	90	Excellent
SW_1914	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	PCC	829	5	4,147	80	Good
SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	PCC	394	6	2,366	69	Good
SW_2194	71ST ST	BIARRITZ DR	GRANVILLE CT	PCC	87	6	520	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2246	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	PCC	966	6	5,793	79	Good
SW_2253	71ST ST	GRANVILLE CT	RUE GRANVILLE	PCC	443	7	3,104	80	Good
SW_2270	71ST ST	HARDING AVE	HARDING CT	PCC	142	14	1,982	90	Excellent
SW_2288	71ST ST	HARDING CT	ABBOTT AVE	PCC	112	10	1,117	70	Good
SW_2301	71ST ST	GRANVILLE CT	RUE GRANVILLE	PCC	256	5	1,282	78	Good
SW_2302	71ST ST	RUE NOTRE DAME	VICHY DR	PCC	555	13	7,221	80	Good
SW_2307	71ST ST	HARDING CT	ABBOTT AVE	PCC	116	14	1,627	90	Excellent
SW_2308	71ST ST	HARDING AVE	HARDING CT	PCC	137	15	2,058	90	Excellent
SW_2354	71ST ST	BIARRITZ DR	GRANVILLE CT	PCC	357	7	2,502	80	Good
SW_2416	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	PCC	263	8	2,102	90	Excellent
SW_2423	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	PCC	896	6	5,378	90	Excellent
SW_2502	71ST ST	VICHY DR	RUE VERSAILLES	PCC	452	13	5,882	80	Good
SW_2534	71ST ST	VERSAILLES CT	RUE VENDOME	PCC	353	10	3,532	80	Good
SW_2624	71ST ST	BONITA DR	NORMANDY DR	PCC	555	6	3,330	70	Good
SW_2632	71ST ST	BONITA DR	NORMANDY DR	PCC	567	6	3,404	80	Good
SW_2639	71ST ST	BONITA DR	NORMANDY DR	PCC	49	7	343	80	Good
SW_2671	71ST ST	CARLYLE AVE	INDIAN CREEK DR	PCC	201	10	2,007	80	Good
SW_2678	71ST ST	INDIAN CREEK DR	BONITA DR	PCC	237	14	3,321	80	Good
SW_2703	71ST ST	BYRON AVE	CARLYLE AVE	PCC	246	14	3,448	80	Good
SW_2708	71ST ST	TROUVILLE ESPLANADE	RUE BORDEAUX	PCC	177	5	883	80	Good
SW_2712	71ST ST	CARLYLE AVE	INDIAN CREEK DR	PCC	253	5	1,266	90	Excellent
SW_2744	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	PCC	158	5	792	80	Good
SW_3145	71ST ST	INDIAN CREEK DR	BONITA DR	BR	105	19	1,995	90	Excellent
SW_3147	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	PCC	245	6	1,470	90	Excellent
SW_3149	71ST ST	VICHY DR	RUE VERSAILLES	PCC	136	14	1,909	90	Excellent
SW_3150	71ST ST	VICHY DR	RUE VERSAILLES	PCC	117	11	1,284	40	Fair
SW_3151	71ST ST	VERSAILLES CT	RUE VENDOME	BR	55	14	776	80	Good
SW_3152	71ST ST	VICHY DR	RUE VERSAILLES	BR	41	10	412	90	Excellent
SW_1662	72ND ST	HARDING CT	HARDING AVE	PCC	19	6	112	100	Excellent
SW_1678	72ND ST	HARDING CT	HARDING AVE	PCC	102	6	610	90	Excellent
SW_1700	72ND ST	COLLINS AVE	HARDING AVE	PCC	435	6	2,612	80	Good
SW_1727	72ND ST	COLLINS AVE	HARDING AVE	PCC	251	8	2,009	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1780	72ND ST	BEACH WALK	COLLINS AVE	PCC	154	12	1,850	80	Good
SW_2054	72ND ST	HARDING AVE	ABBOTT CT	PCC	108	6	647	80	Good
SW_2060	72ND ST	ABBOTT CT	BYRON AVE	PCC	154	6	922	90	Excellent
SW_2071	72ND ST	BYRON AVE	CARLYLE AVE	PCC	355	5	1,773	80	Good
SW_2073	72ND ST	CARLYLE AVE	DICKENS AVE	PCC	189	5	943	90	Excellent
SW_2101	72ND ST	CARLYLE AVE	DICKENS AVE	PCC	55	6	330	90	Excellent
SW_2131	72ND ST	CARLYLE AVE	DICKENS AVE	PCC	250	8	2,000	80	Good
SW_2158	72ND ST	BYRON AVE	CARLYLE AVE	PCC	252	7	1,762	-	U.C./N.A.
SW_2173	72ND ST	ABBOTT CT	BYRON AVE	PCC	123	7	858	70	Good
SW_2184	72ND ST	HARDING AVE	ABBOTT CT	PCC	100	8	798	80	Good
SW_2215	72ND ST	HARDING CT	HARDING AVE	PCC	101	9	910	100	Excellent
SW_2226	72ND ST	HARDING AVE	HARDING CT	PCC	125	6	748	100	Excellent
SW_1322	73RD ST	DICKENS AVE	WAYNE AVE	PCC	348	5	1,740	76	Good
SW_1340	73RD ST	DICKENS AVE	WAYNE AVE	PCC	371	5	1,855	80	Good
SW_1362	73RD ST	OCEAN TER	COLLINS AVE	PCC	140	27	3,769	90	Excellent
SW_1381	73RD ST	OCEAN TER	COLLINS AVE	PCC	284	9	2,552	90	Excellent
SW_1549	73RD ST	OCEAN TER	COLLINS AVE	PCC	332	13	4,321	90	Excellent
SW_1564	73RD ST	COLLINS AVE	COLLINS CT	PCC	327	7	2,289	80	Good
SW_1622	73RD ST	COLLINS AVE	COLLINS CT	PCC	352	6	2,112	77	Good
SW_1943	73RD ST	HARDING CT	BYRON AVE	PCC	331	5	1,654	80	Good
SW_1976	73RD ST	BYRON AVE	HARDING AVE	PCC	352	5	1,761	80	Good
SW_1989	73RD ST	BYRON AVE	HARDING AVE	PCC	19	4	77	100	Excellent
SW_2414	73RD ST	CARLYLE AVE	DICKENS AVE	PCC	169	5	844	77	Good
SW_2447	73RD ST	BYRON CT	CARLYLE AVE	PCC	334	8	2,674	80	Good
SW_2490	73RD ST	DICKENS AVE	CARLYLE AVE	PCC	181	5	907	90	Excellent
SW_2501	73RD ST	CARLYLE AVE	BYRON AVE	PCC	407	5	2,036	80	Good
SW_1503	74TH ST	COLLINS AVE	COLLINS CT	PCC	336	8	2,685	77	Good
SW_1520	74TH ST	COLLINS AVE	COLLINS CT	PCC	337	8	2,697	80	Good
SW_1573	74TH ST	OCEAN TER	COLLINS AVE	PCC	334	18	6,004	80	Good
SW_1608	74TH ST	OCEAN TER	COLLINS AVE	PCC	332	11	3,653	90	Excellent
SW_1903	74TH ST	HARDING CT	BYRON AVE	PCC	329	6	1,973	70	Good
SW_1919	74TH ST	HARDING CT	BYRON AVE	PCC	327	6	1,963	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2413	74TH ST	BYRON CT	CARLYLE AVE	PCC	330	6	1,982	80	Good
SW_2417	74TH ST	CARLYLE AVE	DICKENS AVE	PCC	172	6	1,034	90	Excellent
SW_2425	74TH ST	CARLYLE AVE	DICKENS AVE	PCC	171	5	853	90	Excellent
SW_2431	74TH ST	BYRON CT	CARLYLE AVE	PCC	338	6	2,027	80	Good
SW_1125	75TH ST	OCEAN TER	ATLANTIC WAY	PCC	310	6	1,861	90	Excellent
SW_1370	75TH ST	COLLINS AVE	COLLINS CT	PCC	307	6	1,842	80	Good
SW_1413	75TH ST	COLLINS AVE	COLLINS CT	PCC	198	7	1,387	77	Good
SW_1454	75TH ST	DICKENS AVE	WEST END	PCC	191	5	957	80	Good
SW_1464	75TH ST	DICKENS AVE	WEST END	PCC	177	9	1,592	80	Good
SW_1473	75TH ST	DICKENS AVE	WEST END	PCC	83	7	578	90	Excellent
SW_1537	75TH ST	DICKENS AVE	WEST END	PCC	226	5	1,131	80	Good
SW_1606	75TH ST	BYRON AVE	BYRON AVE	PCC	89	5	444	80	Good
SW_1647	75TH ST	OCEAN TER	ATLANTIC WAY	PCC	402	13	5,226	90	Excellent
SW_1778	75TH ST	ABBOTT AVE	BYRON AVE	PCC	141	4	562	80	Good
SW_1824	75TH ST	HARDING AVE	ABBOTT AVE	PCC	232	7	1,627	80	Good
SW_1825	75TH ST	ABBOTT AVE	BYRON AVE	PCC	123	5	616	90	Excellent
SW_1850	75TH ST	HARDING AVE	ABBOTT AVE	PCC	202	6	1,213	80	Good
SW_2193	75TH ST	BYRON CT	CARLYLE AVE	PCC	232	4	926	80	Good
SW_2405	75TH ST	CARLYLE AVE	DICKENS AVE	PCC	226	5	1,132	90	Excellent
SW_2406	75TH ST	CARLYLE AVE	DICKENS AVE	PCC	211	7	1,479	80	Good
SW_2407	75TH ST	BYRON CT	CARLYLE AVE	PCC	261	5	1,303	80	Good
SW_2409	75TH ST	BYRON AVE	BYRON AVE	PCC	89	4	356	90	Excellent
SW_3130	75TH ST	COLLINS AVE	COLLINS CT	BR	148	6	890	80	Good
SW_0802	76TH ST	BEACH WALK	ATLANTIC WAY	PCC	301	5	1,503	90	Excellent
SW_0830	76TH ST	BEACH WALK	ATLANTIC WAY	PCC	351	5	1,754	90	Excellent
SW_1273	76TH ST	COLLINS CT	HARDING AVE	PCC	85	6	510	80	Good
SW_1282	76TH ST	COLLINS AVE	COLLINS CT	PCC	227	5	1,136	80	Good
SW_1314	76TH ST	COLLINS AVE	COLLINS CT	PCC	259	6	1,557	80	Good
SW_1321	76TH ST	COLLINS CT	HARDING AVE	PCC	48	6	286	80	Good
SW_1548	76TH ST	ABBOTT AVE	BYRON AVE	PCC	228	5	1,142	80	Good
SW_1593	76TH ST	ABBOTT AVE	BYRON AVE	PCC	225	5	1,126	80	Good
SW_1752	76TH ST	HARDING AVE	ABBOTT AVE	PCC	47	5	237	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1768	76TH ST	HARDING AVE	ABBOTT AVE	PCC	179	4	715	80	Good
SW_1795	76TH ST	HARDING AVE	ABBOTT AVE	PCC	223	6	1,340	70	Good
SW_2166	76TH ST	BYRON AVE	CARLYLE AVE	PCC	228	5	1,138	80	Good
SW_2185	76TH ST	BYRON AVE	CARLYLE AVE	PCC	228	6	1,368	90	Excellent
SW_2381	76TH ST	CARLYLE AVE	DICKENS AVE	PCC	227	5	1,133	90	Excellent
SW_2385	76TH ST	CARLYLE AVE	DICKENS AVE	PCC	226	6	1,353	90	Excellent
SW_0537	77TH ST	ATLANTIC WAY	COLLINS AVE	PCC	154	5	768	90	Excellent
SW_0539	77TH ST	ATLANTIC WAY	COLLINS AVE	PCC	147	6	881	90	Excellent
SW_0619	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	PCC	33	7	231	90	Excellent
SW_0628	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	PCC	178	6	1,066	90	Excellent
SW_0640	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	PCC	182	6	1,093	70	Good
SW_1214	77TH ST	COLLINS AVE	COLLINS CT	PCC	310	6	1,859	80	Good
SW_1221	77TH ST	COLLINS AVE	COLLINS CT	PCC	310	6	1,857	80	Good
SW_1435	77TH ST	ABBOTT AVE	BYRON AVE	PCC	217	6	1,301	80	Good
SW_1465	77TH ST	ABBOTT AVE	BYRON AVE	PCC	227	6	1,362	80	Good
SW_1692	77TH ST	HARDING AVE	ABBOTT AVE	PCC	229	5	1,147	80	Good
SW_1701	77TH ST	DICKENS AVE	TATUM WATERWAY DR	PCC	514	5	2,569	90	Excellent
SW_1709	77TH ST	HARDING AVE	ABBOTT AVE	PCC	215	5	1,073	80	Good
SW_1753	77TH ST	DICKENS AVE	TATUM WATERWAY DR	PCC	544	6	3,262	90	Excellent
SW_2078	77TH ST	BYRON AVE	CARLYLE AVE	PCC	223	5	1,113	70	Good
SW_2102	77TH ST	BYRON AVE	CARLYLE AVE	PCC	224	6	1,345	70	Good
SW_2264	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	PCC	380	5	1,902	90	Excellent
SW_2336	77TH ST	CARLYLE AVE	DICKENS AVE	PCC	225	6	1,348	80	Good
SW_2346	77TH ST	CARLYLE AVE	DICKENS AVE	PCC	219	5	1,093	80	Good
SW_3137	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	PCC	108	6	650	90	Excellent
SW_3138	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	PCC	119	8	953	80	Good
SW_3139	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	BR	72	6	433	90	Excellent
SW_0491	78TH ST	ATLANTIC WAY	COLLINS AVE	PCC	130	16	2,082	100	Excellent
SW_0514	78TH ST	ATLANTIC WAY	COLLINS AVE	PCC	329	6	1,976	70	Good
SW_1137	78TH ST	COLLINS AVE	COLLINS CT	PCC	309	5	1,547	80	Good
SW_1350	78TH ST	ABBOTT AVE	BYRON AVE	PCC	231	6	1,388	90	Excellent
SW_1372	78TH ST	ABBOTT AVE	BYRON AVE	PCC	224	6	1,343	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1545	78TH ST	COLLINS AVE	COLLINS CT	PCC	307	6	1,842	80	Good
SW_1631	78TH ST	DICKENS AVE	TATUM WATERWAY DR	PCC	13	4	52	90	Excellent
SW_1640	78TH ST	HARDING AVE	ABBOTT AVE	PCC	230	6	1,380	80	Good
SW_1661	78TH ST	HARDING AVE	ABBOTT AVE	PCC	219	6	1,312	80	Good
SW_1663	78TH ST	DICKENS AVE	TATUM WATERWAY DR	PCC	253	5	1,267	70	Good
SW_2002	78TH ST	BYRON AVE	CARLYLE AVE	PCC	229	6	1,372	80	Good
SW_2027	78TH ST	BYRON AVE	CARLYLE AVE	PCC	229	5	1,144	90	Excellent
SW_2211	78TH ST	DICKENS AVE	TATUM WATERWAY DR	PCC	228	6	1,368	90	Excellent
SW_2244	78TH ST	CARLYLE AVE	DICKENS AVE	PCC	111	6	667	90	Excellent
SW_2271	78TH ST	CARLYLE AVE	DICKENS AVE	PCC	113	6	680	80	Good
SW_2284	78TH ST	CARLYLE AVE	DICKENS AVE	PCC	224	5	1,120	90	Excellent
SW_3129	78TH ST	ATLANTIC WAY	COLLINS AVE	PCC	125	6	748	100	Excellent
SW_0460	79TH CSWY	SW END	NORMANDY DR	PCC	759	5	3,796	80	Good
SW_2142	79TH CSWY	SW END	NORMANDY DR	PCC	762	6	4,573	80	Good
SW_0441	79TH ST	COLLINS AVE	ATLANTIC WAY	PCC	135	5	673	-	U.C./N.A.
SW_1283	79TH ST	BYRON AVE	ABBOTT AVE	PCC	230	6	1,378	80	Good
SW_1303	79TH ST	BYRON AVE	ABBOTT AVE	PCC	226	5	1,129	80	Good
SW_1462	79TH ST	HARDING AVE	COLLINS CT	PCC	132	5	661	100	Excellent
SW_1478	79TH ST	COLLINS CT	COLLINS AVE	PCC	38	6	229	90	Excellent
SW_1493	79TH ST	COLLINS CT	COLLINS AVE	PCC	140	4	560	80	Good
SW_1501	79TH ST	COLLINS CT	COLLINS AVE	PCC	298	7	2,087	90	Excellent
SW_1521	79TH ST	ABBOTT AVE	HARDING AVE	PCC	214	5	1,071	80	Good
SW_1547	79TH ST	ABBOTT AVE	HARDING AVE	PCC	106	6	638	80	Good
SW_1557	79TH ST	ABBOTT AVE	HARDING AVE	PCC	121	6	728	80	Good
SW_1581	79TH ST	ABBOTT AVE	HARDING AVE	PCC	8	6	50	90	Excellent
SW_1944	79TH ST	CARLYLE AVE	BYRON AVE	PCC	229	6	1,371	80	Good
SW_1968	79TH ST	CARLYLE AVE	BYRON AVE	PCC	227	5	1,134	80	Good
SW_2150	79TH ST	DICKENS AVE	CARLYLE AVE	PCC	225	6	1,351	80	Good
SW_2152	79TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	350	7	2,447	90	Excellent
SW_2174	79TH ST	DICKENS AVE	CARLYLE AVE	PCC	223	5	1,114	80	Good
SW_2178	79TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	306	8	2,448	90	Excellent
SW_2089	79TH TER	HAWTHORNE AVE	CRESPI BLVD	PCC	578	6	3,467	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2096	79TH TER	HAWTHORNE AVE	CRESPI BLVD	PCC	511	6	3,068	90	Excellent
SW_0125	7TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	243	5	1,214	80	Good
SW_0547	7TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	245	5	1,223	80	Good
SW_0146	7TH ST	LENOX CT	ALTON RD	PCC	171	4	683	90	Excellent
SW_0153	7TH ST	LENOX AVE	LENOX CT	PCC	169	4	677	90	Excellent
SW_0156	7TH ST	LENOX AVE	LENOX CT	PCC	168	6	1,007	90	Excellent
SW_0163	7TH ST	MICHIGAN AVE	7TH ST	PCC	335	6	2,011	90	Excellent
SW_0169	7TH ST	LENOX CT	ALTON RD	PCC	167	5	836	90	Excellent
SW_0174	7TH ST	MICHIGAN AVE	7TH ST	PCC	339	5	1,695	90	Excellent
SW_0324	7TH ST	OCEAN CT	COLLINS AVE	PCC	139	9	1,253	80	Good
SW_0338	7TH ST	OCEAN DR	OCEAN CT	PCC	161	8	1,284	80	Good
SW_0342	7TH ST	COLLINS AVE	COLLINS CT	PCC	148	9	1,331	60	Good
SW_0350	7TH ST	COLLINS CT	WASHINGTON AVE	PCC	159	9	1,431	90	Excellent
SW_0358	7TH ST	COLLINS CT	WASHINGTON AVE	PCC	158	8	1,268	80	Good
SW_0363	7TH ST	COLLINS AVE	COLLINS CT	PCC	151	8	1,207	90	Excellent
SW_0450	7TH ST	OCEAN DR	OCEAN CT	PCC	150	8	1,197	80	Good
SW_0835	7TH ST	EUCLID CT	MERIDIAN AVE	PCC	325	5	1,623	80	Good
SW_0846	7TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	PCC	387	8	3,093	80	Good
SW_0857	7TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	307	5	1,536	90	Excellent
SW_0877	7TH ST	EUCLID CT	MERIDIAN AVE	PCC	319	4	1,277	72	Good
SW_1267	7TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	311	5	1,553	100	Excellent
SW_1276	7TH ST	JEFFERSON CT	MICHIGAN AVE	PCC	314	5	1,568	90	Excellent
SW_1307	7TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	316	5	1,581	90	Excellent
SW_1316	7TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	330	5	1,651	100	Excellent
SW_1706	7TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	PCC	38	7	264	100	Excellent
SW_2111	7TH ST	BEACH WALK	OCEAN DR	PCC	154	9	1,383	70	Good
SW_2717	7TH ST	OCEAN CT	COLLINS AVE	PCC	156	8	1,248	80	Good
SW_1207	80TH ST	ABBOTT AVE	BYRON AVE	PCC	228	4	911	90	Excellent
SW_1215	80TH ST	ABBOTT AVE	BYRON AVE	PCC	226	5	1,128	90	Excellent
SW_1387	80TH ST	COLLINS AVE	COLLINS CT	PCC	309	6	1,855	75	Good
SW_1443	80TH ST	COLLINS AVE	COLLINS CT	PCC	308	5	1,539	72	Good
SW_1472	80TH ST	HARDING AVE	ABBOTT AVE	PCC	223	6	1,339	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1502	80TH ST	HARDING AVE	ABBOTT AVE	PCC	216	5	1,078	73	Good
SW_1796	80TH ST	BYRON AVE	CARLYLE AVE	PCC	224	6	1,344	90	Excellent
SW_1886	80TH ST	BYRON AVE	CARLYLE AVE	PCC	225	6	1,352	90	Excellent
SW_1905	80TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	790	6	4,738	80	Good
SW_1929	80TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	608	6	3,646	90	Excellent
SW_1979	80TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	125	6	753	80	Good
SW_1138	81ST ST	ABBOTT AVE	BYRON AVE	PCC	208	5	1,041	80	Good
SW_1164	81ST ST	ABBOTT AVE	BYRON AVE	PCC	213	6	1,276	80	Good
SW_1173	81ST ST	ABBOTT AVE	BYRON AVE	PCC	19	4	77	100	Excellent
SW_1245	81ST ST	HARDING AVE	ABBOTT AVE	PCC	224	5	1,118	80	Good
SW_1293	81ST ST	HARDING AVE	ABBOTT AVE	PCC	217	6	1,303	80	Good
SW_1300	81ST ST	COLLINS AVE	COLLINS CT	PCC	320	6	1,920	77	Good
SW_1329	81ST ST	COLLINS AVE	COLLINS CT	PCC	303	5	1,517	80	Good
SW_1854	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	PCC	943	5	4,716	90	Excellent
SW_2542	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	PCC	1,007	6	6,043	90	Excellent
SW_1220	82ND ST	COLLINS CT	HARDING AVE	PCC	20	7	141	90	Excellent
SW_1244	82ND ST	COLLINS AVE	COLLINS CT	PCC	298	5	1,488	80	Good
SW_1254	82ND ST	COLLINS AVE	COLLINS CT	PCC	172	5	862	80	Good
SW_1263	82ND ST	COLLINS CT	HARDING AVE	PCC	110	7	770	90	Excellent
SW_1518	82ND ST	ABBOTT AVE	BYRON AVE	PCC	105	6	630	90	Excellent
SW_1544	82ND ST	ABBOTT AVE	BYRON AVE	PCC	116	6	696	90	Excellent
SW_2355	82ND ST	CRESPI BLVD	HAWTHORNE AVE	PCC	1,027	6	6,163	80	Good
SW_2371	82ND ST	CRESPI BLVD	HAWTHORNE AVE	PCC	58	6	348	90	Excellent
SW_2419	82ND ST	CRESPI BLVD	HAWTHORNE AVE	PCC	1,095	6	6,573	80	Good
SW_1184	82ND TER	ABBOTT AVE	BYRON AVE	PCC	108	4	431	90	Excellent
SW_1394	82ND TER	ABBOTT AVE	BYRON AVE	PCC	112	6	669	90	Excellent
SW_1123	83RD ST	COLLINS CT	HARDING AVE	PCC	47	6	281	80	Good
SW_1143	83RD ST	COLLINS AVE	COLLINS CT	PCC	264	5	1,318	76	Good
SW_1154	83RD ST	HARDING AVE	ABBOTT AVE	PCC	245	5	1,226	80	Good
SW_1193	83RD ST	COLLINS AVE	COLLINS CT	PCC	303	6	1,819	80	Good
SW_1360	83RD ST	HARDING AVE	ABBOTT AVE	PCC	221	6	1,324	80	Good
SW_2125	83RD ST	HAWTHORNE AVE	CRESPI BLVD	PCC	1,081	6	6,486	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2290	83RD ST	HAWTHORNE AVE	CRESPI BLVD	PCC	1,082	6	6,494	90	Excellent
SW_1033	84TH ST	COLLINS AVE	COLLINS CT	PCC	203	6	1,217	80	Good
SW_1056	84TH ST	COLLINS AVE	COLLINS CT	PCC	143	5	713	80	Good
SW_1057	84TH ST	COLLINS CT	HARDING AVE	PCC	172	6	1,031	80	Good
SW_1058	84TH ST	HARDING AVE	BYRON AVE	PCC	376	6	2,257	80	Good
SW_1067	84TH ST	COLLINS CT	HARDING AVE	PCC	103	6	619	80	Good
SW_1101	84TH ST	HARDING AVE	BYRON AVE	PCC	305	6	1,831	80	Good
SW_1122	84TH ST	HARDING AVE	BYRON AVE	PCC	72	6	430	80	Good
SW_1978	84TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	1,070	5	5,352	80	Good
SW_2056	84TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	1,074	6	6,447	77	Good
SW_0051	85TH ST	ATLANTIC WAY	COLLINS AVE	PCC	35	8	282	100	Excellent
SW_0058	85TH ST	BYRON AVE	CRESPI BLVD	PCC	85	5	427	50	Fair
SW_0066	85TH ST	BYRON AVE	CRESPI BLVD	PCC	264	6	1,582	90	Excellent
SW_0067	85TH ST	BYRON AVE	CRESPI BLVD	PCC	88	6	529	70	Good
SW_0728	85TH ST	HARDING AVE	BYRON AVE	PCC	367	6	2,201	90	Excellent
SW_0746	85TH ST	HARDING AVE	BYRON AVE	PCC	373	6	2,241	90	Excellent
SW_0828	85TH ST	BYRON AVE	CRESPI BLVD	PCC	91	4	365	90	Excellent
SW_0853	85TH ST	COLLINS AVE	COLLINS CT	PCC	307	5	1,533	90	Excellent
SW_0872	85TH ST	COLLINS AVE	COLLINS CT	PCC	308	5	1,538	90	Excellent
SW_1694	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	117	5	583	90	Excellent
SW_1711	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	21	6	127	80	Good
SW_1743	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	70	6	423	90	Excellent
SW_1770	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	570	6	3,422	80	Good
SW_1781	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	255	6	1,529	90	Excellent
SW_1852	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	16	5	80	90	Excellent
SW_1853	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	734	6	4,405	80	Good
SW_1863	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	11	5	57	90	Excellent
SW_1871	85TH ST	CRESPI BLVD	HAWTHORNE AVE	PCC	320	5	1,600	80	Good
SW_0373	86TH ST	CRESPI BLVD	STILLWATER DR	PCC	55	5	273	90	Excellent
SW_0437	86TH ST	CRESPI BLVD	STILLWATER DR	PCC	654	6	3,925	100	Excellent
SW_0485	86TH ST	CRESPI BLVD	STILLWATER DR	PCC	478	5	2,392	90	Excellent
SW_0771	86TH ST	HARDING AVE	BYRON AVE	PCC	372	6	2,230	86	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0843	86TH ST	HARDING AVE	BYRON AVE	PCC	120	5	601	80	Good
SW_1531	86TH ST	CRESPI BLVD	STILLWATER DR	PCC	48	10	476	90	Excellent
SW_1584	86TH ST	CRESPI BLVD	STILLWATER DR	PCC	1,067	5	5,337	100	Excellent
SW_0959	87TH ST	COLLINS AVE	COLLINS CT	PCC	186	6	1,114	70	Good
SW_0977	87TH ST	COLLINS AVE	COLLINS CT	PCC	209	5	1,047	70	Good
SW_0006	87TH TER	BEACH SVRD	COLLINS AVE	PCC	244	7	1,707	-	U.C./N.A.
SW_0921	87TH TER	COLLINS AVE	HARDING AVE	PCC	97	7	681	70	Good
SW_0580	8TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	244	5	1,221	90	Excellent
SW_2879	8TH DI LIDO TER	DI LIDO DR	DI LIDO DR	PCC	238	5	1,189	88	Good
SW_0207	8TH ST	LENOX CT	ALTON RD	PCC	173	5	867	90	Excellent
SW_0215	8TH ST	8TH ST	LENOX AVE	PCC	341	5	1,704	90	Excellent
SW_0221	8TH ST	LENOX AVE	LENOX CT	PCC	165	5	825	90	Excellent
SW_0225	8TH ST	LENOX AVE	LENOX CT	PCC	171	5	856	90	Excellent
SW_0228	8TH ST	8TH ST	LENOX AVE	PCC	325	6	1,952	80	Good
SW_0238	8TH ST	LENOX CT	ALTON RD	PCC	173	4	693	90	Excellent
SW_0372	8TH ST	OCEAN CT	COLLINS AVE	PCC	156	8	1,250	90	Excellent
SW_0379	8TH ST	COLLINS AVE	COLLINS CT	PCC	164	8	1,313	90	Excellent
SW_0383	8TH ST	OCEAN CT	COLLINS AVE	PCC	163	8	1,306	90	Excellent
SW_0387	8TH ST	COLLINS CT	WASHINGTON AVE	PCC	157	9	1,415	90	Excellent
SW_0388	8TH ST	COLLINS CT	WASHINGTON AVE	PCC	147	9	1,320	90	Excellent
SW_0397	8TH ST	COLLINS AVE	COLLINS CT	PCC	153	8	1,221	90	Excellent
SW_0890	8TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	323	5	1,616	80	Good
SW_0902	8TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	318	5	1,589	80	Good
SW_0914	8TH ST	EUCLID CT	MERIDIAN AVE	PCC	329	6	1,973	80	Good
SW_0940	8TH ST	EUCLID CT	MERIDIAN AVE	PCC	315	6	1,891	80	Good
SW_1295	8TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	323	5	1,617	90	Excellent
SW_1308	8TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	316	5	1,579	90	Excellent
SW_1332	8TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	320	6	1,922	90	Excellent
SW_1343	8TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	323	5	1,616	90	Excellent
SW_1345	8TH ST	ALTON CT	WEST AVE	PCC	155	6	930	90	Excellent
SW_1355	8TH ST	ALTON RD	ALTON CT	PCC	166	5	832	80	Good
SW_1377	8TH ST	ALTON RD	ALTON CT	PCC	176	6	1,053	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1384	8TH ST	ALTON CT	WEST AVE	PCC	153	6	918	80	Good
SW_1757	8TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	PCC	128	6	767	80	Good
SW_1758	8TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	PCC	144	7	1,008	80	Good
SW_2092	8TH ST	BEACH WALK	OCEAN DR	PCC	73	10	732	70	Good
SW_3072	8TH ST	OCEAN DR	OCEAN CT	PCC	147	9	1,322	90	Excellent
SW_3073	8TH ST	OCEAN DR	OCEAN CT	PCC	149	12	1,786	90	Excellent
SW_0256	9TH ST	MICHIGAN AVE	LENOX AVE	PCC	336	5	1,680	60	Good
SW_0261	9TH ST	LENOX AVE	ALTON RD	PCC	332	6	1,990	70	Good
SW_0264	9TH ST	MICHIGAN AVE	LENOX AVE	PCC	334	6	2,004	60	Good
SW_0272	9TH ST	LENOX AVE	ALTON RD	PCC	335	8	2,676	80	Good
SW_0403	9TH ST	OCEAN CT	COLLINS AVE	PCC	154	8	1,233	90	Excellent
SW_0412	9TH ST	COLLINS AVE	COLLINS CT	PCC	151	7	1,055	90	Excellent
SW_0413	9TH ST	OCEAN DR	OCEAN CT	PCC	153	7	1,069	80	Good
SW_0417	9TH ST	COLLINS CT	WASHINGTON AVE	PCC	166	7	1,164	80	Good
SW_0941	9TH ST	PENNSYLVANIA CT	EUCLID AVE	PCC	318	5	1,589	90	Excellent
SW_0963	9TH ST	EAST END	WEST END	PCC	320	6	1,919	90	Excellent
SW_0971	9TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	PCC	315	5	1,573	90	Excellent
SW_0982	9TH ST	EUCLID AVE	EUCLID CT	PCC	294	5	1,471	80	Good
SW_1241	9TH ST	ALTON CT	WEST AVE	PCC	151	6	906	80	Good
SW_1260	9TH ST	ALTON RD	ALTON CT	PCC	156	6	934	90	Excellent
SW_1278	9TH ST	ALTON RD	ALTON CT	PCC	166	5	830	80	Good
SW_1297	9TH ST	ALTON CT	WEST AVE	PCC	150	6	902	80	Good
SW_1363	9TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	314	6	1,886	70	Good
SW_1364	9TH ST	JEFFERSON AVE	JEFFERSON CT	PCC	320	6	1,918	70	Good
SW_1375	9TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	320	5	1,600	80	Good
SW_1389	9TH ST	MERIDIAN CT	JEFFERSON AVE	PCC	319	5	1,595	80	Good
SW_1749	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	PCC	216	7	1,515	80	Good
SW_1765	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	PCC	215	7	1,503	80	Good
SW_3067	9TH ST	COLLINS AVE	COLLINS CT	PCC	157	6	942	80	Good
SW_3068	9TH ST	COLLINS CT	WASHINGTON AVE	PCC	147	8	1,172	90	Excellent
SW_3071	9TH ST	OCEAN CT	COLLINS AVE	PCC	155	8	1,236	80	Good
SW_3074	9TH ST	OCEAN DR	OCEAN CT	PCC	160	8	1,276	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0335	ABBOTT AVE	71ST ST	69TH ST	PCC	604	5	3,018	79	Good
SW_0352	ABBOTT AVE	NORMANDY BEACH CT	71ST ST	PCC	74	6	443	70	Good
SW_0432	ABBOTT AVE	69TH ST	INDIAN CREEK DR	PCC	705	5	3,527	80	Good
SW_0467	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	PCC	199	7	1,392	77	Good
SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	PCC	301	6	1,806	70	Good
SW_0488	ABBOTT AVE	69TH ST	INDIAN CREEK DR	PCC	855	6	5,130	79	Good
SW_0498	ABBOTT AVE	71ST ST	69TH ST	PCC	587	5	2,934	77	Good
SW_1000	ABBOTT AVE	75TH ST	76TH ST	PCC	148	5	740	70	Good
SW_1046	ABBOTT AVE	76TH ST	77TH ST	PCC	293	5	1,464	80	Good
SW_1085	ABBOTT AVE	77TH ST	78TH ST	PCC	290	5	1,450	80	Good
SW_1124	ABBOTT AVE	78TH ST	79TH ST	PCC	290	6	1,740	80	Good
SW_1146	ABBOTT AVE	79TH ST	80TH ST	PCC	292	5	1,462	80	Good
SW_1163	ABBOTT AVE	82ND TER	83RD ST	PCC	130	4	520	80	Good
SW_1174	ABBOTT AVE	80TH ST	81ST ST	PCC	294	5	1,471	90	Excellent
SW_1185	ABBOTT AVE	80TH ST	81ST ST	PCC	20	5	98	100	Excellent
SW_1195	ABBOTT AVE	80TH ST	81ST ST	PCC	274	4	1,095	90	Excellent
SW_1237	ABBOTT AVE	79TH ST	80TH ST	PCC	200	6	1,200	90	Excellent
SW_1248	ABBOTT AVE	79TH ST	80TH ST	PCC	95	6	568	80	Good
SW_1301	ABBOTT AVE	81ST ST	82ND ST	PCC	254	6	1,524	80	Good
SW_1315	ABBOTT AVE	78TH ST	79TH ST	PCC	293	6	1,761	80	Good
SW_1320	ABBOTT AVE	82ND ST	82ND TER	PCC	286	6	1,718	73	Good
SW_1339	ABBOTT AVE	82ND TER	83RD ST	PCC	120	6	719	80	Good
SW_1414	ABBOTT AVE	77TH ST	78TH ST	PCC	298	6	1,788	80	Good
SW_1471	ABBOTT AVE	82ND ST	82ND TER	PCC	229	5	1,146	80	Good
SW_1529	ABBOTT AVE	76TH ST	77TH ST	PCC	293	6	1,755	80	Good
SW_1552	ABBOTT AVE	81ST ST	82ND ST	PCC	230	5	1,151	80	Good
SW_1600	ABBOTT AVE	75TH ST	76TH ST	PCC	150	5	751	80	Good
SW_2472	ABBOTT AVE	69TH ST	INDIAN CREEK DR	PCC	50	13	651	100	Excellent
SW_2980	ADAMS AVE	43RD CT	44TH CT	PCC	362	4	1,449	80	Good
SW_2984	ADAMS AVE	43RD CT	44TH CT	PCC	363	4	1,452	53	Fair
SW_2992	ADAMS AVE	44TH CT	46TH ST	PCC	1,386	4	5,544	80	Good
SW_2994	ADAMS AVE	44TH CT	46TH ST	PCC	1,373	4	5,493	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0009	ALTON RD	21ST ST	23RD ST	PCC	14	7	99	90	Excellent
SW_0022	ALTON RD	2ND ST	4TH ST	PCC	1,013	10	10,127	90	Excellent
SW_0024	ALTON RD	ALTON RD	SUNSET DR	PCC	201	7	1,404	80	Good
SW_0059	ALTON RD	4TH ST	MAC ARTHUR CSWY	PCC	237	10	2,367	90	Excellent
SW_0068	ALTON RD	ALTON RD	18TH ST	PCC	417	7	2,917	78	Good
SW_0079	ALTON RD	12TH ST	13TH ST	PCC	380	8	3,038	90	Excellent
SW_0092	ALTON RD	MAC ARTHUR CSWY	6TH ST	PCC	388	8	3,106	90	Excellent
SW_0136	ALTON RD	6TH ST	7TH ST	PCC	399	7	2,793	90	Excellent
SW_0141	ALTON RD	13TH ST	14TH ST	PCC	404	8	3,231	90	Excellent
SW_0167	ALTON RD	47TH CT	47TH ST	PCC	108	4	433	90	Excellent
SW_0180	ALTON RD	7TH ST	8TH ST	PCC	296	6	1,776	90	Excellent
SW_0181	ALTON RD	14TH ST	14TH CT	PCC	411	5	2,053	90	Excellent
SW_0195	ALTON RD	7TH ST	8TH ST	PCC	109	7	762	90	Excellent
SW_0196	ALTON RD	14TH CT	15TH ST	PCC	319	8	2,555	64	Good
SW_0197	ALTON RD	DADE BLVD	17TH ST	PCC	637	9	5,736	80	Good
SW_0206	ALTON RD	43RD ST	I 195	PCC	106	9	951	90	Excellent
SW_0214	ALTON RD	BAY RD	29TH ST	PCC	442	9	3,975	88	Good
SW_0231	ALTON RD	18TH ST	DADE BLVD	PCC	70	4	281	80	Good
SW_0247	ALTON RD	58TH ST	57TH ST	PCC	586	5	2,931	80	Good
SW_0253	ALTON RD	8TH ST	9TH ST	PCC	362	6	2,171	89	Good
SW_0257	ALTON RD	15TH ST	15TH TER	PCC	219	8	1,748	90	Excellent
SW_0258	ALTON RD	LAKEVIEW DR	51ST ST	PCC	303	7	2,122	60	Good
SW_0259	ALTON RD	ALTON RD	ALTON RD	PCC	242	5	1,210	90	Excellent
SW_0265	ALTON RD	15TH TER	16TH ST	PCC	228	6	1,367	90	Excellent
SW_0266	ALTON RD	LAKEVIEW DR	51ST ST	PCC	114	7	796	90	Excellent
SW_0268	ALTON RD	ALTON RD	MICHIGAN AVE	PCC	279	5	1,394	90	Excellent
SW_0274	ALTON RD	LINCOLN CT	17TH ST	PCC	519	6	3,112	80	Good
SW_0282	ALTON RD	9TH ST	10TH ST	PCC	420	7	2,938	90	Excellent
SW_0299	ALTON RD	ALTON RD	SUNSET DR	PCC	207	6	1,242	80	Good
SW_0302	ALTON RD	16TH ST	LINCOLN RD	PCC	484	12	5,807	90	Excellent
SW_0313	ALTON RD	ALTON RD	ALTON RD	PCC	19	6	111	90	Excellent
SW_0321	ALTON RD	54TH ST	53RD ST	PCC	658	5	3,291	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0322	ALTON RD	10TH ST	11TH ST	PCC	420	11	4,622	88	Good
SW_0333	ALTON RD	ALTON RD	SUNSET DR	PCC	179	6	1,075	58	Fair
SW_0336	ALTON RD	LINCOLN CT	17TH ST	PCC	508	10	5,082	80	Good
SW_0374	ALTON RD	53RD ST	54TH ST	PCC	19	5	95	80	Good
SW_0399	ALTON RD	BAY RD	ALTON RD	PCC	391	6	2,344	90	Excellent
SW_0402	ALTON RD	17TH ST	DADE BLVD	PCC	365	7	2,555	80	Good
SW_0407	ALTON RD	27TH ST	23RD ST	PCC	895	5	4,477	80	Good
SW_0411	ALTON RD	17TH ST	DADE BLVD	PCC	94	7	658	70	Good
SW_0464	ALTON RD	53RD ST	52ND ST	PCC	691	5	3,453	79	Good
SW_0616	ALTON RD	COMMERCE ST	1ST ST	PCC	261	8	2,085	90	Excellent
SW_0675	ALTON RD	1ST ST	2ND ST	PCC	477	7	3,342	90	Excellent
SW_0711	ALTON RD	11TH ST	12TH ST	PCC	366	6	2,198	90	Excellent
SW_1023	ALTON RD	I 195	NAUTILUS DR	BR	149	12	1,793	70	Good
SW_1167	ALTON RD	2ND ST	1ST ST	PCC	291	9	2,617	80	Good
SW_1176	ALTON RD	I 195-ALTON RAMPON	34TH ST	PCC	178	5	891	80	Good
SW_1374	ALTON RD	52ND ST	53RD ST	PCC	102	7	715	40	Fair
SW_1400	ALTON RD	7TH ST	6TH ST	PCC	270	8	2,159	100	Excellent
SW_1406	ALTON RD	59TH ST	58TH ST	PCC	588	5	2,940	79	Good
SW_1411	ALTON RD	8TH ST	7TH ST	PCC	393	8	3,140	90	Excellent
SW_1426	ALTON RD	8TH ST	9TH ST	PCC	351	8	2,812	80	Good
SW_1434	ALTON RD	9TH ST	10TH ST	PCC	405	8	3,243	80	Good
SW_1439	ALTON RD	10TH ST	11TH ST	PCC	415	7	2,908	90	Excellent
SW_1449	ALTON RD	11TH ST	12TH ST	PCC	299	8	2,390	80	Good
SW_1459	ALTON RD	12TH ST	13TH ST	PCC	414	7	2,895	90	Excellent
SW_1484	ALTON RD	13TH ST	14TH ST	PCC	439	6	2,632	90	Excellent
SW_1499	ALTON RD	14TH ST	14TH CT	PCC	388	9	3,488	90	Excellent
SW_1506	ALTON RD	14TH CT	15TH ST	PCC	316	9	2,840	90	Excellent
SW_1515	ALTON RD	15TH ST	15TH TER	PCC	289	8	2,312	80	Good
SW_1525	ALTON RD	15TH TER	16TH ST	PCC	215	4	861	90	Excellent
SW_1534	ALTON RD	16TH ST	LINCOLN RD	PCC	482	14	6,748	90	Excellent
SW_1801	ALTON RD	60TH ST	59TH ST	PCC	586	5	2,932	78	Good
SW_1985	ALTON RD	BARRY ST	39TH ST	PCC	227	5	1,136	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2014	ALTON RD	62ND ST	60TH ST	PCC	709	5	3,543	79	Good
SW_2108	ALTON RD	63RD ST	62ND ST	PCC	283	5	1,417	90	Excellent
SW_2120	ALTON RD	53RD ST	54TH ST	PCC	29	5	145	70	Good
SW_2128	ALTON RD	54TH ST	56TH ST	PCC	46	5	228	90	Excellent
SW_2223	ALTON RD	LA GORCE DR	63RD ST	PCC	111	9	1,001	80	Good
SW_2224	ALTON RD	29TH ST	27TH ST	PCC	283	10	2,827	80	Good
SW_2235	ALTON RD	LA GORCE DR	63RD ST	PCC	57	4	229	90	Excellent
SW_2250	ALTON RD	19TH ST	ALTON RD	PCC	289	5	1,445	90	Excellent
SW_2258	ALTON RD	LA GORCE DR	63RD ST	PCC	327	5	1,633	80	Good
SW_2299	ALTON RD	54TH ST	56TH ST	PCC	26	4	103	80	Good
SW_2306	ALTON RD	BARRY ST	39TH ST	PCC	173	11	1,907	100	Excellent
SW_2334	ALTON RD	29TH ST	27TH ST	PCC	454	5	2,268	80	Good
SW_2393	ALTON RD	BAY RD	43RD ST	PCC	232	5	1,159	80	Good
SW_2506	ALTON RD	62ND ST	63RD ST	PCC	316	5	1,580	80	Good
SW_2546	ALTON RD	56TH ST	54TH ST	PCC	684	5	3,421	76	Good
SW_2567	ALTON RD	I 195-ALTON RAMPON	34TH ST	PCC	128	6	766	90	Excellent
SW_2589	ALTON RD	51ST ST	51ST ST	PCC	80	8	643	90	Excellent
SW_2603	ALTON RD	LAKEVIEW DR	51ST ST	PCC	78	8	624	90	Excellent
SW_2611	ALTON RD	56TH ST	57TH ST	PCC	648	5	3,239	80	Good
SW_2663	ALTON RD	57TH ST	58TH ST	PCC	599	4	2,398	87	Good
SW_2680	ALTON RD	58TH ST	59TH ST	PCC	564	5	2,822	76	Good
SW_2694	ALTON RD	59TH ST	60TH ST	PCC	538	5	2,688	72	Good
SW_2737	ALTON RD	47TH ST	47TH CT	PCC	204	5	1,018	90	Excellent
SW_2745	ALTON RD	LAKEVIEW DR	51ST ST	PCC	54	6	326	80	Good
SW_2756	ALTON RD	BAY RD	29TH ST	PCC	1,505	5	7,526	70	Good
SW_2763	ALTON RD	23RD ST	ALTON RD	PCC	893	5	4,463	80	Good
SW_2765	ALTON RD	ALTON RD	MICHIGAN AVE	PCC	1,050	5	5,249	77	Good
SW_2767	ALTON RD	52ND ST	51ST ST	PCC	628	5	3,139	80	Good
SW_2769	ALTON RD	51ST ST	52ND ST	PCC	27	7	187	90	Excellent
SW_2770	ALTON RD	51ST ST	52ND ST	PCC	694	5	3,470	76	Good
SW_2779	ALTON RD	52ND ST	53RD ST	PCC	728	5	3,641	80	Good
SW_2784	ALTON RD	53RD ST	54TH ST	PCC	684	5	3,421	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2792	ALTON RD	54TH ST	56TH ST	PCC	714	5	3,568	79	Good
SW_2796	ALTON RD	57TH ST	56TH ST	PCC	615	5	3,077	67	Good
SW_2798	ALTON RD	51ST ST	BAY RD	PCC	661	5	3,306	70	Good
SW_2799	ALTON RD	48TH ST	LAKEVIEW DR	PCC	384	7	2,685	90	Excellent
SW_2807	ALTON RD	18TH ST	19TH ST	PCC	378	9	3,398	90	Excellent
SW_2808	ALTON RD	39TH ST	I 195	BR	356	8	2,847	90	Excellent
SW_2813	ALTON RD	ALTON RD	SUNSET DR	PCC	159	5	793	90	Excellent
SW_2814	ALTON RD	ALTON RD	SUNSET DR	PCC	238	7	1,663	80	Good
SW_2840	ALTON RD	BAY RD	48TH ST	PCC	560	7	3,923	90	Excellent
SW_2849	ALTON RD	60TH ST	62ND ST	PCC	655	5	3,277	54	Fair
SW_2853	ALTON RD	47TH CT	48TH ST	PCC	555	5	2,776	80	Good
SW_2880	ALTON RD	47TH ST	46TH ST	PCC	62	4	246	90	Excellent
SW_2889	ALTON RD	NAUTILUS DR	43RD ST	PCC	713	5	3,564	80	Good
SW_2891	ALTON RD	46TH ST	47TH ST	PCC	238	5	1,191	90	Excellent
SW_2894	ALTON RD	47TH ST	46TH ST	PCC	61	4	245	90	Excellent
SW_2918	ALTON RD	44TH ST	ALTON RD	PCC	739	5	3,693	80	Good
SW_2965	ALTON RD	43RD ST	I 195	PCC	813	5	4,063	69	Good
SW_2968	ALTON RD	43RD ST	ALTON RD	PCC	413	5	2,064	80	Good
SW_2970	ALTON RD	44TH ST	44TH CT	PCC	484	5	2,419	80	Good
SW_2972	ALTON RD	ALTON RD	44TH ST	PCC	594	5	2,969	79	Good
SW_2976	ALTON RD	45TH ST	46TH ST	PCC	578	5	2,891	80	Good
SW_2983	ALTON RD	47TH CT	47TH ST	PCC	307	5	1,534	80	Good
SW_2985	ALTON RD	48TH ST	47TH CT	PCC	611	5	3,054	80	Good
SW_3007	ALTON RD	44TH CT	44TH ST	PCC	481	5	2,404	80	Good
SW_3009	ALTON RD	45TH ST	44TH CT	PCC	518	5	2,589	80	Good
SW_3015	ALTON RD	46TH ST	45TH ST	PCC	686	5	3,428	80	Good
SW_3016	ALTON RD	47TH ST	46TH ST	PCC	291	5	1,455	80	Good
SW_3036	ALTON RD	ALTON RD	BAY RD	PCC	380	10	3,805	80	Good
SW_3047	ALTON RD	MAC ARTHUR CSWY	4TH ST	PCC	208	14	2,912	90	Excellent
SW_3049	ALTON RD	2ND ST	1ST ST	PCC	532	11	5,857	90	Excellent
SW_3050	ALTON RD	MAC ARTHUR CSWY	4TH ST	PCC	143	11	1,577	80	Good
SW_3056	ALTON RD	2ND ST	1ST ST	PCC	1,911	19	36,313	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3057	ALTON RD	1ST ST	POINTE DR	PCC	631	10	6,314	90	Excellent
SW_3062	ALTON RD	4TH ST	2ND ST	PCC	1,066	13	13,853	90	Excellent
SW_3083	ALTON RD	39TH ST	I 195	PCC	213	6	1,276	90	Excellent
SW_3084	ALTON RD	BARRY ST	39TH ST	PCC	293	6	1,756	70	Good
SW_3088	ALTON RD	2ND ST	1ST ST	PCC	1,171	15	17,570	80	Good
SW_3089	ALTON RD	2ND ST	1ST ST	PCC	789	17	13,412	80	Good
SW_3107	ALTON RD	15TH ST	15TH TER	PCC	61	8	486	-	U.C./N.A.
SW_3109	ALTON RD	7TH ST	6TH ST	PCC	200	8	1,604	80	Good
SW_3159	ALTON RD	48TH ST	LAKEVIEW DR	PCC	170	6	1,019	54	Fair
SW_3168	ALTON RD	20TH ST	20TH ST	PCC	23	6	138	90	Excellent
SW_3169	ALTON RD	ALTON RD	SUNSET DR	PCC	70	8	563	-	U.C./N.A.
SW_0452	AQUA AVE	63RD ST	ARI WAY	PCC	108	4	434	80	Good
SW_0496	BARRY ST	MERIDIAN AVE	GARDEN AVE	PCC	306	5	1,528	90	Excellent
SW_0925	BARRY ST	GARDEN AVE	ALTON RD	PCC	229	6	1,375	90	Excellent
SW_1763	BARRY ST	GARDEN AVE	ALTON RD	PCC	219	6	1,313	80	Good
SW_2781	BARRY ST	MERIDIAN AVE	GARDEN AVE	PCC	310	5	1,551	79	Good
SW_0037	BAY DR	CALAIS DR	NW END	PCC	148	5	738	90	Excellent
SW_0416	BAY DR	NORMANDY DR	CALAIS DR	PCC	817	6	4,900	79	Good
SW_0469	BAY DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	675	5	3,377	80	Good
SW_0523	BAY DR	EAST END	RUE NOTRE DAME	PCC	691	5	3,457	80	Good
SW_0686	BAY DR	BREST ESPLANADE	RUE VERSAILLES	PCC	852	5	4,258	69	Good
SW_0782	BAY DR	BREST ESPLANADE	BIARRITZ CT	PCC	860	5	4,299	80	Good
SW_0794	BAY DR	BIARRITZ CT	NORMANDY DR	PCC	141	8	1,128	90	Excellent
SW_1351	BAY DR	NORMANDY DR	CALAIS DR	PCC	739	5	3,693	80	Good
SW_1571	BAY DR	MARSEILLE DR	SHORE DR	PCC	273	6	1,639	90	Excellent
SW_1591	BAY DR	NORMANDY DR	MARSEILLE DR	PCC	606	7	4,240	80	Good
SW_1645	BAY DR	MARSEILLE DR	SHORE DR	PCC	163	7	1,140	90	Excellent
SW_1654	BAY DR	BREST ESPLANADE	BIARRITZ CT	PCC	814	5	4,068	80	Good
SW_1686	BAY DR	MARSEILLE DR	SHORE DR	PCC	106	5	530	90	Excellent
SW_1719	BAY DR	BREST ESPLANADE	RUE VERSAILLES	PCC	949	5	4,746	80	Good
SW_1808	BAY DR	EAST END	RUE NOTRE DAME	PCC	672	5	3,358	70	Good
SW_1815	BAY DR	EAST END	RUE NOTRE DAME	PCC	100	4	401	70	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1877	BAY DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	674	6	4,043	80	Good
SW_1913	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	73	7	511	90	Excellent
SW_1926	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	554	5	2,770	67	Good
SW_1960	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	555	5	2,777	70	Good
SW_1990	BAY DR	NORMANDY DR	MARSEILLE DR	PCC	316	6	1,897	78	Good
SW_2018	BAY DR	TROUVILLE ESPLANADE	WEST END	PCC	1,217	6	7,301	70	Good
SW_2026	BAY DR	TROUVILLE ESPLANADE	WEST END	PCC	101	5	503	80	Good
SW_2069	BAY DR	RUE GRANVILLE	NORMANDY DR	PCC	116	5	580	70	Good
SW_2086	BAY DR	RUE GRANVILLE	NORMANDY DR	PCC	1,165	4	4,661	78	Good
SW_2192	BAY DR	RUE GRANVILLE	NORMANDY DR	PCC	30	12	359	70	Good
SW_2237	BAY DR	RUE GRANVILLE	NORMANDY DR	PCC	1,028	5	5,139	80	Good
SW_2739	BAY DR	CALAIS DR	NW END	PCC	150	5	752	90	Excellent
SW_3146	BAY DR	MARSEILLE DR	SHORE DR	PCC	89	4	357	-	U.C./N.A.
SW_3148	BAY DR	BREST ESPLANADE	BIARRITZ CT	PCC	102	6	611	50	Fair
SW_0007	BAY RD	18TH ST	20TH ST	PCC	666	8	5,328	77	Good
SW_0015	BAY RD	18TH ST	20TH ST	PCC	678	6	4,067	68	Good
SW_0129	BAY RD	DADE BLVD	18TH ST	PCC	351	10	3,515	70	Good
SW_0134	BAY RD	DADE BLVD	18TH ST	PCC	502	6	3,011	68	Good
SW_0232	BAY RD	LINCOLN RD	NORTH END	PCC	457	5	2,285	80	Good
SW_0239	BAY RD	LINCOLN RD	NORTH END	PCC	345	6	2,072	70	Good
SW_0518	BAY RD	ALTON RD	51ST ST	PCC	916	5	4,581	80	Good
SW_0567	BAY RD	16TH ST	LINCOLN TER	PCC	246	5	1,229	90	Excellent
SW_0649	BAY RD	LINCOLN TER	LINCOLN RD	PCC	261	5	1,306	80	Good
SW_0767	BAY RD	15TH TER	16TH ST	PCC	199	5	994	90	Excellent
SW_0778	BAY RD	15TH TER	16TH ST	PCC	131	9	1,177	90	Excellent
SW_0849	BAY RD	15TH ST	15TH TER	PCC	266	6	1,593	90	Excellent
SW_0860	BAY RD	15TH ST	15TH TER	PCC	356	9	3,207	90	Excellent
SW_0906	BAY RD	FLAMINGO WAY	15TH ST	PCC	271	10	2,714	80	Good
SW_0929	BAY RD	FLAMINGO WAY	15TH ST	PCC	236	5	1,181	90	Excellent
SW_0930	BAY RD	14TH TER	FLAMINGO WAY	PCC	223	12	2,672	80	Good
SW_0944	BAY RD	14TH TER	FLAMINGO WAY	PCC	196	5	979	90	Excellent
SW_1017	BAY RD	14TH ST	14TH TER	PCC	198	7	1,384	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1037	BAY RD	14TH ST	14TH TER	PCC	230	5	1,152	80	Good
SW_2267	BAY RD	63RD ST	PINE TREE DR	PCC	761	5	3,803	90	Excellent
SW_2268	BAY RD	59TH ST	60TH ST	PCC	755	5	3,777	80	Good
SW_2296	BAY RD	60TH ST	63RD ST	PCC	682	5	3,410	80	Good
SW_2352	BAY RD	58TH ST	59TH ST	PCC	745	5	3,724	80	Good
SW_2375	BAY RD	57TH ST	58TH ST	PCC	745	5	3,723	90	Excellent
SW_2390	BAY RD	56TH ST	57TH ST	PCC	633	5	3,163	90	Excellent
SW_2487	BAY RD	54TH ST	56TH ST	PCC	649	5	3,247	90	Excellent
SW_2752	BAY RD	51ST ST	52ND ST	PCC	636	5	3,181	90	Excellent
SW_2793	BAY RD	52ND ST	53RD ST	PCC	652	5	3,258	86	Good
SW_2815	BAY RD	SUNSET DR	MICHIGAN AVE	PCC	430	5	2,149	80	Good
SW_2818	BAY RD	MICHIGAN AVE	21ST ST	PCC	863	5	4,314	90	Excellent
SW_2821	BAY RD	21ST ST	23RD ST	PCC	900	5	4,499	89	Good
SW_2828	BAY RD	53RD ST	54TH ST	PCC	611	5	3,057	80	Good
SW_2830	BAY RD	23RD ST	27TH ST	PCC	901	5	4,504	80	Good
SW_2833	BAY RD	27TH ST	29TH ST	PCC	455	5	2,274	90	Excellent
SW_2838	BAY RD	29TH ST	ALTON RD	PCC	1,707	5	8,534	80	Good
SW_2959	BAY RD	I 195	43RD ST	PCC	628	5	3,142	59	Fair
SW_2962	BAY RD	I 195	43RD ST	PCC	321	5	1,603	60	Good
SW_2993	BAY RD	47TH ST	48TH ST	PCC	1,027	5	5,134	77	Good
SW_2996	BAY RD	45TH ST	47TH ST	PCC	1,398	5	6,989	90	Excellent
SW_3000	BAY RD	SUNSET DR	MICHIGAN AVE	PCC	449	5	2,243	70	Good
SW_3001	BAY RD	44TH ST	45TH ST	PCC	812	5	4,059	90	Excellent
SW_3002	BAY RD	ED SULLIVAN DR	44TH ST	PCC	747	5	3,735	90	Excellent
SW_3003	BAY RD	ALTON RD	ED SULLIVAN DR	PCC	173	5	863	90	Excellent
SW_3004	BAY RD	MICHIGAN AVE	21ST ST	PCC	889	5	4,443	80	Good
SW_3006	BAY RD	21ST ST	23RD ST	PCC	944	5	4,719	86	Good
SW_3010	BAY RD	23RD ST	27TH ST	PCC	933	5	4,666	90	Excellent
SW_3018	BAY RD	27TH ST	29TH ST	PCC	480	5	2,400	70	Good
SW_3024	BAY RD	47TH ST	48TH ST	PCC	1,007	5	5,034	86	Good
SW_3027	BAY RD	45TH ST	47TH ST	PCC	1,265	5	6,323	90	Excellent
SW_3030	BAY RD	44TH ST	45TH ST	PCC	353	5	1,765	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3032	BAY RD	ED SULLIVAN DR	44TH ST	PCC	668	5	3,338	80	Good
SW_3035	BAY RD	29TH ST	ALTON RD	PCC	1,855	5	9,275	78	Good
SW_3103	BAY RD	15TH TER	16TH ST	PCC	117	9	1,054	80	Good
SW_3106	BAY RD	LINCOLN RD	NORTH END	PCC	113	6	680	90	Excellent
SW_3164	BAY RD	44TH ST	45TH ST	PCC	86	5	428	-	U.C./N.A.
SW_3165	BAY RD	44TH ST	45TH ST	PCC	338	5	1,691	90	Excellent
SW_3171	BAY RD	DADE BLVD	18TH ST	PCC	109	6	656	90	Excellent
SW_0595	BAYSIDE LN	SOUTH END	HAWTHORNE AVE	PCC	259	5	1,295	90	Excellent
SW_0600	BAYSIDE LN	SOUTH END	HAWTHORNE AVE	PCC	102	5	510	60	Good
SW_0605	BAYSIDE LN	SOUTH END	HAWTHORNE AVE	PCC	95	5	476	90	Excellent
SW_0142	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	PCC	285	22	6,279	90	Excellent
SW_0149	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	PCC	248	13	3,223	90	Excellent
SW_0159	BEACH SVRD	POINTE DR	SOUTH END	BR	626	24	15,031	90	Excellent
SW_0176	BEACH SVRD	POINTE DR	SOUTH END	BR	783	12	9,391	90	Excellent
SW_0184	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	PCC	375	12	4,506	86	Good
SW_0185	BEACH SVRD	POINTE DR	SOUTH END	BR	320	11	3,519	90	Excellent
SW_0186	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	PCC	385	13	5,009	90	Excellent
SW_0193	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	PCC	1,846	20	36,918	90	Excellent
SW_0250	BEACH SVRD	POINTE DR	1ST ST	PCC	379	16	6,067	90	Excellent
SW_0263	BEACH SVRD	1ST ST	2ND ST	BR	459	17	7,803	90	Excellent
SW_0269	BEACH SVRD	2ND ST	3RD ST	BR	599	19	11,379	90	Excellent
SW_0285	BEACH SVRD	2ND ST	3RD ST	PCC	1,326	14	18,564	70	Good
SW_0097	BEACH WALK	5TH ST	6TH ST	PCC	483	16	7,728	90	Excellent
SW_1157	BEACH WALK	74TH ST	75TH ST	PCC	561	23	12,907	90	Excellent
SW_1304	BEACH WALK	73RD ST	74TH ST	PCC	428	21	8,983	90	Excellent
SW_1597	BEACH WALK	22ND ST	BOARD WALK	BR	319	12	3,826	90	Excellent
SW_1628	BEACH WALK	21ST ST	22ND ST	BR	614	11	6,755	90	Excellent
SW_1831	BEACH WALK	20TH ST	21ST ST	BR	187	37	6,905	90	Excellent
SW_1858	BEACH WALK	20TH ST	21ST ST	PCC	191	16	3,060	90	Excellent
SW_1884	BEACH WALK	BEACH SVRD	BEACH WALK	BR	253	26	6,575	90	Excellent
SW_1893	BEACH WALK	BEACH SVRD	15TH ST	BR	435	15	6,519	90	Excellent
SW_1894	BEACH WALK	BEACH WALK	OCEAN DR	BR	221	17	3,759	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1901	BEACH WALK	18TH ST	20TH ST	PCC	427	17	7,262	90	Excellent
SW_1902	BEACH WALK	14TH ST	BEACH WALK	PCC	470	20	9,410	90	Excellent
SW_1912	BEACH WALK	13TH ST	14TH ST	PCC	491	19	9,326	90	Excellent
SW_1933	BEACH WALK	12TH ST	13TH ST	PCC	216	10	2,160	70	Good
SW_1942	BEACH WALK	12TH ST	13TH ST	PCC	791	16	12,658	80	Good
SW_1959	BEACH WALK	11TH ST	12TH ST	PCC	417	19	7,914	90	Excellent
SW_1975	BEACH WALK	10TH ST	11TH ST	PCC	503	21	10,558	80	Good
SW_1988	BEACH WALK	17TH ST	18TH ST	BR	510	14	7,134	90	Excellent
SW_2017	BEACH WALK	BEACH WALK	10TH ST	BR	166	15	2,494	90	Excellent
SW_2034	BEACH WALK	BEACH WALK	10TH ST	PCC	156	7	1,089	80	Good
SW_2044	BEACH WALK	BEACH WALK	10TH ST	PCC	55	6	332	70	Good
SW_2053	BEACH WALK	BEACH WALK	10TH ST	PCC	110	5	552	80	Good
SW_2059	BEACH WALK	LINCOLN RD	17TH ST	BR	419	16	6,712	90	Excellent
SW_2068	BEACH WALK	BEACH WALK	10TH ST	PCC	620	19	11,782	60	Good
SW_2076	BEACH WALK	BEACH WALK	10TH ST	PCC	124	20	2,474	80	Good
SW_2085	BEACH WALK	8TH ST	BEACH WALK	PCC	505	18	9,091	60	Good
SW_2100	BEACH WALK	7TH ST	8TH ST	PCC	492	18	8,863	70	Good
SW_2122	BEACH WALK	6TH ST	7TH ST	PCC	200	10	1,998	80	Good
SW_2130	BEACH WALK	6TH ST	7TH ST	PCC	609	19	11,579	90	Excellent
SW_2140	BEACH WALK	16TH ST	LINCOLN RD	BR	731	16	11,702	90	Excellent
SW_2182	BEACH WALK	15TH ST	16TH ST	PCC	466	17	7,927	90	Excellent
SW_0542	BIARRITZ DR	71ST ST	NORMANDY DR	PCC	158	9	1,424	80	Good
SW_0697	BIARRITZ DR	71ST ST	NORMANDY DR	PCC	63	6	376	67	Good
SW_0720	BIARRITZ DR	71ST ST	NORMANDY DR	PCC	48	7	337	80	Good
SW_0897	BIARRITZ DR	71ST ST	NORMANDY DR	PCC	302	5	1,511	90	Excellent
SW_0898	BIARRITZ DR	BREST ESPLANADE	VENDOME CT	PCC	496	5	2,482	90	Excellent
SW_0922	BIARRITZ DR	BREST ESPLANADE	VENDOME CT	PCC	394	4	1,577	80	Good
SW_0936	BIARRITZ DR	VENDOME CT	RUE VERSAILLES	PCC	124	4	496	90	Excellent
SW_0960	BIARRITZ DR	EAST END	RUE NOTRE DAME	PCC	767	5	3,837	70	Good
SW_1021	BIARRITZ DR	EAST END	RUE NOTRE DAME	PCC	1,060	5	5,298	58	Fair
SW_1292	BIARRITZ DR	CALAIS DR	SHORE DR	PCC	153	5	763	90	Excellent
SW_1359	BIARRITZ DR	SHORE DR	SHORE LN	PCC	237	5	1,183	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1442	BIARRITZ DR	SHORE LN	SHORE DR	PCC	449	12	5,385	80	Good
SW_1480	BIARRITZ DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	827	4	3,307	70	Good
SW_1559	BIARRITZ DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	787	6	4,720	80	Good
SW_1607	BIARRITZ DR	NORMANDY DR	CALAIS DR	PCC	558	6	3,346	80	Good
SW_1632	BIARRITZ DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	992	5	4,960	70	Good
SW_1641	BIARRITZ DR	NORMANDY DR	CALAIS DR	PCC	563	6	3,376	80	Good
SW_1728	BIARRITZ DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	979	5	4,893	80	Good
SW_2001	BIARRITZ DR	TROUVILLE ESPLANADE	WEST END	PCC	892	5	4,458	80	Good
SW_2055	BIARRITZ DR	TROUVILLE ESPLANADE	WEST END	PCC	1,006	5	5,029	80	Good
SW_2094	BIARRITZ DR	RUE GRANVILLE	71ST ST	PCC	495	14	6,934	90	Excellent
SW_2103	BIARRITZ DR	RUE GRANVILLE	71ST ST	PCC	123	7	864	90	Excellent
SW_2696	BIARRITZ DR	CALAIS DR	SHORE DR	PCC	133	6	796	90	Excellent
SW_2743	BIARRITZ DR	TROUVILLE ESPLANADE	WEST END	PCC	79	6	476	90	Excellent
SW_3155	BIARRITZ DR	CALAIS DR	SHORE DR	PCC	178	6	1,069	90	Excellent
SW_0813	BISCAYNE POINT CIR	DAYTONIA RD	BISCAYNE POINT CIR	PCC	582	5	2,909	90	Excellent
SW_0979	BISCAYNE POINT CIR	DAYTONIA RD	BISCAYNE POINT CIR	PCC	721	5	3,603	80	Good
SW_0577	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	PCC	237	5	1,184	90	Excellent
SW_0578	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	PCC	61	7	428	90	Excellent
SW_0590	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	PCC	158	6	945	90	Excellent
SW_2029	BISCAYNE POINT RD	NOREMAC AVE	FOWLER ST	PCC	280	5	1,402	90	Excellent
SW_2205	BISCAYNE POINT RD	FOWLER ST	DAYTONIA RD	PCC	567	5	2,835	100	Excellent
SW_2275	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	PCC	154	6	927	90	Excellent
SW_2291	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	PCC	60	6	360	90	Excellent
SW_2292	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	PCC	188	5	939	90	Excellent
SW_2383	BISCAYNE POINT RD	NE END	NOREMAC AVE	PCC	141	5	704	90	Excellent
SW_2402	BISCAYNE POINT RD	NE END	NOREMAC AVE	PCC	179	5	893	90	Excellent
SW_2428	BISCAYNE POINT RD	NOREMAC AVE	CECIL ST	PCC	366	5	1,831	90	Excellent
SW_2525	BISCAYNE POINT RD	NOREMAC AVE	CECIL ST	PCC	223	5	1,115	80	Good
SW_2554	BISCAYNE POINT RD	CECIL ST	CLEVELAND RD	PCC	572	5	2,858	90	Excellent
SW_2602	BISCAYNE POINT RD	FOWLER ST	DAYTONIA RD	PCC	1,035	5	5,173	90	Excellent
SW_2607	BISCAYNE POINT RD	CECIL ST	CLEVELAND RD	PCC	993	5	4,967	87	Good
SW_2693	BISCAYNE POINT RD	NOREMAC AVE	FOWLER ST	PCC	367	5	1,835	100	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2734	BISCAYNE POINT RD	HAWTHORNE AVE	WEST END	PCC	61	4	242	80	Good
SW_2748	BISCAYNE POINT RD	HAWTHORNE AVE	WEST END	PCC	25	5	123	100	Excellent
SW_3135	BISCAYNE POINT RD	NOREMAC AVE	CECIL ST	PCC	57	5	286	-	U.C./N.A.
SW_1609	BISCAYNE PT BRIDGE	TATUM WATERWAY DR	CRESPI BLVD	PCC	214	7	1,499	80	Good
SW_1625	BISCAYNE PT BRIDGE	TATUM WATERWAY DR	CRESPI BLVD	PCC	128	5	640	80	Good
SW_3136	BISCAYNE PT BRIDGE	TATUM WATERWAY DR	CRESPI BLVD	PCC	112	5	558	90	Excellent
SW_0886	BOARD WALK	24TH ST	25TH ST	PCC	635	11	6,981	90	Excellent
SW_1306	BOARD WALK	25TH ST	26TH ST	PCC	490	12	5,882	90	Excellent
SW_1562	BOARD WALK	23RD ST	24TH ST	BR	679	12	8,149	90	Excellent
SW_1601	BOARD WALK	26TH ST	27TH ST	PCC	512	11	5,627	90	Excellent
SW_1696	BOARD WALK	39TH ST	40TH ST	PCC	283	13	3,683	90	Excellent
SW_1704	BOARD WALK	40TH ST	41ST ST	PCC	370	10	3,698	90	Excellent
SW_1735	BOARD WALK	42ND ST	43RD ST	PCC	251	12	3,007	90	Excellent
SW_1756	BOARD WALK	41ST ST	42ND ST	PCC	379	10	3,785	90	Excellent
SW_1819	BOARD WALK	43RD ST	44TH ST	PCC	734	12	8,811	90	Excellent
SW_1836	BOARD WALK	44TH ST	46TH ST	PCC	467	11	5,134	90	Excellent
SW_1856	BOARD WALK	44TH ST	46TH ST	PCC	1,878	11	20,653	90	Excellent
SW_2097	BOARD WALK	35TH ST	36TH ST	PCC	311	13	4,048	90	Excellent
SW_2168	BOARD WALK	36TH ST	37TH ST	PCC	278	13	3,612	90	Excellent
SW_2240	BOARD WALK	37TH ST	38TH ST	PCC	307	12	3,688	90	Excellent
SW_2255	BOARD WALK	38TH ST	39TH ST	PCC	243	11	2,668	90	Excellent
SW_2436	BOARD WALK	34TH ST	35TH ST	PCC	243	11	2,675	90	Excellent
SW_2437	BOARD WALK	33RD ST	34TH ST	PCC	302	13	3,931	90	Excellent
SW_2457	BOARD WALK	32ND ST	33RD ST	PCC	263	11	2,896	90	Excellent
SW_2466	BOARD WALK	31ST ST	32ND ST	PCC	312	9	2,809	90	Excellent
SW_2478	BOARD WALK	30TH ST	31ST ST	PCC	314	11	3,456	90	Excellent
SW_2495	BOARD WALK	29TH ST	30TH ST	PCC	407	12	4,884	90	Excellent
SW_2517	BOARD WALK	27TH ST	29TH ST	PCC	496	12	5,950	90	Excellent
SW_0128	BONITA DR	BONITA DR	71ST ST	PCC	69	9	620	90	Excellent
SW_1114	BONITA DR	INDIAN CREEK DR	BONITA DR	PCC	261	3	783	50	Fair
SW_1156	BONITA DR	BONITA DR	71ST ST	PCC	237	5	1,183	70	Good
SW_2524	BONITA DR	INDIAN CREEK DR	BONITA DR	PCC	259	3	777	70	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2540	BONITA DR	INDIAN CREEK DR	BONITA DR	PCC	58	8	465	80	Good
SW_2551	BONITA DR	INDIAN CREEK DR	BONITA DR	PCC	83	6	499	80	Good
SW_2560	BONITA DR	BONITA DR	71ST ST	PCC	218	5	1,088	88	Good
SW_2575	BONITA DR	BONITA DR	71ST ST	PCC	61	6	366	80	Good
SW_2653	BONITA DR	71ST ST	NW END	PCC	226	4	906	80	Good
SW_2666	BONITA DR	71ST ST	NW END	PCC	68	6	408	65	Good
SW_2672	BONITA DR	71ST ST	NW END	PCC	12	5	59	90	Excellent
SW_2673	BONITA DR	71ST ST	NW END	PCC	46	5	230	90	Excellent
SW_0719	BREST ESPLANADE	BAY DR	BIARRITZ DR	PCC	270	5	1,350	80	Good
SW_0729	BREST ESPLANADE	BAY DR	BIARRITZ DR	PCC	210	6	1,260	90	Excellent
SW_0747	BREST ESPLANADE	BAY DR	BIARRITZ DR	PCC	126	4	504	80	Good
SW_0772	BREST ESPLANADE	BAY DR	BIARRITZ DR	PCC	99	4	395	90	Excellent
SW_3046	BRIDGE RD	MAC ARTHUR CSWY	STAR ISLAND DR	PCC	1,020	6	6,120	80	Good
SW_1158	BRUCE ST	WAYNE AVE	GARY AVE	PCC	214	5	1,072	80	Good
SW_1342	BRUCE ST	WAYNE AVE	GARY AVE	PCC	196	5	981	80	Good
SW_0233	BYRON AVE	71ST ST	72ND ST	PCC	157	5	785	-	U.C./N.A.
SW_0557	BYRON AVE	71ST ST	72ND ST	PCC	314	6	1,887	80	Good
SW_0781	BYRON AVE	86TH ST	NORTH END	PCC	544	8	4,354	77	Good
SW_0801	BYRON AVE	86TH ST	NORTH END	PCC	573	6	3,437	70	Good
SW_0810	BYRON AVE	85TH ST	86TH ST	PCC	337	6	2,025	90	Excellent
SW_0821	BYRON AVE	85TH ST	86TH ST	PCC	288	6	1,729	80	Good
SW_0990	BYRON AVE	73RD ST	74TH ST	PCC	354	6	2,121	90	Excellent
SW_0999	BYRON AVE	74TH ST	75TH ST	PCC	356	7	2,489	90	Excellent
SW_1646	BYRON AVE	75TH ST	76TH ST	PCC	147	6	880	90	Excellent
SW_1655	BYRON AVE	76TH ST	77TH ST	PCC	291	7	2,040	90	Excellent
SW_1671	BYRON AVE	77TH ST	78TH ST	PCC	297	6	1,783	90	Excellent
SW_1687	BYRON AVE	78TH ST	79TH ST	PCC	299	6	1,792	90	Excellent
SW_1693	BYRON AVE	79TH ST	80TH ST	PCC	298	6	1,788	100	Excellent
SW_1710	BYRON AVE	80TH ST	81ST ST	PCC	298	6	1,788	100	Excellent
SW_1741	BYRON AVE	80TH ST	81ST ST	PCC	23	6	139	70	Good
SW_1788	BYRON AVE	80TH ST	81ST ST	PCC	276	6	1,653	90	Excellent
SW_1927	BYRON AVE	79TH ST	80TH ST	PCC	301	6	1,806	100	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1935	BYRON AVE	81ST ST	82ND ST	PCC	286	5	1,432	90	Excellent
SW_1952	BYRON AVE	82ND ST	82ND TER	PCC	279	5	1,395	60	Good
SW_1967	BYRON AVE	82ND TER	84TH ST	PCC	489	6	2,934	80	Good
SW_1977	BYRON AVE	78TH ST	79TH ST	PCC	297	5	1,486	100	Excellent
SW_1991	BYRON AVE	84TH ST	85TH ST	PCC	334	6	2,004	90	Excellent
SW_2009	BYRON AVE	84TH ST	85TH ST	PCC	290	5	1,448	90	Excellent
SW_2020	BYRON AVE	82ND TER	84TH ST	PCC	433	6	2,599	79	Good
SW_2036	BYRON AVE	82ND ST	82ND TER	PCC	230	6	1,380	80	Good
SW_2046	BYRON AVE	77TH ST	78TH ST	PCC	295	6	1,770	80	Good
SW_2061	BYRON AVE	81ST ST	82ND ST	PCC	249	6	1,496	80	Good
SW_2143	BYRON AVE	76TH ST	77TH ST	PCC	294	5	1,471	90	Excellent
SW_2186	BYRON AVE	75TH ST	76TH ST	PCC	152	5	760	100	Excellent
SW_2410	BYRON AVE	74TH ST	75TH ST	PCC	362	4	1,447	90	Excellent
SW_2441	BYRON AVE	73RD ST	74TH ST	PCC	353	6	2,118	90	Excellent
SW_2709	BYRON AVE	69TH ST	71ST ST	PCC	605	6	3,632	80	Good
SW_2715	BYRON AVE	INDIAN CREEK DR	69TH ST	PCC	310	6	1,861	80	Good
SW_2746	BYRON AVE	69TH ST	71ST ST	PCC	603	6	3,620	80	Good
SW_3142	BYRON AVE	71ST ST	72ND ST	PCC	80	5	401	90	Excellent
SW_3143	BYRON AVE	71ST ST	72ND ST	PCC	59	6	355	70	Good
SW_0812	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	85	5	424	90	Excellent
SW_1530	CALAIS DR	BIARRITZ DR	BAY DR	PCC	307	5	1,537	80	Good
SW_2008	CALAIS DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	625	6	3,750	90	Excellent
SW_2123	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	673	4	2,690	90	Excellent
SW_2337	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	683	5	3,415	80	Good
SW_2424	CALAIS DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	171	5	854	76	Good
SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	PCC	1,310	4	5,239	66	Good
SW_2714	CALAIS DR	BIARRITZ DR	BAY DR	PCC	305	5	1,525	80	Good
SW_1816	CARLYLE AVE	80TH ST	TATUM WATERWAY DR	PCC	61	7	424	90	Excellent
SW_1870	CARLYLE AVE	79TH ST	80TH ST	PCC	69	5	344	90	Excellent
SW_2176	CARLYLE AVE	75TH ST	76TH ST	PCC	150	6	902	100	Excellent
SW_2202	CARLYLE AVE	76TH ST	77TH ST	PCC	292	6	1,754	90	Excellent
SW_2216	CARLYLE AVE	77TH ST	78TH ST	PCC	298	5	1,488	100	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2218	CARLYLE AVE	79TH ST	80TH ST	PCC	303	6	1,815	90	Excellent
SW_2227	CARLYLE AVE	78TH ST	79TH ST	PCC	302	6	1,811	90	Excellent
SW_2263	CARLYLE AVE	79TH ST	80TH ST	PCC	250	5	1,252	90	Excellent
SW_2272	CARLYLE AVE	78TH ST	79TH ST	PCC	299	5	1,494	90	Excellent
SW_2273	CARLYLE AVE	77TH ST	78TH ST	PCC	47	5	234	90	Excellent
SW_2289	CARLYLE AVE	77TH ST	78TH ST	PCC	10	4	38	100	Excellent
SW_2324	CARLYLE AVE	77TH ST	78TH ST	PCC	239	5	1,196	90	Excellent
SW_2345	CARLYLE AVE	76TH ST	77TH ST	PCC	295	5	1,477	90	Excellent
SW_2370	CARLYLE AVE	75TH ST	76TH ST	PCC	10	4	40	90	Excellent
SW_2379	CARLYLE AVE	75TH ST	76TH ST	PCC	104	5	522	70	Good
SW_2380	CARLYLE AVE	75TH ST	76TH ST	PCC	16	5	82	100	Excellent
SW_2382	CARLYLE AVE	75TH ST	76TH ST	PCC	19	4	77	100	Excellent
SW_2442	CARLYLE AVE	73RD ST	74TH ST	PCC	348	6	2,090	80	Good
SW_2455	CARLYLE AVE	74TH ST	75TH ST	PCC	344	6	2,067	90	Excellent
SW_2463	CARLYLE AVE	73RD ST	74TH ST	PCC	349	5	1,743	90	Excellent
SW_2474	CARLYLE AVE	74TH ST	75TH ST	PCC	351	5	1,755	90	Excellent
SW_2581	CARLYLE AVE	INDIAN CREEK DR	71ST ST	PCC	34	5	171	90	Excellent
SW_2674	CARLYLE AVE	INDIAN CREEK DR	71ST ST	PCC	225	6	1,350	60	Good
SW_2676	CARLYLE AVE	INDIAN CREEK DR	71ST ST	PCC	437	6	2,622	80	Good
SW_2732	CARLYLE AVE	71ST ST	72ND ST	PCC	300	5	1,501	90	Excellent
SW_2741	CARLYLE AVE	71ST ST	72ND ST	PCC	204	6	1,225	-	U.C./N.A.
SW_3144	CARLYLE AVE	71ST ST	72ND ST	PCC	98	7	683	90	Excellent
SW_2445	CECIL ST	CLEVELAND RD	BISCAYNE POINT RD	PCC	305	5	1,525	90	Excellent
SW_2600	CECIL ST	CLEVELAND RD	BISCAYNE POINT RD	PCC	252	5	1,259	90	Excellent
SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	PCC	505	5	2,525	78	Good
SW_1818	CHASE AVE	41ST ST	PRAIRIE AVE	PCC	309	7	2,163	90	Excellent
SW_1844	CHASE AVE	41ST ST	PRAIRIE AVE	PCC	357	6	2,145	90	Excellent
SW_1872	CHASE AVE	41ST ST	PRAIRIE AVE	PCC	31	4	126	90	Excellent
SW_1897	CHASE AVE	44TH ST	PRAIRIE AVE	PCC	244	7	1,706	90	Excellent
SW_2207	CHASE AVE	37TH ST	40TH ST	PCC	580	5	2,898	80	Good
SW_2213	CHASE AVE	40TH CT	41ST ST	BR	191	6	1,147	80	Good
SW_2539	CHASE AVE	34TH ST	ALTON RD	PCC	1,209	6	7,254	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2629	CHASE AVE	34TH ST	CHASE AVE	PCC	394	5	1,968	80	Good
SW_2631	CHASE AVE	37TH ST	40TH ST	PCC	625	5	3,124	80	Good
SW_2650	CHASE AVE	CHASE AVE	37TH ST	PCC	286	5	1,428	80	Good
SW_2700	CHASE AVE	40TH ST	40TH CT	PCC	224	6	1,345	80	Good
SW_2726	CHASE AVE	CHASE AVE	37TH ST	PCC	281	5	1,405	80	Good
SW_2738	CHASE AVE	34TH ST	CHASE AVE	PCC	351	5	1,756	79	Good
SW_3040	CHASE AVE	41ST ST	PRAIRIE AVE	PCC	150	6	899	80	Good
SW_3041	CHASE AVE	41ST ST	PRAIRIE AVE	PCC	464	7	3,248	90	Excellent
SW_3177	CHASE AVE	44TH ST	PRAIRIE AVE	PCC	168	6	1,005	90	Excellent
SW_0063	CHEROKEE AVE	50TH ST	51ST ST	PCC	245	5	1,226	90	Excellent
SW_0112	CHEROKEE AVE	49TH ST	50TH ST	PCC	265	5	1,325	90	Excellent
SW_0117	CHEROKEE AVE	49TH ST	50TH ST	PCC	251	5	1,257	90	Excellent
SW_0151	CHEROKEE AVE	LAKEVIEW DR	49TH ST	PCC	260	5	1,299	90	Excellent
SW_0161	CHEROKEE AVE	LAKEVIEW DR	49TH ST	PCC	261	5	1,305	90	Excellent
SW_1713	CLEVELAND RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	1,783	5	8,915	80	Good
SW_1835	CLEVELAND RD	BISCAYNE POINT RD	HENEDON AVE	PCC	906	5	4,529	90	Excellent
SW_1880	CLEVELAND RD	CECIL ST	BISCAYNE POINT RD	PCC	929	5	4,645	90	Excellent
SW_1906	CLEVELAND RD	NOREMAC AVE	CECIL ST	PCC	264	5	1,322	80	Good
SW_2493	CLEVELAND RD	NOREMAC AVE	CECIL ST	PCC	240	5	1,202	80	Good
SW_2570	CLEVELAND RD	CECIL ST	BISCAYNE POINT RD	PCC	519	5	2,595	90	Excellent
SW_2625	CLEVELAND RD	BISCAYNE POINT RD	HENEDON AVE	PCC	935	5	4,676	90	Excellent
SW_2641	CLEVELAND RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	1,794	5	8,968	90	Excellent
SW_3131	CLEVELAND RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	81	7	568	90	Excellent
SW_3132	CLEVELAND RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	85	8	684	90	Excellent
SW_0003	COLLINS AVE	POINTE DR	1ST ST	PCC	504	6	3,024	70	Good
SW_0013	COLLINS AVE	87TH ST	87TH TER	PCC	217	5	1,087	90	Excellent
SW_0026	COLLINS AVE	86TH ST	87TH ST	PCC	329	11	3,621	90	Excellent
SW_0044	COLLINS AVE	85TH ST	86TH ST	PCC	162	8	1,294	80	Good
SW_0050	COLLINS AVE	85TH ST	86TH ST	PCC	214	7	1,495	90	Excellent
SW_0076	COLLINS AVE	84TH ST	85TH ST	PCC	312	10	3,118	80	Good
SW_0087	COLLINS AVE	84TH ST	85TH ST	PCC	18	4	73	80	Good
SW_0120	COLLINS AVE	83RD ST	84TH ST	PCC	353	9	3,178	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0122	COLLINS AVE	2ND ST	3RD ST	PCC	406	17	6,903	90	Excellent
SW_0123	COLLINS AVE	84TH ST	85TH ST	PCC	293	5	1,465	90	Excellent
SW_0168	COLLINS AVE	83RD ST	84TH ST	PCC	304	6	1,823	70	Good
SW_0170	COLLINS AVE	3RD ST	4TH ST	PCC	417	8	3,335	90	Excellent
SW_0171	COLLINS AVE	82ND ST	83RD ST	PCC	361	9	3,247	90	Excellent
SW_0187	COLLINS AVE	3RD ST	4TH ST	PCC	406	8	3,248	90	Excellent
SW_0244	COLLINS AVE	81ST ST	82ND ST	PCC	357	7	2,501	90	Excellent
SW_0245	COLLINS AVE	4TH ST	5TH ST	PCC	368	10	3,675	90	Excellent
SW_0276	COLLINS AVE	5TH ST	6TH ST	PCC	293	9	2,635	80	Good
SW_0280	COLLINS AVE	POINTE DR	1ST ST	PCC	277	7	1,937	80	Good
SW_0311	COLLINS AVE	1ST ST	2ND ST	PCC	411	5	2,056	80	Good
SW_0312	COLLINS AVE	6TH ST	7TH ST	PCC	492	11	5,407	80	Good
SW_0329	COLLINS AVE	6TH ST	7TH ST	PCC	491	12	5,890	80	Good
SW_0353	COLLINS AVE	1ST ST	2ND ST	PCC	408	8	3,263	90	Excellent
SW_0354	COLLINS AVE	7TH ST	8TH ST	PCC	405	8	3,240	90	Excellent
SW_0360	COLLINS AVE	41ST ST	42ND ST	PCC	199	5	997	90	Excellent
SW_0364	COLLINS AVE	82ND ST	83RD ST	PCC	318	6	1,906	78	Good
SW_0369	COLLINS AVE	2ND ST	3RD ST	PCC	409	7	2,861	80	Good
SW_0376	COLLINS AVE	7TH ST	8TH ST	PCC	413	6	2,477	90	Excellent
SW_0389	COLLINS AVE	80TH ST	81ST ST	PCC	357	16	5,707	80	Good
SW_0391	COLLINS AVE	8TH ST	9TH ST	PCC	423	7	2,963	90	Excellent
SW_0392	COLLINS AVE	81ST ST	82ND ST	PCC	323	5	1,613	70	Good
SW_0408	COLLINS AVE	8TH ST	9TH ST	PCC	415	6	2,488	90	Excellent
SW_0409	COLLINS AVE	79TH ST	80TH ST	PCC	331	16	5,294	90	Excellent
SW_0415	COLLINS AVE	9TH ST	10TH ST	PCC	415	6	2,490	90	Excellent
SW_0422	COLLINS AVE	9TH ST	10TH ST	PCC	408	4	1,632	90	Excellent
SW_0446	COLLINS AVE	80TH ST	81ST ST	PCC	309	5	1,547	70	Good
SW_0453	COLLINS AVE	79TH ST	80TH ST	PCC	28	4	111	90	Excellent
SW_0457	COLLINS AVE	79TH ST	80TH ST	PCC	305	5	1,527	78	Good
SW_0459	COLLINS AVE	78TH ST	79TH ST	PCC	315	11	3,470	80	Good
SW_0461	COLLINS AVE	78TH ST	79TH ST	PCC	303	6	1,818	80	Good
SW_0472	COLLINS AVE	43RD ST	44TH ST	PCC	538	7	3,766	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0477	COLLINS AVE	42ND ST	43RD ST	PCC	203	6	1,219	90	Excellent
SW_0487	COLLINS AVE	77TH ST	78TH ST	PCC	308	5	1,538	80	Good
SW_0501	COLLINS AVE	76TH ST	77TH ST	PCC	303	5	1,515	89	Good
SW_0516	COLLINS AVE	75TH ST	76TH ST	PCC	161	6	965	80	Good
SW_0536	COLLINS AVE	74TH ST	75TH ST	PCC	379	9	3,414	90	Excellent
SW_0561	COLLINS AVE	73RD ST	74TH ST	PCC	363	10	3,631	80	Good
SW_0572	COLLINS AVE	72ND ST	73RD ST	PCC	411	10	4,109	90	Excellent
SW_0594	COLLINS AVE	24TH ST	25TH ST	PCC	81	12	969	100	Excellent
SW_0601	COLLINS AVE	25TH ST	INDIAN CREEK DR	PCC	113	12	1,358	100	Excellent
SW_0623	COLLINS AVE	42ND ST	43RD ST	PCC	206	6	1,233	80	Good
SW_0626	COLLINS AVE	43RD ST	44TH ST	PCC	313	6	1,879	80	Good
SW_0638	COLLINS AVE	41ST ST	42ND ST	PCC	205	6	1,231	90	Excellent
SW_0696	COLLINS AVE	67TH ST	69TH ST	PCC	1,267	9	11,399	80	Good
SW_0699	COLLINS AVE	4TH ST	5TH ST	PCC	307	9	2,764	90	Excellent
SW_0748	COLLINS AVE	76TH ST	77TH ST	PCC	276	5	1,382	63	Good
SW_0773	COLLINS AVE	71ST ST	72ND ST	PCC	315	13	4,092	90	Excellent
SW_0811	COLLINS AVE	69TH ST	71ST ST	PCC	614	10	6,144	80	Good
SW_0875	COLLINS AVE	40TH ST	41ST ST	PCC	203	6	1,220	90	Excellent
SW_0920	COLLINS AVE	85TH ST	86TH ST	PCC	30	5	148	80	Good
SW_0948	COLLINS AVE	85TH ST	86TH ST	PCC	290	6	1,741	80	Good
SW_0949	COLLINS AVE	86TH ST	87TH ST	PCC	309	8	2,468	80	Good
SW_0989	COLLINS AVE	87TH ST	87TH TER	PCC	206	6	1,234	80	Good
SW_1001	COLLINS AVE	39TH ST	40TH ST	PCC	205	5	1,024	70	Good
SW_1052	COLLINS AVE	10TH ST	11TH ST	PCC	409	7	2,866	90	Excellent
SW_1064	COLLINS AVE	11TH ST	12TH ST	PCC	344	6	2,063	90	Excellent
SW_1072	COLLINS AVE	12TH ST	13TH ST	PCC	412	6	2,473	90	Excellent
SW_1077	COLLINS AVE	25TH ST	INDIAN CREEK DR	PCC	260	11	2,864	90	Excellent
SW_1082	COLLINS AVE	13TH ST	14TH ST	PCC	406	6	2,434	90	Excellent
SW_1090	COLLINS AVE	14TH ST	14th PLACE	PCC	499	7	3,493	90	Excellent
SW_1098	COLLINS AVE	10TH ST	11TH ST	PCC	419	5	2,093	90	Excellent
SW_1104	COLLINS AVE	75TH ST	76TH ST	PCC	71	7	499	90	Excellent
SW_1105	COLLINS AVE	26TH ST	27TH ST	PCC	459	5	2,293	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1111	COLLINS AVE	14th PLACE	ESPANOLA WAY	PCC	73	18	1,316	90	Excellent
SW_1115	COLLINS AVE	75TH ST	76TH ST	PCC	98	16	1,568	90	Excellent
SW_1120	COLLINS AVE	11TH ST	12TH ST	PCC	349	6	2,091	90	Excellent
SW_1134	COLLINS AVE	12TH ST	13TH ST	PCC	415	6	2,490	90	Excellent
SW_1141	COLLINS AVE	13TH ST	14TH ST	PCC	419	7	2,934	90	Excellent
SW_1147	COLLINS AVE	38TH ST	39TH ST	PCC	204	5	1,022	80	Good
SW_1152	COLLINS AVE	15TH ST	16TH ST	PCC	528	14	7,394	80	Good
SW_1177	COLLINS AVE	38TH ST	39TH ST	PCC	205	6	1,228	90	Excellent
SW_1182	COLLINS AVE	16TH ST	LINCOLN RD	PCC	490	12	5,886	80	Good
SW_1187	COLLINS AVE	65TH ST	67TH ST	PCC	736	9	6,628	80	Good
SW_1213	COLLINS AVE	LINCOLN RD	17TH ST	PCC	518	16	8,280	90	Excellent
SW_1233	COLLINS AVE	17TH ST	18TH ST	PCC	518	15	7,768	80	Good
SW_1242	COLLINS AVE	15TH ST	16TH ST	PCC	489	13	6,363	80	Good
SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	PCC	525	16	8,393	90	Excellent
SW_1256	COLLINS AVE	63RD ST	64TH ST	PCC	1,375	7	9,624	80	Good
SW_1261	COLLINS AVE	18TH ST	19TH ST	PCC	394	14	5,512	90	Excellent
SW_1270	COLLINS AVE	19TH ST	20TH ST	PCC	170	10	1,703	80	Good
SW_1275	COLLINS AVE	37TH ST	38TH ST	PCC	202	5	1,012	80	Good
SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	PCC	539	13	7,011	80	Good
SW_1290	COLLINS AVE	20TH ST	21ST ST	PCC	254	5	1,270	90	Excellent
SW_1298	COLLINS AVE	21ST ST	22ND ST	PCC	414	11	4,558	90	Excellent
SW_1313	COLLINS AVE	22ND ST	23RD ST	PCC	251	11	2,762	80	Good
SW_1327	COLLINS AVE	17TH ST	18TH ST	PCC	533	11	5,868	79	Good
SW_1335	COLLINS AVE	23RD ST	24TH ST	PCC	277	11	3,047	90	Excellent
SW_1346	COLLINS AVE	23RD ST	24TH ST	PCC	377	13	4,899	60	Good
SW_1356	COLLINS AVE	18TH ST	19TH ST	PCC	410	18	7,383	90	Excellent
SW_1367	COLLINS AVE	19TH ST	20TH ST	PCC	165	15	2,472	90	Excellent
SW_1373	COLLINS AVE	37TH ST	38TH ST	PCC	209	5	1,043	90	Excellent
SW_1412	COLLINS AVE	20TH ST	21ST ST	PCC	265	7	1,852	90	Excellent
SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	1,211	6	7,267	80	Good
SW_1430	COLLINS AVE	36TH ST	37TH ST	PCC	204	5	1,020	80	Good
SW_1450	COLLINS AVE	22ND ST	23RD ST	PCC	281	13	3,659	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1481	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	33	11	365	100	Excellent
SW_1482	COLLINS AVE	36TH ST	37TH ST	PCC	36	5	182	90	Excellent
SW_1485	COLLINS AVE	23RD ST	24TH ST	PCC	51	7	356	60	Good
SW_1507	COLLINS AVE	23RD ST	24TH ST	PCC	625	14	8,752	80	Good
SW_1523	COLLINS AVE	36TH ST	37TH ST	PCC	169	5	846	90	Excellent
SW_1633	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	13	10	132	100	Excellent
SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	9,274	7	64,916	79	Good
SW_1695	COLLINS AVE	73RD ST	74TH ST	PCC	358	15	5,368	80	Good
SW_1702	COLLINS AVE	74TH ST	75TH ST	PCC	399	11	4,389	69	Good
SW_1729	COLLINS AVE	72ND ST	73RD ST	PCC	271	9	2,439	80	Good
SW_1730	COLLINS AVE	35TH ST	36TH ST	PCC	210	5	1,050	90	Excellent
SW_1742	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	17	9	150	90	Excellent
SW_1748	COLLINS AVE	72ND ST	73RD ST	PCC	70	6	417	100	Excellent
SW_1754	COLLINS AVE	72ND ST	73RD ST	PCC	126	10	1,264	80	Good
SW_1764	COLLINS AVE	35TH ST	36TH ST	PCC	207	6	1,245	80	Good
SW_1790	COLLINS AVE	71ST ST	72ND ST	PCC	381	9	3,430	80	Good
SW_1810	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	55	14	766	100	Excellent
SW_1834	COLLINS AVE	34TH ST	35TH ST	PCC	203	5	1,016	90	Excellent
SW_1842	COLLINS AVE	69TH ST	71ST ST	PCC	633	9	5,696	80	Good
SW_1879	COLLINS AVE	34TH ST	35TH ST	PCC	222	7	1,557	70	Good
SW_1920	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	32	12	382	90	Excellent
SW_1969	COLLINS AVE	33RD ST	34TH ST	PCC	139	5	695	90	Excellent
SW_2003	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	1,575	8	12,601	79	Good
SW_2004	COLLINS AVE	33RD ST	34TH ST	PCC	160	6	957	90	Excellent
SW_2021	COLLINS AVE	46TH ST	53RD ST	PCC	14	7	101	90	Excellent
SW_2028	COLLINS AVE	32ND ST	33RD ST	PCC	204	5	1,020	90	Excellent
SW_2038	COLLINS AVE	32ND ST	33RD ST	PCC	210	6	1,259	90	Excellent
SW_2088	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	16	7	112	80	Good
SW_2133	COLLINS AVE	65TH ST	67TH ST	PCC	802	9	7,220	80	Good
SW_2144	COLLINS AVE	64TH ST	65TH ST	PCC	373	7	2,608	80	Good
SW_2145	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	14	7	98	80	Good
SW_2157	COLLINS AVE	ESPANOLA WAY	15TH ST	PCC	218	13	2,834	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2160	COLLINS AVE	63RD ST	64TH ST	PCC	1,062	6	6,370	79	Good
SW_2161	COLLINS AVE	31ST ST	32ND ST	PCC	204	6	1,223	90	Excellent
SW_2167	COLLINS AVE	31ST ST	32ND ST	PCC	201	5	1,006	80	Good
SW_2195	COLLINS AVE	60TH ST	63RD ST	PCC	734	7	5,138	80	Good
SW_2196	COLLINS AVE	INDIAN CREEK DR	60TH ST	PCC	455	9	4,091	90	Excellent
SW_2203	COLLINS AVE	BEACH ACCESS WALK	INDIAN CREEK DR	PCC	146	6	878	90	Excellent
SW_2225	COLLINS AVE	14TH ST	14th PLACE	PCC	489	6	2,937	90	Excellent
SW_2229	COLLINS AVE	30TH ST	31ST ST	PCC	212	5	1,061	90	Excellent
SW_2236	COLLINS AVE	14th PLACE	ESPANOLA WAY	PCC	103	10	1,026	80	Good
SW_2239	COLLINS AVE	30TH ST	31ST ST	PCC	207	6	1,240	80	Good
SW_2241	COLLINS AVE	ESPANOLA WAY	15TH ST	PCC	206	10	2,059	90	Excellent
SW_2281	COLLINS AVE	46TH ST	INDIAN CREEK DR	PCC	10	10	105	90	Excellent
SW_2282	COLLINS AVE	INDIAN CREEK DR	60TH ST	PCC	964	8	7,715	80	Good
SW_2293	COLLINS AVE	29TH ST	30TH ST	PCC	328	9	2,950	87	Good
SW_2300	COLLINS AVE	60TH ST	63RD ST	PCC	35	8	281	50	Fair
SW_2347	COLLINS AVE	46TH ST	INDIAN CREEK DR	PCC	15	7	102	90	Excellent
SW_2348	COLLINS AVE	46TH ST	INDIAN CREEK DR	PCC	10	5	52	90	Excellent
SW_2349	COLLINS AVE	29TH ST	30TH ST	PCC	299	6	1,792	80	Good
SW_2400	COLLINS AVE	46TH ST	53RD ST	PCC	9,022	10	90,219	80	Good
SW_2444	COLLINS AVE	28TH ST	29TH ST	PCC	213	5	1,065	80	Good
SW_2456	COLLINS AVE	28TH ST	29TH ST	PCC	194	6	1,164	80	Good
SW_2484	COLLINS AVE	27TH ST	28TH ST	PCC	225	5	1,123	80	Good
SW_2543	COLLINS AVE	27TH ST	28TH ST	PCC	205	8	1,639	70	Good
SW_2576	COLLINS AVE	39TH ST	40TH ST	PCC	204	5	1,019	90	Excellent
SW_2609	COLLINS AVE	26TH ST	27TH ST	PCC	394	7	2,759	80	Good
SW_2617	COLLINS AVE	26TH ST	27TH ST	PCC	65	6	387	100	Excellent
SW_2645	COLLINS AVE	25TH ST	INDIAN CREEK DR	PCC	377	9	3,390	90	Excellent
SW_2654	COLLINS AVE	40TH ST	41ST ST	PCC	204	5	1,019	90	Excellent
SW_2655	COLLINS AVE	24TH ST	25TH ST	PCC	545	11	6,000	80	Good
SW_2661	COLLINS AVE	24TH ST	25TH ST	PCC	427	10	4,269	80	Good
SW_2710	COLLINS AVE	INDIAN CREEK DR	46TH ST	PCC	236	8	1,888	70	Good
SW_3078	COLLINS AVE	5TH ST	6TH ST	PCC	276	8	2,212	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3112	COLLINS AVE	POINTE DR	1ST ST	BR	200	6	1,202	80	Good
SW_3185	COLLINS AVE	43RD ST	44TH ST	PCC	219	5	1,093	-	U.C./N.A.
SW_3186	COLLINS AVE	46TH ST	53RD ST	PCC	544	7	3,805	100	Excellent
SW_3196	COLLINS AVE	14th PLACE	ESPANOLA WAY	Brick Pavers	145	11	1,590	80	Good
SW_0541	COMMERCE ST	WASHINGTON AVE	ALTON RD	PCC	455	7	3,187	90	Excellent
SW_0603	COMMERCE ST	WASHINGTON AVE	ALTON RD	PCC	505	5	2,524	90	Excellent
SW_1083	CONVENTION CENTER DR	19TH ST	DADE BLVD	PCC	251	10	2,514	90	Excellent
SW_1099	CONVENTION CENTER DR	19TH ST	DADE BLVD	PCC	165	10	1,649	80	Good
SW_1121	CONVENTION CENTER DR	19TH ST	DADE BLVD	PCC	115	10	1,154	90	Excellent
SW_1135	CONVENTION CENTER DR	19TH ST	DADE BLVD	PCC	547	24	13,122	90	Excellent
SW_1153	CONVENTION CENTER DR	18TH ST	19TH ST	PCC	812	22	17,866	90	Excellent
SW_1183	CONVENTION CENTER DR	18TH ST	19TH ST	PCC	519	8	4,151	90	Excellent
SW_2042	CONVENTION CENTER DR	17TH ST	18TH ST	PCC	368	10	3,683	90	Excellent
SW_0155	CRESPI BLVD	85TH ST	86TH ST	PCC	68	5	341	90	Excellent
SW_0210	CRESPI BLVD	85TH ST	86TH ST	PCC	29	5	144	100	Excellent
SW_0359	CRESPI BLVD	85TH ST	86TH ST	PCC	119	5	596	80	Good
SW_1550	CRESPI BLVD	84TH ST	85TH ST	PCC	277	6	1,663	80	Good
SW_1566	CRESPI BLVD	83RD ST	84TH ST	PCC	275	6	1,651	80	Good
SW_1574	CRESPI BLVD	82ND ST	83RD ST	PCC	278	6	1,670	80	Good
SW_1585	CRESPI BLVD	81ST ST	82ND ST	PCC	51	6	308	90	Excellent
SW_1594	CRESPI BLVD	81ST ST	82ND ST	PCC	272	6	1,630	80	Good
SW_1623	CRESPI BLVD	85TH ST	86TH ST	PCC	194	6	1,165	90	Excellent
SW_1635	CRESPI BLVD	80TH ST	81ST ST	PCC	360	6	2,159	80	Good
SW_1672	CRESPI BLVD	79TH TER	80TH ST	PCC	326	6	1,959	70	Good
SW_1703	CRESPI BLVD	79TH ST	79TH TER	PCC	372	6	2,234	80	Good
SW_1744	CRESPI BLVD	HAWTHORNE AVE	79TH ST	PCC	633	6	3,799	80	Good
SW_1755	CRESPI BLVD	HAWTHORNE AVE	79TH ST	PCC	465	6	2,787	90	Excellent
SW_1772	CRESPI BLVD	79TH ST	79TH TER	PCC	282	5	1,412	80	Good
SW_1817	CRESPI BLVD	79TH TER	80TH ST	PCC	263	6	1,579	90	Excellent
SW_1843	CRESPI BLVD	80TH ST	81ST ST	PCC	267	6	1,599	90	Excellent
SW_1928	CRESPI BLVD	84TH ST	85TH ST	PCC	245	6	1,468	90	Excellent
SW_2079	CRESPI BLVD	83RD ST	84TH ST	PCC	215	5	1,076	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2310	CRESPI BLVD	82ND ST	83RD ST	PCC	216	5	1,079	90	Excellent
SW_2483	CRESPI BLVD	81ST ST	82ND ST	PCC	46	6	276	90	Excellent
SW_2491	CRESPI BLVD	81ST ST	82ND ST	PCC	21	6	127	80	Good
SW_2508	CRESPI BLVD	81ST ST	82ND ST	PCC	187	5	934	90	Excellent
SW_0094	DADE BLVD	PURDY AVE	VENETIAN WAY	PCC	467	5	2,335	80	Good
SW_0101	DADE BLVD	BAY RD	PURDY AVE	PCC	263	6	1,579	80	Good
SW_0102	DADE BLVD	ALTON RD	WEST AVE	PCC	330	10	3,296	80	Good
SW_0105	DADE BLVD	WEST AVE	BAY RD	PCC	382	5	1,910	80	Good
SW_0121	DADE BLVD	BAY RD	PURDY AVE	PCC	189	6	1,136	80	Good
SW_0158	DADE BLVD	PURDY AVE	VENETIAN WAY	PCC	214	10	2,143	80	Good
SW_0209	DADE BLVD	ALTON RD	WEST AVE	PCC	103	6	616	80	Good
SW_0593	DADE BLVD	MERIDIAN AVE	MICHIGAN AVE	PCC	737	6	4,420	80	Good
SW_0988	DADE BLVD	MERIDIAN AVE	MICHIGAN AVE	BR	57	8	453	70	Good
SW_1112	DADE BLVD	CONVENTION CENTER DR	MERIDIAN AVE	PCC	203	10	2,034	90	Excellent
SW_1751	DADE BLVD	23RD ST	WASHINGTON AVE	PCC	689	5	3,446	80	Good
SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	PCC	740	6	4,442	78	Good
SW_2612	DADE BLVD	WASHINGTON AVE	CONVENTION CENTER DR	PCC	964	6	5,787	90	Excellent
SW_2687	DADE BLVD	CONVENTION CENTER DR	MERIDIAN AVE	PCC	569	7	3,984	90	Excellent
SW_2759	DADE BLVD	PURDY AVE	VENETIAN WAY	PCC	13	7	89	-	U.C./N.A.
SW_2782	DADE BLVD	MICHIGAN AVE	18TH ST	PCC	724	6	4,343	90	Excellent
SW_2789	DADE BLVD	PURDY AVE	VENETIAN WAY	AC	1,576	7	11,034	70	Good
SW_1938	DAYTONIA RD	NOREMAC AVE	FOWLER ST	PCC	265	5	1,325	100	Excellent
SW_2082	DAYTONIA RD	NOREMAC AVE	FOWLER ST	PCC	235	5	1,176	90	Excellent
SW_2147	DAYTONIA RD	FOWLER ST	DAYTONIA RD	PCC	521	5	2,606	90	Excellent
SW_2294	DAYTONIA RD	FOWLER ST	DAYTONIA RD	PCC	980	5	4,899	86	Good
SW_2403	DAYTONIA RD	BISCAYNE POINT RD	HENEDON AVE	PCC	1,009	5	5,046	90	Excellent
SW_2451	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	1,946	5	9,732	80	Good
SW_2504	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	1,816	5	9,082	90	Excellent
SW_2583	DAYTONIA RD	BISCAYNE POINT RD	HENEDON AVE	PCC	879	5	4,395	90	Excellent
SW_3133	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	62	5	310	90	Excellent
SW_3134	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	PCC	63	5	317	90	Excellent
SW_0014	DELAWARE AVE	50TH ST	51ST ST	PCC	266	5	1,329	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0237	DELAWARE AVE	49TH ST	50TH ST	PCC	272	5	1,362	90	Excellent
SW_0126	DI LIDO DR	7TH DI LIDO TER	8TH DI LIDO TER	PCC	300	5	1,501	80	Good
SW_0587	DI LIDO DR	5TH DI LIDO TER	6TH DI LIDO TER	PCC	306	5	1,530	90	Excellent
SW_2864	DI LIDO DR	VENETIAN DI LIDO WAY	5TH DI LIDO TER	PCC	302	5	1,511	80	Good
SW_2871	DI LIDO DR	6TH DI LIDO TER	7TH DI LIDO TER	PCC	324	5	1,618	90	Excellent
SW_2875	DI LIDO DR	7TH DI LIDO TER	8TH DI LIDO TER	PCC	303	5	1,513	90	Excellent
SW_2882	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	PCC	375	5	1,873	83	Good
SW_2885	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	PCC	371	5	1,856	90	Excellent
SW_2888	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	PCC	291	5	1,454	90	Excellent
SW_2890	DI LIDO DR	6TH DI LIDO TER	7TH DI LIDO TER	PCC	310	5	1,551	90	Excellent
SW_2892	DI LIDO DR	5TH DI LIDO TER	6TH DI LIDO TER	PCC	312	5	1,559	80	Good
SW_2896	DI LIDO DR	VENETIAN DI LIDO WAY	5TH DI LIDO TER	PCC	291	5	1,453	68	Good
SW_2923	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	PCC	291	5	1,453	90	Excellent
SW_2926	DI LIDO DR	3RD DI LIDO TER	4TH DI LIDO TER	PCC	312	5	1,561	70	Good
SW_2929	DI LIDO DR	2ND DI LIDO TER	3RD DI LIDO TER	PCC	297	5	1,483	80	Good
SW_2932	DI LIDO DR	1ST DI LIDO TER	2ND DI LIDO TER	PCC	312	5	1,560	88	Good
SW_2935	DI LIDO DR	DI LIDO DR	1ST DI LIDO TER	PCC	280	5	1,399	70	Good
SW_2936	DI LIDO DR	DI LIDO DR	1ST DI LIDO TER	PCC	275	5	1,373	80	Good
SW_2937	DI LIDO DR	DI LIDO DR	1ST DI LIDO TER	PCC	380	5	1,902	90	Excellent
SW_2938	DI LIDO DR	DI LIDO DR	1ST DI LIDO TER	PCC	369	5	1,845	90	Excellent
SW_2939	DI LIDO DR	1ST DI LIDO TER	2ND DI LIDO TER	PCC	304	5	1,522	80	Good
SW_2940	DI LIDO DR	2ND DI LIDO TER	3RD DI LIDO TER	PCC	303	5	1,514	90	Excellent
SW_2941	DI LIDO DR	3RD DI LIDO TER	4TH DI LIDO TER	PCC	310	5	1,551	80	Good
SW_2942	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	PCC	288	5	1,440	70	Good
SW_3090	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	PCC	47	5	233	90	Excellent
SW_3091	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	PCC	112	5	560	90	Excellent
SW_3092	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	PCC	188	7	1,315	80	Good
SW_1222	DICKENS AVE	71ST ST	72ND ST	PCC	284	6	1,704	80	Good
SW_1247	DICKENS AVE	72ND ST	73RD ST	PCC	10	5	48	90	Excellent
SW_1274	DICKENS AVE	72ND ST	73RD ST	PCC	410	5	2,050	80	Good
SW_1361	DICKENS AVE	73RD ST	74TH ST	PCC	385	6	2,307	80	Good
SW_1428	DICKENS AVE	74TH ST	75TH ST	PCC	378	6	2,270	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1558	DICKENS AVE	75TH ST	76TH ST	PCC	176	5	880	80	Good
SW_1583	DICKENS AVE	76TH ST	77TH ST	PCC	320	6	1,923	80	Good
SW_1615	DICKENS AVE	77TH ST	78TH ST	PCC	299	5	1,493	80	Good
SW_2132	DICKENS AVE	79TH ST	TATUM WATERWAY DR	PCC	61	6	366	80	Good
SW_2175	DICKENS AVE	78TH ST	79TH ST	PCC	12	4	47	80	Good
SW_2228	DICKENS AVE	78TH ST	79TH ST	PCC	279	6	1,676	90	Excellent
SW_2238	DICKENS AVE	78TH ST	79TH ST	PCC	313	5	1,563	80	Good
SW_2243	DICKENS AVE	78TH ST	79TH ST	PCC	9	6	55	90	Excellent
SW_2317	DICKENS AVE	77TH ST	78TH ST	PCC	294	5	1,470	80	Good
SW_2369	DICKENS AVE	76TH ST	77TH ST	PCC	293	6	1,761	80	Good
SW_2394	DICKENS AVE	75TH ST	76TH ST	PCC	144	6	865	90	Excellent
SW_2408	DICKENS AVE	74TH ST	75TH ST	PCC	352	6	2,111	80	Good
SW_2411	DICKENS AVE	73RD ST	74TH ST	PCC	52	5	259	80	Good
SW_2412	DICKENS AVE	73RD ST	74TH ST	PCC	50	6	298	80	Good
SW_2418	DICKENS AVE	73RD ST	74TH ST	PCC	248	6	1,491	80	Good
SW_2482	DICKENS AVE	72ND ST	73RD ST	PCC	370	5	1,850	90	Excellent
SW_2648	DICKENS AVE	71ST ST	72ND ST	PCC	304	5	1,518	80	Good
SW_1784	DREXEL AVE	12TH ST	13TH ST	PCC	421	5	2,104	90	Excellent
SW_1792	DREXEL AVE	12TH ST	13TH ST	PCC	426	5	2,132	80	Good
SW_1802	DREXEL AVE	13TH ST	14TH ST	PCC	413	5	2,063	80	Good
SW_1803	DREXEL AVE	13TH ST	14TH ST	PCC	409	6	2,453	70	Good
SW_1821	DREXEL AVE	SOUTH END	ESPANOLA WAY	BR	84	16	1,345	90	Excellent
SW_1830	DREXEL AVE	SOUTH END	ESPANOLA WAY	BR	75	16	1,195	80	Good
SW_1837	DREXEL AVE	SOUTH END	ESPANOLA WAY	PCC	194	17	3,302	60	Good
SW_1847	DREXEL AVE	SOUTH END	ESPANOLA WAY	PCC	66	13	861	70	Good
SW_1848	DREXEL AVE	ESPANOLA WAY	15TH ST	PCC	99	18	1,782	90	Excellent
SW_1857	DREXEL AVE	ESPANOLA WAY	15TH ST	PCC	113	17	1,923	80	Good
SW_1865	DREXEL AVE	15TH ST	16TH ST	PCC	521	6	3,127	70	Good
SW_1874	DREXEL AVE	15TH ST	16TH ST	PCC	514	5	2,569	66	Good
SW_1882	DREXEL AVE	16TH ST	LINCOLN RD	PCC	461	11	5,073	80	Good
SW_1891	DREXEL AVE	LINCOLN RD	16TH ST	PCC	464	5	2,320	79	Good
SW_1899	DREXEL AVE	LINCOLN RD	LINCOLN LN	PCC	180	7	1,262	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1900	DREXEL AVE	LINCOLN LN	LINCOLN RD	PCC	136	6	818	90	Excellent
SW_3116	DREXEL AVE	ESPANOLA WAY	15TH ST	BR	83	16	1,329	80	Good
SW_3117	DREXEL AVE	ESPANOLA WAY	15TH ST	BR	91	17	1,542	90	Excellent
SW_3208	DREXEL AVE	LINCOLN LN	LINCOLN RD	PCC	334	15	5,003	80	Good
SW_3209	DREXEL AVE	LINCOLN RD	LINCOLN LN	PCC	340	35	11,904	80	Good
SW_3210	DREXEL AVE	LINCOLN RD	LINCOLN LN	PCC	338	34	11,478	80	Good
SW_0727	ESPANOLA WAY	MERIDIAN AVE	JEFFERSON AVE	PCC	319	5	1,593	80	Good
SW_0745	ESPANOLA WAY	MERIDIAN AVE	JEFFERSON AVE	PCC	313	4	1,252	70	Good
SW_1109	ESPANOLA WAY	PENNSYLVANIA AVE	EUCLID AVE	PCC	309	8	2,471	90	Excellent
SW_1119	ESPANOLA WAY	EUCLID AVE	MERIDIAN AVE	PCC	309	4	1,236	80	Good
SW_1131	ESPANOLA WAY	PENNSYLVANIA AVE	EUCLID AVE	PCC	322	8	2,578	90	Excellent
SW_1140	ESPANOLA WAY	EUCLID AVE	MERIDIAN AVE	PCC	317	5	1,585	80	Good
SW_1437	ESPANOLA WAY	DREXEL AVE	PENNSYLVANIA AVE	PCC	361	9	3,252	80	Good
SW_1438	ESPANOLA WAY	WASHINGTON AVE	DREXEL AVE	PCC	348	11	3,825	90	Excellent
SW_1448	ESPANOLA WAY	WASHINGTON AVE	DREXEL AVE	BR	372	13	4,838	70	Good
SW_1456	ESPANOLA WAY	DREXEL AVE	PENNSYLVANIA AVE	PCC	350	11	3,845	78	Good
SW_2129	ESPANOLA WAY	COLLINS CT	WASHINGTON AVE	PCC	165	6	991	80	Good
SW_2148	ESPANOLA WAY	COLLINS AVE	COLLINS CT	PCC	188	6	1,128	80	Good
SW_2172	ESPANOLA WAY	COLLINS AVE	COLLINS CT	PCC	184	7	1,289	80	Good
SW_2199	ESPANOLA WAY	COLLINS CT	WASHINGTON AVE	PCC	149	6	894	80	Good
SW_0548	EUCLID AVE	11TH ST	12TH ST	PCC	320	4	1,279	70	Good
SW_0558	EUCLID AVE	12TH ST	13TH ST	PCC	421	5	2,103	80	Good
SW_0582	EUCLID AVE	13TH ST	14TH ST	PCC	408	5	2,038	70	Good
SW_0647	EUCLID AVE	14TH ST	14TH PL	PCC	260	5	1,302	80	Good
SW_0669	EUCLID AVE	14TH PL	ESPANOLA WAY	PCC	212	4	848	80	Good
SW_0673	EUCLID AVE	ESPANOLA WAY	15TH ST	PCC	194	4	777	70	Good
SW_0684	EUCLID AVE	15TH ST	16TH ST	PCC	506	5	2,530	80	Good
SW_0695	EUCLID AVE	16TH ST	LINCOLN LN	PCC	306	5	1,532	90	Excellent
SW_0704	EUCLID AVE	LINCOLN LN	LINCOLN RD	PCC	176	13	2,282	90	Excellent
SW_0705	EUCLID AVE	LINCOLN LN	LINCOLN RD	PCC	40	7	277	90	Excellent
SW_0856	EUCLID AVE	4TH ST	5TH ST	PCC	228	8	1,827	90	Excellent
SW_0858	EUCLID AVE	11TH ST	12TH ST	PCC	302	10	3,016	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0866	EUCLID AVE	4TH ST	5TH ST	PCC	223	6	1,338	90	Excellent
SW_0888	EUCLID AVE	3RD ST	4TH ST	PCC	362	6	2,171	90	Excellent
SW_0928	EUCLID AVE	12TH ST	13TH ST	PCC	413	5	2,064	90	Excellent
SW_0951	EUCLID AVE	3RD ST	4TH ST	PCC	418	12	5,012	85	Good
SW_1006	EUCLID AVE	13TH ST	14TH ST	PCC	409	5	2,046	80	Good
SW_1036	EUCLID AVE	14TH ST	14TH PL	PCC	269	5	1,347	70	Good
SW_1088	EUCLID AVE	10TH ST	11TH ST	PCC	404	5	2,021	90	Excellent
SW_1095	EUCLID AVE	10TH ST	11TH ST	PCC	415	5	2,074	90	Excellent
SW_1096	EUCLID AVE	14TH PL	ESPANOLA WAY	PCC	211	5	1,055	80	Good
SW_1107	EUCLID AVE	9TH ST	10TH ST	PCC	417	5	2,084	90	Excellent
SW_1108	EUCLID AVE	9TH ST	10TH ST	PCC	409	4	1,634	90	Excellent
SW_1118	EUCLID AVE	8TH ST	9TH ST	PCC	358	5	1,788	90	Excellent
SW_1129	EUCLID AVE	8TH ST	9TH ST	PCC	354	5	1,771	90	Excellent
SW_1130	EUCLID AVE	6TH ST	7TH ST	PCC	409	5	2,044	83	Good
SW_1139	EUCLID AVE	7TH ST	8TH ST	PCC	407	5	2,034	90	Excellent
SW_1149	EUCLID AVE	7TH ST	8TH ST	PCC	408	5	2,042	90	Excellent
SW_1159	EUCLID AVE	6TH ST	7TH ST	PCC	409	5	2,047	80	Good
SW_1168	EUCLID AVE	5TH ST	6TH ST	PCC	408	8	3,262	90	Excellent
SW_1169	EUCLID AVE	ESPANOLA WAY	15TH ST	PCC	190	6	1,137	67	Good
SW_1178	EUCLID AVE	5TH ST	6TH ST	PCC	419	5	2,095	80	Good
SW_1226	EUCLID AVE	15TH ST	16TH ST	PCC	307	6	1,843	78	Good
SW_1288	EUCLID AVE	16TH ST	LINCOLN LN	PCC	324	6	1,942	88	Good
SW_1296	EUCLID AVE	LINCOLN LN	LINCOLN RD	PCC	155	14	2,175	90	Excellent
SW_3118	EUCLID AVE	15TH ST	16TH ST	PCC	196	5	981	-	U.C./N.A.
SW_0842	FAIRWAY DR	SHORE DR	FAIRWAY DR	PCC	284	5	1,419	90	Excellent
SW_1206	FAIRWAY DR	MITCHELL ST	SARAZEN ST	PCC	1,219	5	6,094	80	Good
SW_1264	FAIRWAY DR	VARDON ST	MITCHELL ST	PCC	1,142	5	5,712	90	Excellent
SW_1330	FAIRWAY DR	FAIRWAY DR	VARDON ST	PCC	1,597	5	7,985	90	Excellent
SW_1527	FAIRWAY DR	SARAZEN ST	SHORE DR	PCC	810	5	4,049	90	Excellent
SW_3178	FAIRWAY DR	FAIRWAY DR	FAIRWAY DR	PCC	49	4	198	80	Good
SW_0506	FLAMINGO DR	35TH ST	40TH ST	PCC	1,156	5	5,778	80	Good
SW_1392	FLAMINGO DR	24TH TER	LAKE PANCOAST DR	PCC	363	7	2,541	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1401	FLAMINGO DR	24TH ST	SOUTH END	PCC	116	6	696	80	Good
SW_1421	FLAMINGO DR	24TH ST	SOUTH END	BR	89	8	710	90	Excellent
SW_1427	FLAMINGO DR	24TH ST	SOUTH END	PCC	156	4	622	80	Good
SW_2181	FLAMINGO DR	25TH ST	26TH ST	PCC	545	4	2,179	90	Excellent
SW_2222	FLAMINGO DR	LAKE PANCOAST DR	25TH ST	PCC	100	5	501	80	Good
SW_2248	FLAMINGO DR	24TH ST	24TH TER	PCC	117	5	585	90	Excellent
SW_2366	FLAMINGO DR	24TH TER	LAKE PANCOAST DR	PCC	204	4	815	90	Excellent
SW_2376	FLAMINGO DR	LAKE PANCOAST DR	25TH ST	PCC	79	4	317	80	Good
SW_2572	FLAMINGO DR	25TH ST	26TH ST	PCC	474	4	1,898	80	Good
SW_2643	FLAMINGO DR	35TH ST	40TH ST	PCC	1,511	5	7,554	88	Good
SW_2662	FLAMINGO DR	33RD ST	35TH ST	PCC	525	5	2,623	80	Good
SW_2670	FLAMINGO DR	26TH ST	28TH ST	PCC	385	5	1,926	90	Excellent
SW_2702	FLAMINGO DR	28TH ST	33RD ST	PCC	1,446	5	7,232	90	Excellent
SW_2341	FLAMINGO PL	24TH TER	25TH ST	PCC	264	4	1,057	80	Good
SW_2458	FLAMINGO PL	24TH TER	25TH ST	PCC	270	4	1,078	80	Good
SW_2557	FLAMINGO PL	25TH ST	26TH ST	PCC	501	4	2,002	76	Good
SW_2601	FLAMINGO PL	25TH ST	26TH ST	PCC	477	4	1,908	80	Good
SW_0905	FLAMINGO WAY	WEST AVE	BAY RD	PCC	330	5	1,651	80	Good
SW_0965	FLAMINGO WAY	WEST AVE	BAY RD	PCC	329	5	1,647	59	Fair
SW_0654	FOUNTAIN ST	PALM MIDWAY	PALM AVE	PCC	180	6	1,082	90	Excellent
SW_0655	FOUNTAIN ST	PALM MIDWAY	PALM AVE	PCC	612	5	3,059	90	Excellent
SW_0656	FOUNTAIN ST	PALM MIDWAY	PALM AVE	PCC	328	7	2,294	90	Excellent
SW_0658	FOUNTAIN ST	PALM AVE	MAC ARTHUR CSWY	PCC	305	6	1,828	80	Good
SW_0659	FOUNTAIN ST	PALM AVE	MAC ARTHUR CSWY	PCC	591	5	2,955	80	Good
SW_3195	FOUNTAIN ST	PALM AVE	FOUNTAIN ST	PCC	59	7	412	90	Excellent
SW_3193	FOUNTAIN ST	PALM AVE	MAC ARTHUR CSWY	PCC	35	7	242	90	Excellent
SW_3192	FOUNTAIN ST	PALM AVE	PALM AVE	PCC	42	10	419	90	Excellent
SW_1994	FOWLER ST	BISCAYNE POINT RD	DAYTONIA RD	PCC	314	5	1,568	80	Good
SW_2265	FOWLER ST	BISCAYNE POINT RD	DAYTONIA RD	PCC	254	5	1,270	90	Excellent
SW_0398	GARDEN AVE	39TH ST	40TH ST	PCC	231	5	1,153	80	Good
SW_1596	GARDEN AVE	40TH ST	41ST ST	PCC	162	12	1,946	90	Excellent
SW_2156	GARDEN AVE	BARRY ST	39TH ST	PCC	236	6	1,415	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2652	GARDEN AVE	40TH ST	41ST ST	PCC	130	8	1,041	90	Excellent
SW_2736	GARDEN AVE	BARRY ST	39TH ST	PCC	240	6	1,437	80	Good
SW_2777	GARDEN AVE	MERIDIAN AVE	BARRY ST	PCC	328	5	1,641	70	Good
SW_2778	GARDEN AVE	MERIDIAN AVE	BARRY ST	PCC	347	5	1,734	80	Good
SW_2812	GARDEN AVE	39TH ST	40TH ST	PCC	230	5	1,151	80	Good
SW_1166	GARY AVE	RAYMOND ST	BRUCE ST	PCC	34	5	170	90	Excellent
SW_1179	GARY AVE	MICHAEL ST	BRUCE ST	PCC	23	5	116	80	Good
SW_1198	GARY AVE	MICHAEL ST	BRUCE ST	PCC	36	6	214	60	Good
SW_1224	GARY AVE	MICHAEL ST	BRUCE ST	PCC	109	6	654	90	Excellent
SW_0718	HARDING AVE	67TH ST	69TH ST	PCC	1,244	6	7,465	69	Good
SW_0756	HARDING AVE	86TH ST	85TH ST	PCC	289	5	1,444	80	Good
SW_0865	HARDING AVE	87TH ST	86TH ST	PCC	358	5	1,790	80	Good
SW_0882	HARDING AVE	87TH TER	87TH ST	PCC	233	8	1,864	80	Good
SW_0896	HARDING AVE	NORTH END	87TH TER	PCC	34	10	336	90	Excellent
SW_0934	HARDING AVE	NORTH END	87TH TER	PCC	161	7	1,125	74	Good
SW_0935	HARDING AVE	87TH TER	87TH ST	PCC	180	8	1,440	74	Good
SW_0958	HARDING AVE	NORTH END	87TH TER	PCC	210	6	1,261	70	Good
SW_1020	HARDING AVE	86TH ST	85TH ST	PCC	302	5	1,511	70	Good
SW_1030	HARDING AVE	85TH ST	84TH ST	PCC	21	4	82	90	Excellent
SW_1031	HARDING AVE	85TH ST	84TH ST	PCC	10	5	51	90	Excellent
SW_1032	HARDING AVE	85TH ST	84TH ST	PCC	302	6	1,812	80	Good
SW_1045	HARDING AVE	85TH ST	84TH ST	PCC	100	5	498	80	Good
SW_1055	HARDING AVE	85TH ST	84TH ST	PCC	92	5	458	75	Good
SW_1074	HARDING AVE	85TH ST	84TH ST	PCC	4	5	22	90	Excellent
SW_1075	HARDING AVE	85TH ST	84TH ST	PCC	4	5	22	90	Excellent
SW_1084	HARDING AVE	85TH ST	84TH ST	PCC	64	5	318	80	Good
SW_1100	HARDING AVE	84TH ST	83RD ST	PCC	295	6	1,769	80	Good
SW_1136	HARDING AVE	84TH ST	83RD ST	PCC	298	5	1,490	90	Excellent
SW_1155	HARDING AVE	78TH ST	77TH ST	PCC	296	7	2,073	80	Good
SW_1205	HARDING AVE	83RD ST	82ND ST	PCC	307	6	1,843	80	Good
SW_1255	HARDING AVE	77TH ST	76TH ST	PCC	289	7	2,026	80	Good
SW_1281	HARDING AVE	82ND ST	81ST ST	PCC	289	6	1,732	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1348	HARDING AVE	81ST ST	80TH ST	PCC	294	6	1,764	80	Good
SW_1349	HARDING AVE	76TH ST	75TH ST	PCC	146	6	877	80	Good
SW_1371	HARDING AVE	83RD ST	82ND ST	PCC	107	5	534	80	Good
SW_1395	HARDING AVE	83RD ST	82ND ST	PCC	46	5	231	90	Excellent
SW_1444	HARDING AVE	83RD ST	82ND ST	PCC	181	5	903	90	Excellent
SW_1452	HARDING AVE	80TH ST	79TH ST	PCC	289	6	1,735	80	Good
SW_1453	HARDING AVE	82ND ST	81ST ST	PCC	327	5	1,633	90	Excellent
SW_1463	HARDING AVE	81ST ST	80TH ST	PCC	292	5	1,461	80	Good
SW_1479	HARDING AVE	75TH ST	74TH ST	PCC	364	9	3,279	80	Good
SW_1511	HARDING AVE	80TH ST	79TH ST	PCC	283	6	1,698	80	Good
SW_1519	HARDING AVE	80TH ST	79TH ST	PCC	9	5	44	100	Excellent
SW_1528	HARDING AVE	80TH ST	79TH ST	PCC	10	5	50	100	Excellent
SW_1536	HARDING AVE	79TH ST	78TH ST	PCC	294	6	1,762	70	Good
SW_1546	HARDING AVE	74TH ST	73RD ST	PCC	367	6	2,200	90	Excellent
SW_1582	HARDING AVE	79TH ST	78TH ST	PCC	10	6	58	90	Excellent
SW_1592	HARDING AVE	79TH ST	78TH ST	PCC	5	5	27	90	Excellent
SW_1599	HARDING AVE	79TH ST	78TH ST	PCC	7	5	37	90	Excellent
SW_1605	HARDING AVE	79TH ST	78TH ST	PCC	5	5	23	90	Excellent
SW_1614	HARDING AVE	79TH ST	78TH ST	PCC	266	5	1,332	80	Good
SW_1670	HARDING AVE	78TH ST	77TH ST	PCC	289	5	1,444	80	Good
SW_1740	HARDING AVE	77TH ST	76TH ST	PCC	298	5	1,490	80	Good
SW_1761	HARDING AVE	71ST ST	72ND ST	PCC	301	6	1,806	80	Good
SW_1814	HARDING AVE	76TH ST	75TH ST	PCC	145	6	869	90	Excellent
SW_1861	HARDING AVE	69TH ST	71ST ST	PCC	602	6	3,614	78	Good
SW_1869	HARDING AVE	75TH ST	74TH ST	PCC	358	5	1,792	90	Excellent
SW_1934	HARDING AVE	74TH ST	73RD ST	PCC	359	6	2,153	80	Good
SW_2019	HARDING AVE	73RD ST	72ND ST	PCC	392	5	1,959	80	Good
SW_2242	HARDING AVE	71ST ST	72ND ST	PCC	313	6	1,878	80	Good
SW_2316	HARDING AVE	69TH ST	71ST ST	PCC	605	6	3,630	80	Good
SW_2353	HARDING AVE	67TH ST	69TH ST	PCC	184	5	918	80	Good
SW_2362	HARDING AVE	67TH ST	69TH ST	PCC	10	6	62	80	Good
SW_2368	HARDING AVE	67TH ST	69TH ST	PCC	1,086	6	6,515	77	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0418	HAWTHORNE AVE	80TH ST	BISCAYNE POINT RD	PCC	234	5	1,172	80	Good
SW_0458	HAWTHORNE AVE	79TH TER	80TH ST	PCC	263	5	1,316	80	Good
SW_0479	HAWTHORNE AVE	79TH ST	79TH TER	PCC	282	4	1,129	80	Good
SW_0571	HAWTHORNE AVE	CRESPI BLVD	79TH ST	PCC	358	4	1,430	64	Good
SW_0573	HAWTHORNE AVE	CRESPI BLVD	79TH ST	PCC	113	4	452	80	Good
SW_0576	HAWTHORNE AVE	BAYSIDE LN	CRESPI BLVD	PCC	57	5	286	80	Good
SW_0584	HAWTHORNE AVE	BAYSIDE LN	CRESPI BLVD	PCC	392	5	1,962	64	Good
SW_1196	HAWTHORNE AVE	83RD ST	STILLWATER DR	PCC	186	5	929	90	Excellent
SW_1197	HAWTHORNE AVE	83RD ST	STILLWATER DR	PCC	71	7	497	90	Excellent
SW_1323	HAWTHORNE AVE	85TH ST	86TH ST	PCC	132	5	658	90	Excellent
SW_1369	HAWTHORNE AVE	84TH ST	85TH ST	PCC	283	5	1,413	80	Good
SW_1474	HAWTHORNE AVE	84TH ST	85TH ST	PCC	222	5	1,111	90	Excellent
SW_1512	HAWTHORNE AVE	85TH ST	86TH ST	PCC	151	5	754	90	Excellent
SW_1864	HAWTHORNE AVE	80TH ST	BISCAYNE POINT RD	PCC	227	5	1,134	80	Good
SW_2011	HAWTHORNE AVE	79TH TER	80TH ST	PCC	217	5	1,086	80	Good
SW_2136	HAWTHORNE AVE	79TH ST	79TH TER	PCC	234	5	1,170	80	Good
SW_2151	HAWTHORNE AVE	83RD ST	STILLWATER DR	PCC	218	5	1,090	90	Excellent
SW_2197	HAWTHORNE AVE	CRESPI BLVD	79TH ST	PCC	371	5	1,853	80	Good
SW_2553	HAWTHORNE AVE	BISCAYNE POINT RD	82ND ST	PCC	219	5	1,093	80	Good
SW_2590	HAWTHORNE AVE	82ND ST	83RD ST	PCC	225	5	1,124	80	Good
SW_2615	HAWTHORNE AVE	83RD ST	STILLWATER DR	PCC	71	5	356	90	Excellent
SW_2644	HAWTHORNE AVE	82ND ST	83RD ST	PCC	175	5	873	80	Good
SW_2660	HAWTHORNE AVE	82ND ST	83RD ST	PCC	108	5	542	90	Excellent
SW_2677	HAWTHORNE AVE	BISCAYNE POINT RD	82ND ST	PCC	275	5	1,375	76	Good
SW_1733	HENEDON AVE	DAYTONIA RD	CLEVELAND RD	PCC	130	5	652	90	Excellent
SW_1746	HENEDON AVE	DAYTONIA RD	CLEVELAND RD	PCC	151	4	605	90	Excellent
SW_2967	I 195	41ST ST	BAY RD	PCC	143	10	1,426	80	Good
SW_3014	I 195	I 195 RAMPOF	41ST ST	PCC	44	7	306	90	Excellent
SW_3082	I 195	I 195 RAMPOF	41ST ST	PCC	23	7	160	90	Excellent
SW_0394	INDIAN CREEK DR	67TH ST	65TH ST	PCC	12	7	85	90	Excellent
SW_0395	INDIAN CREEK DR	67TH ST	65TH ST	PCC	12	6	71	90	Excellent
SW_0645	INDIAN CREEK DR	43RD ST	COLLINS AVE	PCC	552	10	5,525	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0774	INDIAN CREEK DR	42ND ST	43RD ST	PCC	204	9	1,835	80	Good
SW_0803	INDIAN CREEK DR	41ST ST	42ND ST	PCC	190	9	1,714	77	Good
SW_0832	INDIAN CREEK DR	41ST ST	40TH ST	PCC	229	10	2,286	90	Excellent
SW_0900	INDIAN CREEK DR	40TH ST	39TH ST	PCC	212	10	2,117	100	Excellent
SW_1022	INDIAN CREEK DR	BONITA DR	71ST ST	PCC	91	7	639	80	Good
SW_1076	INDIAN CREEK DR	BONITA DR	71ST ST	PCC	152	7	1,061	80	Good
SW_1576	INDIAN CREEK DR	27TH ST	26TH ST	PCC	426	5	2,130	90	Excellent
SW_1577	INDIAN CREEK DR	27TH ST	26TH ST	PCC	63	5	316	80	Good
SW_1799	INDIAN CREEK DR	28TH ST	27TH ST	PCC	205	5	1,025	100	Excellent
SW_1827	INDIAN CREEK DR	29TH ST	28TH ST	PCC	211	8	1,685	100	Excellent
SW_1845	INDIAN CREEK DR	31ST ST	30TH ST	PCC	212	6	1,272	100	Excellent
SW_1855	INDIAN CREEK DR	30TH ST	29TH ST	PCC	304	6	1,826	100	Excellent
SW_1873	INDIAN CREEK DR	33RD ST	32ND ST	PCC	211	6	1,268	100	Excellent
SW_1888	INDIAN CREEK DR	32ND ST	31ST ST	PCC	235	6	1,409	90	Excellent
SW_1898	INDIAN CREEK DR	35TH ST	34TH ST	PCC	205	6	1,231	100	Excellent
SW_1907	INDIAN CREEK DR	34TH ST	33RD ST	PCC	94	5	469	100	Excellent
SW_1954	INDIAN CREEK DR	36TH ST	35TH ST	PCC	220	6	1,318	100	Excellent
SW_1963	INDIAN CREEK DR	35TH ST	34TH ST	PCC	47	8	374	100	Excellent
SW_1972	INDIAN CREEK DR	35TH ST	34TH ST	PCC	18	4	72	100	Excellent
SW_1980	INDIAN CREEK DR	37TH ST	36TH ST	PCC	205	5	1,023	100	Excellent
SW_1982	INDIAN CREEK DR	COLLINS AVE	43RD ST	PCC	446	10	4,463	80	Good
SW_2035	INDIAN CREEK DR	65TH ST	67TH ST	PCC	734	7	5,138	80	Good
SW_2112	INDIAN CREEK DR	63RD ST	65TH ST	PCC	891	7	6,234	90	Excellent
SW_2170	INDIAN CREEK DR	29TH ST	28TH ST	PCC	2,242	6	13,449	80	Good
SW_2252	INDIAN CREEK DR	63RD ST	COLLINS AVE	PCC	877	6	5,263	90	Excellent
SW_2330	INDIAN CREEK DR	39TH ST	38TH ST	PCC	208	6	1,248	90	Excellent
SW_2338	INDIAN CREEK DR	38TH ST	37TH ST	PCC	209	6	1,253	100	Excellent
SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	PCC	1,593	7	11,149	80	Good
SW_2365	INDIAN CREEK DR	38TH ST	37TH ST	PCC	42	7	292	100	Excellent
SW_2378	INDIAN CREEK DR	67TH ST	65TH ST	PCC	788	9	7,091	80	Good
SW_2398	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	PCC	70	7	488	90	Excellent
SW_2401	INDIAN CREEK DR	43RD ST	COLLINS AVE	PCC	10	5	49	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2422	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	PCC	329	9	2,963	90	Excellent
SW_2430	INDIAN CREEK DR	67TH ST	ABBOTT AVE	PCC	514	10	5,145	90	Excellent
SW_2440	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	PCC	92	8	738	90	Excellent
SW_2446	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	PCC	20	7	143	90	Excellent
SW_2448	INDIAN CREEK DR	COLLINS AVE	43RD ST	PCC	74	10	742	60	Good
SW_2454	INDIAN CREEK DR	43RD ST	42ND ST	PCC	38	10	377	60	Good
SW_2462	INDIAN CREEK DR	BYRON AVE	INDIAN CREEK DR	PCC	573	7	4,012	80	Good
SW_2464	INDIAN CREEK DR	43RD ST	42ND ST	PCC	210	13	2,729	80	Good
SW_2473	INDIAN CREEK DR	BYRON AVE	69TH ST	PCC	398	8	3,185	70	Good
SW_2475	INDIAN CREEK DR	42ND ST	41ST ST	PCC	166	15	2,492	80	Good
SW_2489	INDIAN CREEK DR	ABBOTT AVE	BYRON AVE	PCC	456	7	3,195	80	Good
SW_2492	INDIAN CREEK DR	42ND ST	41ST ST	PCC	47	7	331	90	Excellent
SW_2500	INDIAN CREEK DR	69TH ST	CARLYLE AVE	PCC	135	8	1,080	90	Excellent
SW_2507	INDIAN CREEK DR	CARLYLE AVE	BONITA DR	PCC	257	8	2,059	80	Good
SW_2514	INDIAN CREEK DR	BYRON AVE	69TH ST	PCC	231	4	925	70	Good
SW_2532	INDIAN CREEK DR	41ST ST	40TH ST	PCC	223	10	2,234	100	Excellent
SW_2541	INDIAN CREEK DR	40TH ST	39TH ST	PCC	303	11	3,332	100	Excellent
SW_2568	INDIAN CREEK DR	69TH ST	CARLYLE AVE	PCC	217	7	1,517	80	Good
SW_2596	INDIAN CREEK DR	CARLYLE AVE	BONITA DR	PCC	43	7	300	80	Good
SW_2597	INDIAN CREEK DR	BONITA DR	71ST ST	PCC	220	6	1,320	80	Good
SW_2604	INDIAN CREEK DR	CARLYLE AVE	BONITA DR	PCC	60	7	420	90	Excellent
SW_2614	INDIAN CREEK DR	BONITA DR	71ST ST	BR	49	6	295	90	Excellent
SW_2706	INDIAN CREEK DR	71ST ST	NW END	PCC	269	8	2,150	80	Good
SW_2707	INDIAN CREEK DR	71ST ST	NW END	PCC	242	8	1,939	90	Excellent
SW_2716	INDIAN CREEK DR	28TH ST	27TH ST	PCC	64	9	573	80	Good
SW_2728	INDIAN CREEK DR	29TH ST	28TH ST	PCC	159	7	1,114	100	Excellent
SW_3080	INDIAN CREEK DR	34TH ST	33RD ST	PCC	111	4	445	100	Excellent
SW_3081	INDIAN CREEK DR	32ND ST	31ST ST	PCC	63	5	316	100	Excellent
SW_0118	ISLAND AVE	HARBOR LN	VENETIAN WAY	PCC	209	4	836	80	Good
SW_0127	ISLAND AVE	VENETIAN WAY	HARBOR LN	PCC	522	5	2,611	90	Excellent
SW_0224	ISLAND AVE	VENETIAN WAY	FARREY LN	PCC	450	7	3,147	90	Excellent
SW_0309	ISLAND AVE	VENETIAN WAY	HARBOR LN	PCC	303	6	1,821	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2969	ISLAND AVE	HARBOR LN	VENETIAN WAY	PCC	290	5	1,452	90	Excellent
SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	PCC	904	6	5,422	80	Good
SW_3176	ISLAND AVE	VENETIAN WAY	FARREY LN	PCC	270	11	2,969	100	Excellent
SW_1957	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	PCC	331	10	3,307	80	Good
SW_1973	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	PCC	103	10	1,029	80	Good
SW_3122	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	PCC	118	8	946	80	Good
SW_3123	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	PCC	131	8	1,047	80	Good
SW_3124	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	PCC	127	7	892	90	Excellent
SW_1368	JAMES AVE	LINCOLN RD	17TH ST	PCC	528	8	4,226	80	Good
SW_1410	JAMES AVE	17TH ST	18TH ST	PCC	506	5	2,532	80	Good
SW_1423	JAMES AVE	18TH ST	19TH ST	PCC	370	5	1,849	80	Good
SW_1859	JAMES AVE	18TH ST	19TH ST	PCC	375	5	1,875	80	Good
SW_1924	JAMES AVE	17TH ST	18TH ST	PCC	503	5	2,516	80	Good
SW_1956	JAMES AVE	LINCOLN RD	17TH ST	PCC	511	9	4,599	80	Good
SW_0040	JEFFERSON AVE	41ST ST	42ND ST	PCC	54	13	699	90	Excellent
SW_0162	JEFFERSON AVE	41ST ST	42ND ST	PCC	257	6	1,541	80	Good
SW_0447	JEFFERSON AVE	POINTE CT	ALTON RD	PCC	243	11	2,678	90	Excellent
SW_0554	JEFFERSON AVE	LINCOLN LN	LINCOLN RD	PCC	162	15	2,425	80	Good
SW_0555	JEFFERSON AVE	LINCOLN RD	LINCOLN LN	PCC	161	14	2,255	80	Good
SW_0565	JEFFERSON AVE	16TH ST	LINCOLN LN	PCC	324	6	1,942	80	Good
SW_0602	JEFFERSON AVE	16TH ST	LINCOLN LN	PCC	327	5	1,637	80	Good
SW_0604	JEFFERSON AVE	15TH ST	16TH ST	PCC	503	5	2,517	70	Good
SW_0614	JEFFERSON AVE	ALTON RD	COMMERCE CT	PCC	267	6	1,604	90	Excellent
SW_0620	JEFFERSON AVE	COMMERCE CT	1ST ST	PCC	168	9	1,510	90	Excellent
SW_0682	JEFFERSON AVE	15TH ST	16TH ST	PCC	505	5	2,523	56	Fair
SW_0690	JEFFERSON AVE	15TH ST	SOUTH END	PCC	104	6	626	90	Excellent
SW_0700	JEFFERSON AVE	15TH ST	SOUTH END	PCC	104	5	520	80	Good
SW_0749	JEFFERSON AVE	2ND ST	3RD ST	PCC	368	5	1,838	80	Good
SW_0881	JEFFERSON AVE	17TH ST	LINCOLN RD	PCC	539	12	6,467	80	Good
SW_0911	JEFFERSON AVE	LINCOLN RD	17TH ST	PCC	538	8	4,303	80	Good
SW_0933	JEFFERSON AVE	18TH ST	19TH ST	PCC	426	5	2,129	80	Good
SW_0946	JEFFERSON AVE	17TH ST	18TH ST	PCC	517	5	2,587	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0970	JEFFERSON AVE	4TH ST	5TH ST	PCC	222	6	1,331	90	Excellent
SW_0976	JEFFERSON AVE	17TH ST	18TH ST	PCC	511	5	2,554	80	Good
SW_0992	JEFFERSON AVE	4TH ST	5TH ST	PCC	210	5	1,049	80	Good
SW_1024	JEFFERSON AVE	3RD ST	4TH ST	PCC	427	9	3,845	90	Excellent
SW_1029	JEFFERSON AVE	18TH ST	19TH ST	PCC	375	5	1,873	80	Good
SW_1034	JEFFERSON AVE	3RD ST	4TH ST	PCC	416	6	2,495	90	Excellent
SW_1445	JEFFERSON AVE	10TH ST	11TH ST	PCC	405	5	2,026	80	Good
SW_1446	JEFFERSON AVE	8TH ST	9TH ST	PCC	362	5	1,808	80	Good
SW_1447	JEFFERSON AVE	8TH ST	9TH ST	PCC	376	4	1,502	76	Good
SW_1457	JEFFERSON AVE	10TH ST	11TH ST	PCC	405	6	2,430	90	Excellent
SW_1458	JEFFERSON AVE	9TH ST	10TH ST	PCC	410	4	1,639	80	Good
SW_1467	JEFFERSON AVE	9TH ST	10TH ST	PCC	404	5	2,019	80	Good
SW_1486	JEFFERSON AVE	7TH ST	8TH ST	PCC	417	5	2,085	76	Good
SW_1487	JEFFERSON AVE	7TH ST	8TH ST	PCC	405	5	2,025	80	Good
SW_1495	JEFFERSON AVE	6TH ST	7TH ST	PCC	411	5	2,056	68	Good
SW_1496	JEFFERSON AVE	6TH ST	7TH ST	PCC	410	5	2,050	80	Good
SW_1497	JEFFERSON AVE	5TH ST	6TH ST	PCC	408	6	2,450	80	Good
SW_1504	JEFFERSON AVE	5TH ST	6TH ST	PCC	422	8	3,377	88	Good
SW_2837	JEFFERSON AVE	41ST ST	42ND ST	PCC	209	5	1,047	80	Good
SW_2971	JEFFERSON AVE	43RD CT	44TH CT	PCC	352	4	1,406	80	Good
SW_2973	JEFFERSON AVE	43RD CT	44TH CT	PCC	840	4	3,360	90	Excellent
SW_2998	JEFFERSON AVE	44TH CT	46TH ST	PCC	1,316	4	5,263	70	Good
SW_2999	JEFFERSON AVE	44TH CT	46TH ST	PCC	1,561	4	6,243	80	Good
SW_3054	JEFFERSON AVE	2ND ST	3RD ST	PCC	73	9	661	80	Good
SW_3200	JEFFERSON AVE	17TH ST	LINCOLN RD	PCC	292	29	8,478	80	Good
SW_3199	JEFFERSON AVE	LINCOLN RD	LINCOLN LN	PCC	317	20	6,335	80	Good
SW_0465	LA GORCE DR	56TH ST	55TH ST	PCC	45	5	223	80	Good
SW_0471	LA GORCE DR	56TH ST	55TH ST	PCC	575	5	2,876	77	Good
SW_2269	LA GORCE DR	ALTON RD	PINE TREE DR	PCC	199	5	994	90	Excellent
SW_2460	LA GORCE DR	55TH ST	54TH ST	PCC	522	5	2,608	90	Excellent
SW_2497	LA GORCE DR	52ND ST	PINE TREE DR	PCC	212	5	1,062	90	Excellent
SW_2505	LA GORCE DR	52ND ST	PINE TREE DR	PCC	109	5	546	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2519	LA GORCE DR	53RD ST	52ND ST	PCC	395	5	1,977	90	Excellent
SW_2522	LA GORCE DR	54TH ST	53RD ST	PCC	511	5	2,553	78	Good
SW_2527	LA GORCE DR	54TH ST	53RD ST	PCC	457	5	2,284	80	Good
SW_2529	LA GORCE DR	63RD ST	62ND ST	PCC	317	5	1,585	80	Good
SW_2544	LA GORCE DR	55TH ST	54TH ST	PCC	453	5	2,264	90	Excellent
SW_2547	LA GORCE DR	62ND ST	61ST ST	PCC	114	6	685	80	Good
SW_2548	LA GORCE DR	53RD ST	52ND ST	PCC	436	5	2,181	80	Good
SW_2558	LA GORCE DR	62ND ST	61ST ST	PCC	216	5	1,078	90	Excellent
SW_2564	LA GORCE DR	56TH ST	55TH ST	PCC	536	5	2,679	79	Good
SW_2569	LA GORCE DR	57TH ST	56TH ST	PCC	513	5	2,564	80	Good
SW_2574	LA GORCE DR	53RD ST	52ND ST	PCC	49	5	243	90	Excellent
SW_2584	LA GORCE DR	59TH ST	58TH ST	PCC	408	5	2,042	90	Excellent
SW_2586	LA GORCE DR	61ST ST	60TH ST	PCC	463	5	2,314	80	Good
SW_2593	LA GORCE DR	58TH ST	57TH ST	PCC	508	5	2,539	90	Excellent
SW_2595	LA GORCE DR	52ND ST	PINE TREE DR	PCC	136	5	681	80	Good
SW_2627	LA GORCE DR	60TH ST	59TH ST	PCC	408	5	2,041	90	Excellent
SW_2630	LA GORCE DR	59TH ST	58TH ST	PCC	450	5	2,250	76	Good
SW_2636	LA GORCE DR	60TH ST	59TH ST	PCC	464	5	2,318	80	Good
SW_2637	LA GORCE DR	PINE TREE DR	51ST ST	PCC	490	5	2,449	90	Excellent
SW_2647	LA GORCE DR	61ST ST	60TH ST	PCC	412	5	2,059	86	Good
SW_2658	LA GORCE DR	62ND ST	61ST ST	PCC	330	5	1,649	74	Good
SW_2675	LA GORCE DR	58TH ST	57TH ST	PCC	534	5	2,669	80	Good
SW_2697	LA GORCE DR	63RD ST	62ND ST	PCC	299	5	1,494	87	Good
SW_2721	LA GORCE DR	57TH ST	56TH ST	PCC	503	5	2,514	88	Good
SW_2722	LA GORCE DR	63RD ST	ALTON RD	PCC	267	5	1,334	90	Excellent
SW_1378	LAKE PANCOAST DR	COLLINS AVE	LAKE PANCOAST DR	PCC	812	5	4,059	80	Good
SW_1385	LAKE PANCOAST DR	FLAMINGO DR	LAKE PANCOAST DR	PCC	387	5	1,935	80	Good
SW_2233	LAKE PANCOAST DR	LAKE PANCOAST DR	FLAMINGO DR	PCC	102	5	509	80	Good
SW_0091	LAKEVIEW DR	50TH ST	51ST ST	PCC	230	5	1,150	90	Excellent
SW_0098	LAKEVIEW DR	49TH ST	50TH ST	PCC	246	4	984	90	Excellent
SW_0139	LAKEVIEW DR	CHEROKEE AVE	DELAWARE AVE	PCC	257	5	1,285	90	Excellent
SW_0145	LAKEVIEW DR	CHEROKEE AVE	DELAWARE AVE	PCC	599	5	2,996	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0172	LAKEVIEW DR	LAKEVIEW CT	49TH ST	PCC	270	5	1,350	80	Good
SW_0188	LAKEVIEW DR	LAKEVIEW CT	CHEROKEE AVE	PCC	385	5	1,926	90	Excellent
SW_0201	LAKEVIEW DR	LAKEVIEW CT	LAKEVIEW CT	PCC	182	4	727	90	Excellent
SW_0217	LAKEVIEW DR	LAKEVIEW CT	CHEROKEE AVE	PCC	408	5	2,041	90	Excellent
SW_0503	LAKEVIEW DR	LAKEVIEW CT	LAKEVIEW CT	PCC	191	5	955	90	Excellent
SW_0507	LAKEVIEW DR	LAKEVIEW CT	49TH ST	PCC	330	5	1,648	90	Excellent
SW_0513	LAKEVIEW DR	49TH ST	50TH ST	PCC	327	5	1,633	90	Excellent
SW_0677	LAKEVIEW DR	50TH ST	51ST ST	PCC	324	4	1,297	78	Good
SW_2259	LAKEVIEW DR	DELAWARE AVE	ALTON RD	PCC	515	4	2,059	80	Good
SW_2566	LAKEVIEW DR	CHEROKEE AVE	DELAWARE AVE	PCC	694	5	3,471	90	Excellent
SW_0005	LENOX AVE	15TH ST	16TH ST	PCC	503	5	2,514	79	Good
SW_0011	LENOX AVE	15TH ST	16TH ST	PCC	508	5	2,542	79	Good
SW_0019	LENOX AVE	14TH ST	15TH ST	PCC	735	4	2,940	60	Good
SW_0031	LENOX AVE	14TH ST	15TH ST	PCC	727	4	2,906	67	Good
SW_0042	LENOX AVE	13TH ST	14TH ST	PCC	408	4	1,631	80	Good
SW_0049	LENOX AVE	13TH ST	14TH ST	PCC	407	4	1,629	78	Good
SW_0055	LENOX AVE	12TH ST	13TH ST	PCC	377	4	1,508	90	Excellent
SW_0060	LENOX AVE	12TH ST	13TH ST	PCC	376	4	1,504	80	Good
SW_0074	LENOX AVE	4TH ST	5TH ST	PCC	217	6	1,303	90	Excellent
SW_0340	LENOX AVE	10TH ST	11TH ST	PCC	394	6	2,362	90	Excellent
SW_0348	LENOX AVE	10TH ST	11TH ST	PCC	431	5	2,155	80	Good
SW_0355	LENOX AVE	9TH ST	10TH ST	PCC	411	5	2,054	80	Good
SW_0361	LENOX AVE	9TH ST	10TH ST	PCC	400	5	1,999	80	Good
SW_0367	LENOX AVE	8TH ST	9TH ST	PCC	345	7	2,416	71	Good
SW_0371	LENOX AVE	8TH ST	9TH ST	PCC	357	10	3,567	80	Good
SW_0375	LENOX AVE	7TH ST	8TH ST	PCC	410	4	1,640	83	Good
SW_0378	LENOX AVE	7TH ST	8TH ST	PCC	400	5	1,998	80	Good
SW_0382	LENOX AVE	6TH ST	7TH ST	PCC	402	6	2,413	90	Excellent
SW_0385	LENOX AVE	6TH ST	7TH ST	PCC	403	6	2,420	89	Good
SW_0390	LENOX AVE	5TH ST	6TH ST	PCC	408	7	2,853	90	Excellent
SW_0401	LENOX AVE	4TH ST	5TH ST	PCC	217	6	1,299	78	Good
SW_0478	LENOX AVE	17TH ST	18TH ST	PCC	536	5	2,679	79	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0494	LENOX AVE	17TH ST	18TH ST	PCC	510	5	2,548	78	Good
SW_0499	LENOX AVE	LINCOLN CT	17TH ST	PCC	281	10	2,810	70	Good
SW_0543	LENOX AVE	LINCOLN CT	17TH ST	PCC	538	7	3,766	80	Good
SW_0544	LENOX AVE	16TH ST	LINCOLN LN	PCC	344	6	2,063	70	Good
SW_0551	LENOX AVE	LINCOLN LN	LINCOLN RD	PCC	185	10	1,849	80	Good
SW_0553	LENOX AVE	16TH ST	LINCOLN LN	PCC	320	6	1,919	80	Good
SW_3119	LENOX AVE	16TH ST	LINCOLN LN	PCC	142	5	710	70	Good
SW_3120	LENOX AVE	LINCOLN CT	17TH ST	PCC	245	7	1,712	80	Good
SW_3197	LENOX AVE	LINCOLN LN	LINCOLN RD	PCC	313	14	4,380	80	Good
SW_3198	LENOX AVE	LINCOLN CT	17TH ST	PCC	326	22	7,169	80	Good
SW_1500	LIBERTY AVE	23RD ST	NORTH END	PCC	372	8	2,977	70	Good
SW_1509	LIBERTY AVE	19TH ST	20TH ST	PCC	313	6	1,876	90	Excellent
SW_1516	LIBERTY AVE	23RD ST	NORTH END	PCC	303	8	2,426	80	Good
SW_1556	LIBERTY AVE	20TH ST	21ST ST	PCC	266	6	1,596	90	Excellent
SW_1603	LIBERTY AVE	22ND ST	23RD ST	PCC	247	14	3,459	90	Excellent
SW_1653	LIBERTY AVE	22ND ST	23RD ST	PCC	261	11	2,873	90	Excellent
SW_1725	LIBERTY AVE	20TH ST	21ST ST	PCC	259	5	1,297	80	Good
SW_1793	LIBERTY AVE	19TH ST	20TH ST	PCC	288	5	1,442	80	Good
SW_3126	LIBERTY AVE	23RD ST	NORTH END	PCC	85	7	595	-	U.C./N.A.
SW_0474	LINCOLN CT	LICOLN RD	NORTH END	PCC	300	5	1,498	80	Good
SW_3097	LINCOLN CT	LICOLN RD	NORTH END	PCC	195	5	975	90	Excellent
SW_3098	LINCOLN CT	LICOLN RD	NORTH END	PCC	287	5	1,437	80	Good
SW_1228	LINCOLN LN	MERIDIAN CT	MERIDIAN AVE	PCC	247	13	3,216	90	Excellent
SW_1234	LINCOLN LN	MERIDIAN CT	MERIDIAN AVE	PCC	112	6	671	60	Good
SW_1243	LINCOLN LN	PENNSYLVANIA AVE	MERIDIAN CT	PCC	347	4	1,387	70	Good
SW_1253	LINCOLN LN	PENNSYLVANIA AVE	MERIDIAN CT	PCC	49	4	195	70	Good
SW_1271	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	PCC	41	6	248	80	Good
SW_1299	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	PCC	339	5	1,693	80	Good
SW_1319	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	PCC	806	25	20,150	90	Excellent
SW_1328	LINCOLN LN	WASHINGTON AVE	DREXEL AVE	PCC	344	10	3,444	70	Good
SW_1336	LINCOLN LN	WASHINGTON AVE	DREXEL AVE	PCC	23	12	279	70	Good
SW_1337	LINCOLN LN	WASHINGTON AVE	DREXEL AVE	PCC	328	14	4,595	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0226	LINCOLN RD	WEST AVE	BAY RD	PCC	334	8	2,674	74	Good
SW_0243	LINCOLN RD	BAY RD	LINCOLN CT	PCC	135	8	1,082	90	Excellent
SW_0283	LINCOLN RD	ALTON RD	ALTON CT	PCC	163	6	978	80	Good
SW_0307	LINCOLN RD	ALTON RD	LENOX AVE	PCC	339	21	7,109	70	Good
SW_0316	LINCOLN RD	ALTON RD	LENOX AVE	PCC	651	6	3,905	70	Good
SW_0317	LINCOLN RD	ALTON CT	WEST AVE	PCC	166	7	1,161	90	Excellent
SW_0326	LINCOLN RD	LENOX AVE	ALTON RD	PCC	350	12	4,200	70	Good
SW_0476	LINCOLN RD	WEST AVE	ALTON CT	PCC	641	8	5,127	75	Good
SW_0481	LINCOLN RD	LINCOLN CT	WEST END	PCC	277	6	1,665	90	Excellent
SW_0484	LINCOLN RD	BAY RD	LINCOLN CT	PCC	243	5	1,214	90	Excellent
SW_0549	LINCOLN RD	WEST AVE	BAY RD	PCC	810	10	8,102	70	Good
SW_1310	LINCOLN RD	WASHINGTON AVE	DREXEL AVE	PCC	175	15	2,619	80	Good
SW_1347	LINCOLN RD	JAMES AVE	WASHINGTON AVE	PCC	330	23	7,587	80	Good
SW_1974	LINCOLN RD	COLLINS AVE	JAMES AVE	PCC	195	15	2,924	90	Excellent
SW_1999	LINCOLN RD	COLLINS AVE	JAMES AVE	PCC	200	15	3,003	80	Good
SW_2006	LINCOLN RD	JAMES AVE	WASHINGTON AVE	PCC	335	14	4,690	80	Good
SW_2067	LINCOLN RD	BEACH WALK	COLLINS AVE	BR	375	29	10,868	90	Excellent
SW_2110	LINCOLN RD	BEACH WALK	COLLINS AVE	PCC	284	12	3,411	80	Good
SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	PCC	437	18	7,873	80	Good
SW_3075	LINCOLN RD	ALTON CT	ALTON RD	PCC	154	14	2,154	80	Good
SW_3099	LINCOLN RD	LINCOLN CT	WEST END	PCC	69	8	553	80	Good
SW_3100	LINCOLN RD	LINCOLN CT	WEST END	PCC	85	8	678	68	Good
SW_3101	LINCOLN RD	BAY RD	LINCOLN CT	PCC	143	9	1,285	70	Good
SW_0683	LINCOLN TER	BAY RD	WEST END	BR	334	4	1,334	80	Good
SW_0691	LINCOLN TER	BAY RD	WEST END	PCC	198	9	1,783	80	Good
SW_3102	LINCOLN TER	BAY RD	WEST END	BR	252	4	1,007	80	Good
SW_0660	MAC ARTHUR CSWY	FOUNTAIN ST	NW END	PCC	162	7	1,131	70	Good
SW_0661	MAC ARTHUR CSWY	FOUNTAIN ST	NW END	PCC	20	6	120	70	Good
SW_0662	MAC ARTHUR CSWY	FOUNTAIN ST	NW END	PCC	169	6	1,015	80	Good
SW_0663	MAC ARTHUR CSWY	NW END	FOUNTAIN ST	PCC	392	8	3,137	80	Good
SW_1312	MAC ARTHUR CSWY	MAC ARTHUR RAMPOF	ALTON RD	PCC	523	7	3,658	-	U.C./N.A.
SW_2705	MAC ARTHUR CSWY	NW END	FOUNTAIN ST	PCC	72	10	719	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3026	MAC ARTHUR CSWY	BRIDGE RD	FOUNTAIN ST	PCC	357	6	2,143	80	Good
SW_3043	MAC ARTHUR CSWY	ALTON RD	FISHER ISLAND FERRY RD	PCC	2,798	7	19,586	80	Good
SW_3044	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	PCC	687	8	5,493	89	Good
SW_3048	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	MAC ARTHUR RAMPOF	PCC	221	7	1,546	80	Good
SW_3058	MAC ARTHUR CSWY	FOUNTAIN ST	BRIDGE RD	PCC	410	7	2,868	80	Good
SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	PCC	788	10	7,882	88	Good
SW_3060	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	MAC ARTHUR RAMPOF	PCC	2,206	8	17,647	90	Excellent
SW_3061	MAC ARTHUR CSWY	MAC ARTHUR RAMPOF	ALTON RD	PCC	660	15	9,905	90	Excellent
SW_3087	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	PCC	50	5	249	90	Excellent
SW_2319	MAIMONIDES ST	VICHY DR	RUE NOTRE DAME	PCC	423	10	4,230	80	Good
SW_2364	MAIMONIDES ST	VICHY DR	RUE NOTRE DAME	PCC	534	8	4,272	80	Good
SW_0568	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	319	6	1,915	80	Good
SW_0731	MARSEILLE DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	659	5	3,293	79	Good
SW_0924	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	79	4	314	80	Good
SW_1116	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	750	6	4,503	80	Good
SW_1787	MARSEILLE DR	BAY DR	RUE VERSAILLES	PCC	387	6	2,322	89	Good
SW_1840	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	PCC	1,184	6	7,105	90	Excellent
SW_1992	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	185	6	1,111	90	Excellent
SW_2045	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	697	5	3,486	80	Good
SW_2074	MARSEILLE DR	BAY DR	RUE VERSAILLES	PCC	597	6	3,580	80	Good
SW_2134	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	173	6	1,035	90	Excellent
SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	PCC	909	5	4,546	67	Good
SW_2187	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	PCC	1,114	5	5,572	90	Excellent
SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	844	5	4,220	79	Good
SW_0267	MERIDIAN AVE	BARRY ST	39TH ST	PCC	246	6	1,477	-	U.C./N.A.
SW_0298	MERIDIAN AVE	BARRY ST	39TH ST	PCC	229	5	1,147	-	U.C./N.A.
SW_0308	MERIDIAN AVE	42ND ST	43RD CT	PCC	392	5	1,960	90	Excellent
SW_0330	MERIDIAN AVE	46TH ST	47TH ST	PCC	244	5	1,218	90	Excellent
SW_0370	MERIDIAN AVE	43RD CT	44TH CT	PCC	590	4	2,362	80	Good
SW_0405	MERIDIAN AVE	40TH ST	41ST ST	PCC	393	6	2,361	80	Good
SW_0414	MERIDIAN AVE	2ND ST	3RD ST	PCC	434	6	2,602	90	Excellent
SW_0420	MERIDIAN AVE	1ST ST	2ND ST	PCC	384	5	1,918	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0423	MERIDIAN AVE	39TH ST	40TH ST	PCC	283	6	1,698	70	Good
SW_0444	MERIDIAN AVE	1ST ST	2ND ST	PCC	396	9	3,564	86	Good
SW_0480	MERIDIAN AVE	39TH ST	40TH ST	PCC	231	4	926	90	Excellent
SW_0724	MERIDIAN AVE	ESPANOLA WAY	15TH ST	PCC	182	5	909	80	Good
SW_0735	MERIDIAN AVE	ESPANOLA WAY	15TH ST	PCC	185	5	927	90	Excellent
SW_0742	MERIDIAN AVE	14TH PL	ESPANOLA WAY	PCC	220	5	1,098	80	Good
SW_0751	MERIDIAN AVE	14TH PL	ESPANOLA WAY	PCC	233	5	1,166	90	Excellent
SW_0754	MERIDIAN AVE	15TH ST	16TH ST	PCC	507	5	2,535	80	Good
SW_0755	MERIDIAN AVE	16TH ST	LINCOLN LN	PCC	323	5	1,613	80	Good
SW_0759	MERIDIAN AVE	14TH ST	14TH PL	PCC	301	6	1,807	80	Good
SW_0762	MERIDIAN AVE	LINCOLN LN	MERIDIAN AVE	PCC	182	16	2,913	80	Good
SW_0764	MERIDIAN AVE	2ND ST	3RD ST	PCC	428	6	2,568	90	Excellent
SW_0766	MERIDIAN AVE	14TH ST	14TH PL	PCC	272	4	1,090	80	Good
SW_0777	MERIDIAN AVE	13TH ST	14TH ST	PCC	413	5	2,065	70	Good
SW_0787	MERIDIAN AVE	13TH ST	14TH ST	PCC	450	5	2,250	80	Good
SW_0790	MERIDIAN AVE	LINCOLN RD	LINCOLN LN	PCC	185	9	1,668	80	Good
SW_0796	MERIDIAN AVE	5TH ST	6TH ST	PCC	435	5	2,175	90	Excellent
SW_0797	MERIDIAN AVE	12TH ST	13TH ST	PCC	411	5	2,054	80	Good
SW_0800	MERIDIAN AVE	16TH ST	LINCOLN LN	PCC	320	5	1,598	80	Good
SW_0806	MERIDIAN AVE	12TH ST	13TH ST	PCC	451	5	2,255	80	Good
SW_0816	MERIDIAN AVE	11TH ST	12TH ST	PCC	354	5	1,768	80	Good
SW_0825	MERIDIAN AVE	11TH ST	12TH ST	PCC	316	5	1,580	80	Good
SW_0834	MERIDIAN AVE	6TH ST	7TH ST	PCC	418	6	2,510	90	Excellent
SW_0852	MERIDIAN AVE	15TH ST	16TH ST	PCC	507	6	3,042	80	Good
SW_0889	MERIDIAN AVE	7TH ST	8TH ST	PCC	413	6	2,478	90	Excellent
SW_0901	MERIDIAN AVE	4TH ST	5TH ST	PCC	227	5	1,135	90	Excellent
SW_0926	MERIDIAN AVE	4TH ST	5TH ST	PCC	236	6	1,416	90	Excellent
SW_0952	MERIDIAN AVE	8TH ST	9TH ST	PCC	383	7	2,679	90	Excellent
SW_0962	MERIDIAN AVE	3RD ST	4TH ST	PCC	418	6	2,510	90	Excellent
SW_0980	MERIDIAN AVE	3RD ST	4TH ST	PCC	416	6	2,498	90	Excellent
SW_0986	MERIDIAN AVE	19TH ST	DADE BLVD	BR	252	10	2,523	70	Good
SW_1004	MERIDIAN AVE	9TH ST	10TH ST	PCC	407	5	2,035	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1019	MERIDIAN AVE	19TH ST	DADE BLVD	PCC	20	8	161	80	Good
SW_1053	MERIDIAN AVE	19TH ST	DADE BLVD	PCC	169	10	1,690	80	Good
SW_1054	MERIDIAN AVE	18TH ST	19TH ST	PCC	374	6	2,243	80	Good
SW_1060	MERIDIAN AVE	10TH ST	11TH ST	PCC	413	5	2,067	85	Good
SW_1062	MERIDIAN AVE	18TH ST	18TH ST	PCC	114	5	572	90	Excellent
SW_1066	MERIDIAN AVE	17TH ST	18TH ST	PCC	394	5	1,970	90	Excellent
SW_1091	MERIDIAN AVE	17TH ST	18TH ST	PCC	364	5	1,818	80	Good
SW_1192	MERIDIAN AVE	18TH ST	18TH ST	PCC	124	5	620	90	Excellent
SW_1204	MERIDIAN AVE	18TH ST	19TH ST	PCC	400	5	2,000	90	Excellent
SW_1210	MERIDIAN AVE	5TH ST	6TH ST	PCC	413	8	3,300	90	Excellent
SW_1287	MERIDIAN AVE	6TH ST	7TH ST	PCC	415	6	2,489	65	Good
SW_1309	MERIDIAN AVE	7TH ST	8TH ST	PCC	416	5	2,081	90	Excellent
SW_1353	MERIDIAN AVE	8TH ST	9TH ST	PCC	369	5	1,844	80	Good
SW_1408	MERIDIAN AVE	9TH ST	10TH ST	PCC	412	5	2,062	79	Good
SW_1419	MERIDIAN AVE	10TH ST	11TH ST	PCC	414	5	2,071	90	Excellent
SW_2024	MERIDIAN AVE	LINCOLN LN	17TH ST	PCC	304	7	2,128	80	Good
SW_2032	MERIDIAN AVE	MERIDIAN AVE	LINCOLN LN	PCC	183	8	1,466	80	Good
SW_2043	MERIDIAN AVE	LINCOLN LN	LINCOLN RD	PCC	201	8	1,611	80	Good
SW_2051	MERIDIAN AVE	LINCOLN LN	17TH ST	PCC	335	8	2,681	80	Good
SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	PCC	1,544	5	7,719	79	Good
SW_2461	MERIDIAN AVE	40TH ST	41ST ST	PCC	324	7	2,265	80	Good
SW_2580	MERIDIAN AVE	23RD ST	28TH ST	PCC	1,278	5	6,389	88	Good
SW_2723	MERIDIAN AVE	DADE BLVD	23RD ST	PCC	28	15	426	80	Good
SW_2760	MERIDIAN AVE	44TH CT	46TH ST	PCC	1,442	4	5,770	70	Good
SW_2762	MERIDIAN AVE	BARRY ST	GARDEN AVE	PCC	511	5	2,557	80	Good
SW_2787	MERIDIAN AVE	41ST ST	42ND ST	PCC	268	6	1,609	80	Good
SW_2795	MERIDIAN AVE	41ST ST	42ND ST	PCC	56	21	1,171	80	Good
SW_2842	MERIDIAN AVE	47TH ST	47TH CT	PCC	339	5	1,696	90	Excellent
SW_2865	MERIDIAN AVE	47TH ST	47TH CT	PCC	339	6	2,031	90	Excellent
SW_3022	MERIDIAN AVE	41ST ST	42ND ST	PCC	175	7	1,223	90	Excellent
SW_3038	MERIDIAN AVE	41ST ST	42ND ST	BR	52	12	624	90	Excellent
SW_3201	MERIDIAN AVE	LINCOLN RD	LINCOLN LN	PCC	311	20	6,229	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3202	MERIDIAN AVE	LINCOLN LN	LINCOLN RD	PCC	293	24	7,021	80	Good
SW_3203	MERIDIAN AVE	LINCOLN LN	MERIDIAN AVE	PCC	329	21	6,901	80	Good
SW_3204	MERIDIAN AVE	MERIDIAN AVE	LINCOLN LN	PCC	328	26	8,531	80	Good
SW_1987	MERIDIAN CT	LINCOLN LN	17TH ST	PCC	242	16	3,879	80	Good
SW_1998	MERIDIAN CT	LINCOLN LN	17TH ST	PCC	288	17	4,889	80	Good
SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	PCC	862	8	6,897	80	Good
SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	PCC	929	8	7,430	80	Good
SW_1659	MIAMI BEACH DR	21ST ST	22ND ST	PCC	872	10	8,722	80	Good
SW_1738	MIAMI BEACH DR	21ST ST	22ND ST	PCC	580	4	2,319	70	Good
SW_1750	MIAMI BEACH DR	21ST ST	22ND ST	PCC	581	4	2,322	80	Good
SW_1257	MICHAEL ST	WAYNE AVE	GARY AVE	PCC	159	5	796	80	Good
SW_0004	MICHIGAN AVE	3RD ST	4TH ST	PCC	423	6	2,540	80	Good
SW_0010	MICHIGAN AVE	2ND ST	3RD ST	PCC	441	5	2,207	80	Good
SW_0035	MICHIGAN AVE	LINCOLN RD	17TH ST	PCC	531	12	6,373	80	Good
SW_0069	MICHIGAN AVE	4TH ST	5TH ST	PCC	111	10	1,107	-	U.C./N.A.
SW_0075	MICHIGAN AVE	12TH ST	13TH ST	PCC	414	5	2,072	90	Excellent
SW_0108	MICHIGAN AVE	5TH ST	6TH ST	PCC	410	5	2,048	80	Good
SW_0133	MICHIGAN AVE	13TH ST	14TH ST	PCC	429	5	2,147	78	Good
SW_0152	MICHIGAN AVE	6TH ST	7TH ST	PCC	409	4	1,636	75	Good
SW_0189	MICHIGAN AVE	7TH ST	8TH ST	PCC	405	5	2,025	80	Good
SW_0190	MICHIGAN AVE	14TH ST	MICHIGAN CT	PCC	737	5	3,685	80	Good
SW_0218	MICHIGAN AVE	19TH ST	ALTON RD	PCC	58	14	815	90	Excellent
SW_0248	MICHIGAN AVE	8TH ST	9TH ST	PCC	365	5	1,826	70	Good
SW_0249	MICHIGAN AVE	15TH ST	16TH ST	PCC	503	5	2,513	80	Good
SW_0278	MICHIGAN AVE	9TH ST	10TH ST	PCC	421	4	1,684	80	Good
SW_0289	MICHIGAN AVE	16TH ST	LINCOLN LN	PCC	321	6	1,927	90	Excellent
SW_0301	MICHIGAN AVE	LINCOLN RD	LINCOLN LN	PCC	186	15	2,796	90	Excellent
SW_0315	MICHIGAN AVE	10TH ST	11TH ST	PCC	413	5	2,067	72	Good
SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	PCC	534	7	3,737	90	Excellent
SW_0393	MICHIGAN AVE	17TH ST	18TH ST	PCC	511	5	2,557	79	Good
SW_0489	MICHIGAN AVE	18TH ST	NORTH END	PCC	228	4	911	80	Good
SW_0492	MICHIGAN AVE	18TH ST	NORTH END	PCC	227	5	1,135	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0685	MICHIGAN AVE	19TH ST	ALTON RD	PCC	225	4	899	90	Excellent
SW_0722	MICHIGAN AVE	2ND ST	3RD ST	PCC	440	6	2,638	89	Good
SW_0769	MICHIGAN AVE	14TH ST	MICHIGAN CT	PCC	805	7	5,634	80	Good
SW_0770	MICHIGAN AVE	12TH ST	13TH ST	PCC	642	7	4,497	-	U.C./N.A.
SW_0776	MICHIGAN AVE	3RD ST	4TH ST	PCC	422	5	2,109	88	Good
SW_0791	MICHIGAN AVE	15TH ST	16TH ST	PCC	498	5	2,492	78	Good
SW_0864	MICHIGAN AVE	16TH ST	LINCOLN LN	PCC	324	5	1,622	80	Good
SW_0871	MICHIGAN AVE	LINCOLN LN	LINCOLN RD	PCC	183	16	2,931	90	Excellent
SW_0895	MICHIGAN AVE	17TH ST	18TH ST	PCC	520	5	2,601	79	Good
SW_1216	MICHIGAN AVE	5TH ST	6TH ST	PCC	403	8	3,223	79	Good
SW_1249	MICHIGAN AVE	6TH ST	7TH ST	PCC	409	5	2,043	70	Good
SW_1294	MICHIGAN AVE	7TH ST	8TH ST	PCC	407	5	2,036	80	Good
SW_1324	MICHIGAN AVE	8TH ST	9TH ST	PCC	356	5	1,778	80	Good
SW_1382	MICHIGAN AVE	9TH ST	10TH ST	PCC	417	5	2,084	70	Good
SW_1409	MICHIGAN AVE	10TH ST	11TH ST	PCC	422	5	2,109	86	Good
SW_2768	MICHIGAN AVE	19TH ST	ALTON RD	PCC	305	4	1,220	90	Excellent
SW_2780	MICHIGAN AVE	19TH ST	ALTON RD	PCC	275	8	2,200	43	Fair
SW_2816	MICHIGAN AVE	ALTON RD	BAY RD	PCC	228	5	1,141	80	Good
SW_2817	MICHIGAN AVE	ALTON RD	BAY RD	PCC	241	5	1,205	80	Good
SW_2873	MICHIGAN AVE	47TH ST	47TH CT	PCC	263	5	1,316	90	Excellent
SW_2876	MICHIGAN AVE	42ND ST	43RD ST	PCC	395	4	1,579	80	Good
SW_2878	MICHIGAN AVE	47TH ST	47TH CT	PCC	237	5	1,187	90	Excellent
SW_2898	MICHIGAN AVE	46TH ST	47TH ST	PCC	239	5	1,194	90	Excellent
SW_2901	MICHIGAN AVE	46TH ST	47TH ST	PCC	244	5	1,220	80	Good
SW_2914	MICHIGAN AVE	44TH CT	46TH ST	PCC	1,248	4	4,992	90	Excellent
SW_2915	MICHIGAN AVE	43RD CT	44TH CT	PCC	349	4	1,398	80	Good
SW_2917	MICHIGAN AVE	42ND ST	43RD ST	PCC	541	5	2,707	90	Excellent
SW_3028	MICHIGAN AVE	44TH CT	46TH ST	PCC	1,230	4	4,919	90	Excellent
SW_3033	MICHIGAN AVE	43RD CT	44TH CT	PCC	367	4	1,466	90	Excellent
SW_3034	MICHIGAN AVE	43RD ST	43RD CT	PCC	538	4	2,150	68	Good
SW_3069	MICHIGAN AVE	4TH ST	5TH ST	PCC	208	5	1,039	-	U.C./N.A.
SW_3115	MICHIGAN AVE	12TH ST	13TH ST	PCC	254	7	1,775	86	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3128	MICHIGAN AVE	4TH ST	5TH ST	PCC	91	10	913	70	Good
SW_3170	MICHIGAN AVE	19TH ST	ALTON RD	PCC	322	6	1,935	70	Good
SW_0314	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	PCC	115	5	574	80	Good
SW_0535	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	PCC	66	5	329	90	Excellent
SW_0625	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	PCC	96	7	670	90	Excellent
SW_0650	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	PCC	165	7	1,152	90	Excellent
SW_0672	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	PCC	58	5	292	90	Excellent
SW_2905	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	PCC	236	5	1,179	90	Excellent
SW_2906	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	PCC	235	5	1,175	90	Excellent
SW_2909	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	PCC	180	7	1,257	80	Good
SW_2912	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	PCC	280	7	1,960	80	Good
SW_3085	MOUNT SINAI HOSPITAL PR	MOUNT SINAI HOSPITAL PR	ED SULLIVAN DR	PCC	183	6	1,100	90	Excellent
SW_3086	MOUNT SINAI HOSPITAL PR	MOUNT SINAI HOSPITAL PR	ED SULLIVAN DR	PCC	146	6	878	80	Good
SW_3023	NAUTILUS CT	NAUTILUS DR	46TH ST	PCC	506	4	2,026	90	Excellent
SW_3025	NAUTILUS CT	NAUTILUS DR	46TH ST	PCC	808	4	3,233	90	Excellent
SW_2790	NAUTILUS DR	ALTON RD	42ND ST	PCC	242	4	967	80	Good
SW_2797	NAUTILUS DR	ALTON RD	42ND ST	PCC	274	6	1,642	80	Good
SW_2836	NAUTILUS DR	42ND ST	43RD ST	PCC	29	4	116	90	Excellent
SW_2877	NAUTILUS DR	42ND ST	43RD ST	PCC	519	4	2,077	90	Excellent
SW_2881	NAUTILUS DR	43RD ST	44TH CT	PCC	1,012	4	4,046	90	Excellent
SW_2883	NAUTILUS DR	43RD ST	44TH CT	PCC	1,061	4	4,242	90	Excellent
SW_2887	NAUTILUS DR	42ND ST	43RD ST	PCC	672	4	2,686	80	Good
SW_3008	NAUTILUS DR	44TH CT	NAUTILUS CT	PCC	649	4	2,596	90	Excellent
SW_3011	NAUTILUS DR	NAUTILUS CT	46TH ST	PCC	608	4	2,434	80	Good
SW_3017	NAUTILUS DR	NAUTILUS CT	46TH ST	PCC	447	4	1,786	90	Excellent
SW_3020	NAUTILUS DR	NAUTILUS CT	46TH ST	PCC	19	4	76	80	Good
SW_1922	NOREMAC AVE	DAYTONIA RD	CLEVELAND RD	PCC	359	6	2,155	80	Good
SW_2039	NOREMAC AVE	BISCAYNE POINT RD	DAYTONIA RD	PCC	463	5	2,315	90	Excellent
SW_2321	NOREMAC AVE	CLEVELAND RD	BISCAYNE POINT RD	PCC	584	5	2,919	90	Excellent
SW_2329	NOREMAC AVE	BISCAYNE POINT RD	DAYTONIA RD	PCC	557	5	2,785	100	Excellent
SW_2356	NOREMAC AVE	DAYTONIA RD	CLEVELAND RD	PCC	410	7	2,871	90	Excellent
SW_2494	NOREMAC AVE	CLEVELAND RD	BISCAYNE POINT RD	PCC	462	5	2,309	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0495	NORMANDY DR	79TH CSWY	71ST ST	PCC	18	4	72	90	Excellent
SW_0560	NORMANDY DR	BIARRITZ DR	BIARRITZ DR	PCC	144	9	1,299	80	Good
SW_0585	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	777	6	4,662	70	Good
SW_0591	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	191	8	1,528	80	Good
SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	PCC	761	6	4,563	68	Good
SW_0730	NORMANDY DR	GRANVILLE CT	VERDUN DR	PCC	241	4	964	80	Good
SW_0854	NORMANDY DR	VERDUN DR	BIARRITZ DR	PCC	305	5	1,525	90	Excellent
SW_0884	NORMANDY DR	GRANVILLE CT	VERDUN DR	PCC	254	5	1,268	78	Good
SW_0923	NORMANDY DR	RUE GRANVILLE	GRANVILLE CT	PCC	263	5	1,317	80	Good
SW_1165	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	768	5	3,841	79	Good
SW_1223	NORMANDY DR	BIARRITZ DR	BIARRITZ DR	PCC	297	5	1,484	70	Good
SW_1246	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	1,112	5	5,560	79	Good
SW_1331	NORMANDY DR	VICHY DR	RUE NOTRE DAME	PCC	556	15	8,340	78	Good
SW_1396	NORMANDY DR	VERSAILLES CT	VICHY DR	PCC	525	11	5,776	80	Good
SW_1522	NORMANDY DR	RUE VENDOME	VERSAILLES CT	PCC	141	14	1,972	80	Good
SW_1572	NORMANDY DR	RUE VENDOME	VERSAILLES CT	PCC	153	14	2,135	80	Good
SW_1624	NORMANDY DR	71ST ST	RUE VENDOME	PCC	380	13	4,936	80	Good
SW_1951	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	1,157	5	5,784	90	Excellent
SW_2047	NORMANDY DR	VICHY DR	RUE NOTRE DAME	PCC	618	10	6,183	40	Fair
SW_2063	NORMANDY DR	VERSAILLES CT	VICHY DR	PCC	444	10	4,437	34	Poor
SW_2283	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	1,027	5	5,133	80	Good
SW_2309	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	PCC	245	6	1,468	66	Good
SW_2552	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	664	6	3,982	70	Good
SW_2599	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	PCC	251	5	1,253	90	Excellent
SW_0017	OCEAN DR	2ND ST	3RD ST	PCC	406	9	3,656	90	Excellent
SW_0081	OCEAN DR	4TH ST	5TH ST	PCC	743	8	5,944	90	Excellent
SW_0116	OCEAN DR	5TH ST	6TH ST	PCC	363	11	3,995	90	Excellent
SW_0160	OCEAN DR	5TH ST	6TH ST	PCC	311	16	4,968	80	Good
SW_0179	OCEAN DR	4TH ST	5TH ST	PCC	408	6	2,449	80	Good
SW_0220	OCEAN DR	3RD ST	4TH ST	PCC	306	9	2,755	80	Good
SW_0304	OCEAN DR	1ST ST	2ND ST	PCC	448	11	4,925	80	Good
SW_0310	OCEAN DR	1ST ST	POINTE DR	BR	406	11	4,466	70	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0328	OCEAN DR	1ST ST	2ND ST	PCC	410	10	4,103	70	Good
SW_0337	OCEAN DR	2ND ST	3RD ST	PCC	454	11	4,999	90	Excellent
SW_0362	OCEAN DR	3RD ST	4TH ST	PCC	427	10	4,268	90	Excellent
SW_0739	OCEAN DR	13TH ST	14TH ST	PCC	442	14	6,192	80	Good
SW_0839	OCEAN DR	12TH ST	13TH ST	PCC	438	15	6,574	80	Good
SW_0909	OCEAN DR	11TH ST	12TH ST	PCC	368	15	5,527	80	Good
SW_0984	OCEAN DR	10TH ST	11TH ST	PCC	440	11	4,840	80	Good
SW_1018	OCEAN DR	9TH ST	10TH ST	PCC	405	16	6,477	80	Good
SW_1028	OCEAN DR	8TH ST	9TH ST	PCC	405	15	6,074	80	Good
SW_1043	OCEAN DR	7TH ST	8TH ST	PCC	414	14	5,800	80	Good
SW_1065	OCEAN DR	6TH ST	7TH ST	PCC	409	15	6,137	80	Good
SW_1191	OCEAN DR	14TH ST	14th PLACE	PCC	535	16	8,559	80	Good
SW_1219	OCEAN DR	14th PLACE	15TH ST	PCC	322	11	3,545	80	Good
SW_1760	OCEAN DR	6TH ST	7TH ST	PCC	430	11	4,734	80	Good
SW_1767	OCEAN DR	7TH ST	8TH ST	PCC	457	11	5,031	90	Excellent
SW_1776	OCEAN DR	8TH ST	9TH ST	PCC	454	13	5,903	80	Good
SW_1786	OCEAN DR	9TH ST	10TH ST	PCC	524	9	4,719	80	Good
SW_1794	OCEAN DR	10TH ST	11TH ST	PCC	386	10	3,856	80	Good
SW_1805	OCEAN DR	11TH ST	12TH ST	PCC	410	11	4,505	90	Excellent
SW_1813	OCEAN DR	12TH ST	13TH ST	PCC	459	11	5,046	80	Good
SW_1823	OCEAN DR	13TH ST	14TH ST	PCC	435	11	4,784	80	Good
SW_1860	OCEAN DR	14TH ST	14th PLACE	PCC	612	10	6,119	90	Excellent
SW_1868	OCEAN DR	14th PLACE	15TH ST	PCC	303	8	2,422	90	Excellent
SW_3113	OCEAN DR	3RD ST	4TH ST	PCC	99	9	891	100	Excellent
SW_1565	OCEAN TER	73RD ST	74TH ST	PCC	361	28	10,121	90	Excellent
SW_1634	OCEAN TER	74TH ST	75TH ST	PCC	393	24	9,424	70	Good
SW_3194	PALM AVE	FOUNTAIN ST	FOUNTAIN ST	PCC	16	10	157	90	Excellent
SW_1598	PARK AVE	20TH ST	21ST ST	PCC	265	5	1,325	70	Good
SW_1613	PARK AVE	19TH ST	20TH ST	PCC	413	5	2,064	80	Good
SW_1620	PARK AVE	19TH ST	20TH ST	PCC	450	5	2,251	80	Good
SW_1644	PARK AVE	20TH ST	21ST ST	PCC	259	6	1,553	60	Good
SW_1676	PARK AVE	21ST ST	22ND ST	PCC	421	9	3,789	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1677	PARK AVE	22ND ST	21ST ST	PCC	418	5	2,088	90	Excellent
SW_1708	PARK AVE	22ND ST	23RD ST	PCC	246	11	2,710	80	Good
SW_1726	PARK AVE	22ND ST	23RD ST	PCC	281	7	1,967	71	Good
SW_0867	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	PCC	417	5	2,083	90	Excellent
SW_0868	PENNSYLVANIA AVE	11TH ST	12TH ST	PCC	304	4	1,218	90	Excellent
SW_0927	PENNSYLVANIA AVE	8TH ST	9TH ST	PCC	361	5	1,805	87	Good
SW_0942	PENNSYLVANIA AVE	12TH ST	13TH ST	PCC	401	5	2,005	90	Excellent
SW_0973	PENNSYLVANIA AVE	13TH ST	14TH ST	PCC	403	5	2,013	80	Good
SW_0993	PENNSYLVANIA AVE	9TH ST	10TH ST	PCC	411	5	2,054	85	Good
SW_1016	PENNSYLVANIA AVE	14TH ST	14TH PL	PCC	261	5	1,305	90	Excellent
SW_1048	PENNSYLVANIA AVE	10TH ST	11TH ST	PCC	402	5	2,010	80	Good
SW_1087	PENNSYLVANIA AVE	14TH PL	ESPANOLA WAY	PCC	211	5	1,053	90	Excellent
SW_1150	PENNSYLVANIA AVE	ESPANOLA WAY	15TH ST	PCC	192	6	1,153	80	Good
SW_1217	PENNSYLVANIA AVE	15TH ST	16TH ST	PCC	515	5	2,573	90	Excellent
SW_1262	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	PCC	26	8	205	80	Good
SW_1268	PENNSYLVANIA AVE	16TH ST	LINCOLN LN	PCC	307	6	1,842	90	Excellent
SW_1277	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	PCC	209	15	3,141	80	Good
SW_1280	PENNSYLVANIA AVE	LINCOLN RD	LINCOLN LN	PCC	136	6	818	80	Good
SW_1289	PENNSYLVANIA AVE	LINCOLN RD	LINCOLN LN	PCC	141	5	707	80	Good
SW_1333	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	PCC	202	14	2,835	80	Good
SW_1344	PENNSYLVANIA AVE	16TH ST	LINCOLN LN	PCC	303	6	1,820	80	Good
SW_1399	PENNSYLVANIA AVE	15TH ST	16TH ST	PCC	515	5	2,573	90	Excellent
SW_1433	PENNSYLVANIA AVE	ESPANOLA WAY	15TH ST	PCC	187	6	1,119	90	Excellent
SW_1475	PENNSYLVANIA AVE	14TH PL	ESPANOLA WAY	PCC	228	9	2,052	90	Excellent
SW_1498	PENNSYLVANIA AVE	14TH ST	14TH PL	PCC	276	9	2,485	80	Good
SW_1533	PENNSYLVANIA AVE	13TH ST	14TH ST	PCC	417	5	2,086	80	Good
SW_1567	PENNSYLVANIA AVE	12TH ST	13TH ST	PCC	411	5	2,056	80	Good
SW_1642	PENNSYLVANIA AVE	11TH ST	12TH ST	PCC	299	10	2,990	80	Good
SW_1674	PENNSYLVANIA AVE	10TH ST	11TH ST	PCC	415	5	2,076	80	Good
SW_1716	PENNSYLVANIA AVE	9TH ST	10TH ST	PCC	411	5	2,057	80	Good
SW_1737	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	PCC	441	8	3,531	79	Good
SW_1774	PENNSYLVANIA AVE	8TH ST	9TH ST	PCC	357	6	2,142	77	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1948	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	PCC	358	14	5,009	80	Good
SW_1964	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	PCC	366	7	2,563	80	Good
SW_3206	PENNSYLVANIA AVE	LINCOLN RD	LINCOLN LN	PCC	361	24	8,666	80	Good
SW_3205	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	PCC	333	19	6,326	80	Good
SW_3207	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	PCC	332	29	9,618	80	Good
SW_0351	PINE TREE DR	63RD ST	PINE TREE DR CIR	PCC	260	5	1,298	80	Good
SW_0511	PINE TREE DR	46TH XOVR	45TH ST	PCC	745	5	3,725	66	Good
SW_0520	PINE TREE DR	61ST ST	63RD ST	PCC	585	5	2,925	80	Good
SW_0531	PINE TREE DR	46TH ST	46TH XOVR	PCC	57	6	339	80	Good
SW_0575	PINE TREE DR	47TH ST	46TH ST	PCC	320	6	1,922	74	Good
SW_0610	PINE TREE DR	60TH ST	61ST ST	PCC	291	5	1,453	80	Good
SW_0615	PINE TREE DR	60TH ST	61ST ST	PCC	147	5	733	80	Good
SW_0887	PINE TREE DR	37TH ST	40TH ST	PCC	1,093	5	5,466	80	Good
SW_0937	PINE TREE DR	31ST ST	33RD ST	PCC	458	5	2,290	80	Good
SW_1002	PINE TREE DR	30TH ST	31ST ST	PCC	258	5	1,292	85	Good
SW_1199	PINE TREE DR	PINE TREE DR	30TH ST	PCC	599	5	2,996	90	Excellent
SW_1286	PINE TREE DR	SHERIDAN AVE	28TH ST	PCC	278	9	2,500	80	Good
SW_1460	PINE TREE DR	DADE BLVD	24TH ST	PCC	468	5	2,341	80	Good
SW_1551	PINE TREE DR	59TH ST	60TH ST	PCC	312	5	1,561	80	Good
SW_1734	PINE TREE DR	42ND ST	41ST ST	PCC	241	7	1,689	70	Good
SW_1829	PINE TREE DR	PINE TREE DR	30TH ST	PCC	67	5	337	80	Good
SW_1931	PINE TREE DR	51ST ST	47TH ST	PCC	1,636	6	9,818	70	Good
SW_1971	PINE TREE DR	44TH ST	42ND ST	PCC	725	5	3,623	77	Good
SW_1984	PINE TREE DR	58TH ST	59TH ST	PCC	436	5	2,182	80	Good
SW_1997	PINE TREE DR	51ST ST	47TH ST	PCC	117	5	585	85	Good
SW_2010	PINE TREE DR	51ST ST	47TH ST	PCC	61	5	305	80	Good
SW_2030	PINE TREE DR	51ST ST	47TH ST	PCC	33	5	163	90	Excellent
SW_2031	PINE TREE DR	51ST ST	47TH ST	PCC	71	5	357	80	Good
SW_2058	PINE TREE DR	51ST ST	47TH ST	PCC	99	5	497	90	Excellent
SW_2065	PINE TREE DR	51ST ST	47TH ST	PCC	105	10	1,053	70	Good
SW_2095	PINE TREE DR	51ST ST	52ND ST	PCC	239	9	2,152	80	Good
SW_2107	PINE TREE DR	57TH ST	58TH ST	PCC	542	4	2,169	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2117	PINE TREE DR	LA GORCE DR	51ST ST	PCC	100	5	500	90	Excellent
SW_2135	PINE TREE DR	51ST ST	47TH ST	PCC	230	5	1,149	90	Excellent
SW_2153	PINE TREE DR	56TH ST	57TH ST	PCC	547	5	2,736	80	Good
SW_2169	PINE TREE DR	51ST ST	47TH ST	PCC	75	4	299	80	Good
SW_2177	PINE TREE DR	51ST ST	47TH ST	PCC	33	4	131	90	Excellent
SW_2189	PINE TREE DR	51ST ST	47TH ST	PCC	60	5	300	90	Excellent
SW_2208	PINE TREE DR	SHERIDAN AVE	25TH ST	PCC	588	6	3,527	77	Good
SW_2219	PINE TREE DR	55TH ST	56TH ST	PCC	571	5	2,857	80	Good
SW_2277	PINE TREE DR	54TH ST	55TH ST	PCC	452	5	2,261	80	Good
SW_2279	PINE TREE DR	24TH ST	24TH TER	PCC	131	7	919	90	Excellent
SW_2311	PINE TREE DR	42ND ST	44TJ ST	PCC	427	8	3,417	80	Good
SW_2313	PINE TREE DR	24TH TER	25TH ST	PCC	285	4	1,140	75	Good
SW_2314	PINE TREE DR	25TH ST	24TH TER	PCC	317	6	1,902	81	Good
SW_2328	PINE TREE DR	53RD ST	54TH ST	PCC	440	4	1,762	80	Good
SW_2358	PINE TREE DR	52ND ST	53RD ST	PCC	390	4	1,560	80	Good
SW_2360	PINE TREE DR	LA GORCE CIR	PINE TREE DR CIR	PCC	150	8	1,200	90	Excellent
SW_2372	PINE TREE DR	41ST ST	42ND ST	PCC	243	9	2,189	80	Good
SW_2396	PINE TREE DR	41ST ST	42ND ST	PCC	23	4	93	80	Good
SW_2470	PINE TREE DR	51ST ST	52ND ST	PCC	136	4	546	80	Good
SW_2480	PINE TREE DR	51ST ST	52ND ST	PCC	213	5	1,067	90	Excellent
SW_2499	PINE TREE DR	24TH ST	DADE BLVD	PCC	624	6	3,746	80	Good
SW_2528	PINE TREE DR	25TH ST	26TH ST	PCC	449	5	2,243	80	Good
SW_2582	PINE TREE DR	40TH ST	FLAMINGO DR	PCC	76	5	381	90	Excellent
SW_2628	PINE TREE DR	26TH ST	SHERIDAN AVE	PCC	84	5	419	90	Excellent
SW_2649	PINE TREE DR	40TH ST	37TH ST	PCC	623	5	3,114	80	Good
SW_2657	PINE TREE DR	41ST ST	40TH CT	BR	333	10	3,325	80	Good
SW_2667	PINE TREE DR	SHERIDAN AVE	28TH ST	PCC	415	5	2,076	63	Good
SW_2668	PINE TREE DR	28TH ST	PINE TREE DR	PCC	81	5	404	90	Excellent
SW_3156	PINE TREE DR	63RD ST	PINE TREE DR CIR	PCC	226	5	1,132	40	Fair
SW_3157	PINE TREE DR	59TH ST	60TH ST	PCC	123	5	615	100	Excellent
SW_3181	PINE TREE DR	45TH ST	45TH ST	PCC	37	17	637	90	Excellent
SW_3189	PINE TREE DR	37TH ST	35TH ST	PCC	116	5	582	40	Fair

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_3190	PINE TREE DR	37TH ST	35TH ST	PCC	161	6	966	40	Fair
SW_2725	PINE TREE DR CIR	LA GORCE DR	PINE TREE DR	PCC	186	6	1,119	80	Good
SW_0008	POINTE DR	COLLINS AVE	COLLINS CT	PCC	154	10	1,537	90	Excellent
SW_0016	POINTE DR	COLLINS CT	WASHINGTON AVE	PCC	141	11	1,548	90	Excellent
SW_0192	POINTE DR	OCEAN DR	BEACH SVRD	BR	148	29	4,290	90	Excellent
SW_0194	POINTE DR	BEACH SVRD	OCEAN DR	PCC	319	8	2,551	80	Good
SW_0199	POINTE DR	COLLINS CT	POINTE DR	PCC	347	14	4,854	90	Excellent
SW_0202	POINTE DR	POINTE DR	OCEAN CT	PCC	281	11	3,094	90	Excellent
SW_0203	POINTE DR	OCEAN DR	BEACH SVRD	PCC	52	5	262	80	Good
SW_0222	POINTE DR	OCEAN DR	BEACH SVRD	BR	378	8	3,021	90	Excellent
SW_0227	POINTE DR	BEACH SVRD	OCEAN DR	PCC	499	14	6,988	90	Excellent
SW_0512	POINTE DR	WASHINGTON AVE	JEFFERSON AVE	BR	394	11	4,332	90	Excellent
SW_0665	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	BR	153	15	2,289	90	Excellent
SW_0666	POINTE DR	OCEAN DR	OCEAN CT	PCC	118	13	1,536	80	Good
SW_3045	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	BR	259	12	3,112	90	Excellent
SW_3051	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	BR	357	8	2,856	90	Excellent
SW_3052	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	BR	868	17	14,760	90	Excellent
SW_3053	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	PCC	63	10	632	70	Good
SW_3055	POINTE DR	OCEAN CT	COLLINS AVE	BR	142	17	2,416	80	Good
SW_3111	POINTE DR	OCEAN DR	BEACH SVRD	PCC	12	11	136	90	Excellent
SW_1225	POST AVE	45TH ST	46TH ST	PCC	599	5	2,995	90	Excellent
SW_1586	POST AVE	44TH ST	45TH ST	PCC	595	5	2,975	80	Good
SW_1617	POST AVE	43RD ST	44TH ST	PCC	431	5	2,153	90	Excellent
SW_1649	POST AVE	42ND ST	43RD ST	PCC	304	5	1,521	90	Excellent
SW_2486	POST AVE	43RD ST	44TH ST	PCC	394	5	1,968	90	Excellent
SW_2510	POST AVE	42ND ST	43RD ST	PCC	277	5	1,385	80	Good
SW_2571	POST AVE	46TH ST	47TH ST	PCC	298	5	1,491	90	Excellent
SW_2608	POST AVE	45TH ST	46TH ST	PCC	616	5	3,081	90	Excellent
SW_0241	PRAIRIE AVE	PRAIRIE AVE	28TH ST	PCC	216	7	1,514	80	Good
SW_0242	PRAIRIE AVE	23RD ST	PRAIRIE AVE	PCC	31	12	366	90	Excellent
SW_0366	PRAIRIE AVE	28TH ST	29TH ST	PCC	720	7	5,042	90	Excellent
SW_0406	PRAIRIE AVE	29TH ST	30TH ST	PCC	326	7	2,285	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0419	PRAIRIE AVE	30TH ST	31ST ST	PCC	409	7	2,866	80	Good
SW_0462	PRAIRIE AVE	23RD ST	PRAIRIE AVE	PCC	1,134	7	7,938	79	Good
SW_0463	PRAIRIE AVE	23RD ST	PRAIRIE AVE	PCC	372	13	4,841	80	Good
SW_0468	PRAIRIE AVE	DADE BLVD	23RD ST	PCC	218	10	2,178	90	Excellent
SW_0486	PRAIRIE AVE	DADE BLVD	23RD ST	PCC	364	8	2,913	90	Excellent
SW_0504	PRAIRIE AVE	34TH ST	37TH ST	PCC	620	5	3,099	80	Good
SW_0519	PRAIRIE AVE	DADE BLVD	23RD ST	PCC	1,164	5	5,819	79	Good
SW_1970	PRAIRIE AVE	42ND ST	44TH ST	PCC	664	8	5,312	90	Excellent
SW_2012	PRAIRIE AVE	42ND ST	44TH ST	PCC	287	5	1,433	90	Excellent
SW_2048	PRAIRIE AVE	41ST ST	41ST CT	PCC	460	7	3,219	90	Excellent
SW_2081	PRAIRIE AVE	41ST ST	41ST CT	PCC	140	9	1,260	90	Excellent
SW_2105	PRAIRIE AVE	41ST CT	42ND ST	PCC	244	6	1,464	90	Excellent
SW_2109	PRAIRIE AVE	31ST ST	34TH ST	PCC	697	7	4,882	74	Good
SW_2221	PRAIRIE AVE	42ND ST	44TH ST	PCC	756	5	3,779	90	Excellent
SW_2234	PRAIRIE AVE	37TH ST	40TH ST	PCC	626	5	3,129	90	Excellent
SW_2256	PRAIRIE AVE	40TH ST	41ST ST	PCC	221	10	2,207	80	Good
SW_2287	PRAIRIE AVE	40TH ST	41ST ST	PCC	204	10	2,037	80	Good
SW_2305	PRAIRIE AVE	37TH ST	40TH ST	PCC	621	5	3,107	80	Good
SW_2350	PRAIRIE AVE	CHASE AVE	45TH ST	PCC	260	5	1,298	90	Excellent
SW_2357	PRAIRIE AVE	CHASE AVE	45TH ST	PCC	339	5	1,694	84	Good
SW_2479	PRAIRIE AVE	46TH ST	47TH ST	PCC	317	5	1,583	90	Excellent
SW_2521	PRAIRIE AVE	34TH ST	37TH ST	PCC	626	5	3,128	80	Good
SW_2664	PRAIRIE AVE	DADE BLVD	23RD ST	PCC	62	20	1,233	90	Excellent
SW_3167	PRAIRIE AVE	DADE BLVD	23RD ST	PCC	365	7	2,555	80	Good
SW_0609	PROMENADE ST	24TH ST	25TH ST	PCC	585	20	11,704	80	Good
SW_0636	PROMENADE ST	24TH ST	25TH ST	PCC	522	18	9,395	80	Good
SW_1610	PROMENADE ST	27TH ST	29TH ST	PCC	467	19	8,878	90	Excellent
SW_1626	PROMENADE ST	27TH ST	29TH ST	PCC	57	51	2,928	90	Excellent
SW_2545	PROMENADE ST	26TH ST	27TH ST	PCC	561	22	12,345	90	Excellent
SW_2563	PROMENADE ST	26TH ST	27TH ST	PCC	238	16	3,804	80	Good
SW_2618	PROMENADE ST	25TH ST	26TH ST	PCC	465	34	15,797	90	Excellent
SW_0020	PURDY AVE	18TH ST	DADE BLVD	PCC	152	8	1,213	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0032	PURDY AVE	18TH ST	DADE BLVD	PCC	294	9	2,643	80	Good
SW_0034	PURDY AVE	20TH ST	18TH ST	PCC	216	5	1,081	90	Excellent
SW_0043	PURDY AVE	20TH ST	18TH ST	PCC	139	6	831	80	Good
SW_0045	PURDY AVE	18TH ST	20TH ST	PCC	639	5	3,196	70	Good
SW_0071	PURDY AVE	20TH ST	18TH ST	PCC	364	5	1,822	80	Good
SW_0095	PURDY AVE	18TH ST	DADE BLVD	PCC	638	5	3,188	80	Good
SW_0110	PURDY AVE	DADE BLVD	18TH ST	PCC	193	10	1,931	80	Good
SW_0219	PURDY AVE	18TH ST	DADE BLVD	PCC	32	7	223	-	U.C./N.A.
SW_2766	PURDY AVE	18TH ST	DADE BLVD	PCC	50	11	549	-	U.C./N.A.
SW_2773	PURDY AVE	18TH ST	DADE BLVD	PCC	22	4	88	-	U.C./N.A.
SW_3172	PURDY AVE	DADE BLVD	18TH ST	PCC	139	5	695	80	Good
SW_3173	PURDY AVE	DADE BLVD	18TH ST	PCC	239	7	1,674	-	U.C./N.A.
SW_1113	RAY ST	SE END	SHORE DR	PCC	142	4	569	70	Good
SW_0569	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	20	6	119	90	Excellent
SW_2698	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	10	5	52	80	Good
SW_2754	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	295	5	1,476	80	Good
SW_2775	RIVO ALTO DR	3RD RIVO ALTO TER	4TH RIVO ALTO TER	PCC	317	5	1,585	90	Excellent
SW_2806	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	PCC	486	5	2,432	90	Excellent
SW_2826	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	PCC	268	5	1,339	90	Excellent
SW_2827	RIVO ALTO DR	3RD RIVO ALTO TER	4TH RIVO ALTO TER	PCC	331	5	1,656	90	Excellent
SW_2843	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	248	5	1,238	80	Good
SW_2846	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	113	5	567	30	Poor
SW_2850	RIVO ALTO DR	3RD RIVO ALTO TER	4TH RIVO ALTO TER	PCC	242	5	1,211	90	Excellent
SW_2855	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	PCC	332	5	1,661	90	Excellent
SW_2856	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	PCC	371	5	1,855	88	Good
SW_2860	RIVO ALTO DR	3RD RIVO ALTO TER	4TH RIVO ALTO TER	PCC	246	5	1,229	80	Good
SW_2861	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	309	5	1,545	37	Poor
SW_2945	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	PCC	325	5	1,623	63	Good
SW_2946	RIVO ALTO DR	1ST RIVO ALTO TER	2ND RIVO ALTO TER	PCC	317	5	1,586	76	Good
SW_2947	RIVO ALTO DR	RIVO ALTO DR	1ST RIVO ALTO TER	PCC	506	5	2,530	80	Good
SW_2948	RIVO ALTO DR	RIVO ALTO DR	1ST RIVO ALTO TER	PCC	417	5	2,084	80	Good
SW_2949	RIVO ALTO DR	1ST RIVO ALTO TER	2ND RIVO ALTO TER	PCC	327	5	1,635	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2950	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	PCC	301	5	1,505	70	Good
SW_2951	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	30	5	149	80	Good
SW_2953	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	PCC	248	5	1,239	90	Excellent
SW_2956	RIVO ALTO DR	1ST RIVO ALTO TER	2ND RIVO ALTO TER	PCC	244	5	1,221	80	Good
SW_2960	RIVO ALTO DR	1ST RIVO ALTO TER	2ND RIVO ALTO TER	PCC	251	5	1,254	80	Good
SW_2961	RIVO ALTO DR	RIVO ALTO DR	1ST RIVO ALTO TER	PCC	382	5	1,908	90	Excellent
SW_2963	RIVO ALTO DR	RIVO ALTO DR	1ST RIVO ALTO TER	PCC	319	5	1,596	80	Good
SW_2964	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	PCC	255	5	1,274	90	Excellent
SW_3093	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	PCC	119	5	597	90	Excellent
SW_3174	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	PCC	97	5	486	80	Good
SW_0613	ROYAL PALM AVE	46TH ST	47TH ST	PCC	329	5	1,644	90	Excellent
SW_0621	ROYAL PALM AVE	44TH ST	45TH ST	PCC	595	5	2,976	80	Good
SW_0646	ROYAL PALM AVE	43RD ST	44TH ST	PCC	426	5	2,130	80	Good
SW_0671	ROYAL PALM AVE	42ND ST	43RD ST	PCC	297	5	1,484	90	Excellent
SW_1747	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	BR	48	8	385	80	Good
SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	PCC	277	7	1,936	80	Good
SW_2090	ROYAL PALM AVE	42ND ST	43RD ST	PCC	291	5	1,453	80	Good
SW_2303	ROYAL PALM AVE	43RD ST	44TH ST	PCC	430	5	2,150	90	Excellent
SW_2333	ROYAL PALM AVE	34TH ST	37TH ST	PCC	634	5	3,169	80	Good
SW_2340	ROYAL PALM AVE	40TH ST	41ST ST	BR	253	11	2,785	70	Good
SW_2342	ROYAL PALM AVE	37TH ST	40TH ST	PCC	635	5	3,173	80	Good
SW_2367	ROYAL PALM AVE	34TH ST	37TH ST	PCC	607	5	3,033	80	Good
SW_2404	ROYAL PALM AVE	40TH ST	41ST ST	BR	274	8	2,194	80	Good
SW_2429	ROYAL PALM AVE	44TH ST	45TH ST	PCC	597	5	2,983	80	Good
SW_2439	ROYAL PALM AVE	37TH ST	40TH ST	PCC	617	5	3,085	80	Good
SW_2642	ROYAL PALM AVE	45TH ST	46TH ST	PCC	661	5	3,305	90	Excellent
SW_0400	RUE BORDEAUX	BAY DR	BIARRITZ DR	PCC	261	5	1,307	80	Good
SW_0448	RUE BORDEAUX	BAY DR	BIARRITZ DR	PCC	262	5	1,310	62	Good
SW_1762	RUE BORDEAUX	BIARRITZ DR	71ST ST	PCC	268	4	1,073	90	Excellent
SW_1962	RUE GRANVILLE	BIARRITZ DR	71ST ST	PCC	212	6	1,273	80	Good
SW_2262	RUE GRANVILLE	BAY DR	BIARRITZ DR	PCC	291	11	3,196	80	Good
SW_2399	RUE GRANVILLE	71ST ST	NORMANDY DR	PCC	243	5	1,213	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2750	RUE GRANVILLE	BAY DR	BIARRITZ DR	PCC	218	5	1,091	90	Excellent
SW_0475	RUE NOTRE DAME	BAY DR	BIARRITZ DR	PCC	263	5	1,314	80	Good
SW_0482	RUE NOTRE DAME	BAY DR	BIARRITZ DR	PCC	268	5	1,340	78	Good
SW_1341	RUE NOTRE DAME	BIARRITZ DR	71ST ST	PCC	238	5	1,191	80	Good
SW_1876	RUE NOTRE DAME	MARSEILLE DR	NW END	PCC	101	8	808	90	Excellent
SW_2104	RUE NOTRE DAME	NORMANDY DR	MARSEILLE DR	PCC	244	7	1,708	80	Good
SW_2126	RUE NOTRE DAME	EVERGLADES CT	NORMANDY DR	PCC	110	7	770	80	Good
SW_2179	RUE NOTRE DAME	71ST ST	EVERGLADES CT	PCC	93	15	1,401	90	Excellent
SW_2217	RUE NOTRE DAME	NORMANDY DR	MARSEILLE DR	PCC	274	10	2,744	90	Excellent
SW_0822	RUE VENDOME	BIARRITZ CT	71ST ST	BR	45	8	363	90	Excellent
SW_0844	RUE VENDOME	BREST ESPLANADE	BIARRITZ CT	PCC	325	5	1,627	90	Excellent
SW_0873	RUE VENDOME	BREST ESPLANADE	BIARRITZ CT	PCC	419	4	1,676	80	Good
SW_0883	RUE VENDOME	BIARRITZ CT	71ST ST	PCC	117	7	816	80	Good
SW_2562	RUE VENDOME	71ST ST	NORMANDY DR	PCC	596	19	11,329	90	Excellent
SW_3153	RUE VENDOME	BIARRITZ CT	71ST ST	BR	52	15	784	90	Excellent
SW_3154	RUE VENDOME	BIARRITZ CT	71ST ST	BR	96	4	383	90	Excellent
SW_0525	RUE VERSAILLES	BAY DR	BIARRITZ DR	PCC	254	6	1,526	80	Good
SW_0559	RUE VERSAILLES	BAY DR	BIARRITZ DR	PCC	257	6	1,539	66	Good
SW_0855	RUE VERSAILLES	BIARRITZ CT	71ST ST	PCC	89	6	537	90	Excellent
SW_0874	RUE VERSAILLES	BIARRITZ DR	BIARRITZ CT	PCC	148	6	887	80	Good
SW_0950	RUE VERSAILLES	BAY DR	BIARRITZ DR	PCC	86	4	343	90	Excellent
SW_1068	RUE VERSAILLES	BIARRITZ DR	BIARRITZ CT	PCC	174	5	870	90	Excellent
SW_1102	RUE VERSAILLES	BIARRITZ CT	71ST ST	PCC	80	6	482	90	Excellent
SW_1769	RUE VERSAILLES	SOUTH END	BAY DR	PCC	141	5	705	90	Excellent
SW_1777	RUE VERSAILLES	SOUTH END	BAY DR	PCC	105	4	422	90	Excellent
SW_2124	RUE VERSAILLES	NORMANDY DR	MARSEILLE DR	PCC	259	6	1,552	80	Good
SW_0377	SHERIDAN AVE	43RD ST	44TH ST	PCC	421	5	2,106	80	Good
SW_0429	SHERIDAN AVE	43RD ST	44TH ST	PCC	403	5	2,017	90	Excellent
SW_0451	SHERIDAN AVE	44TH ST	45TH ST	PCC	598	5	2,991	90	Excellent
SW_0505	SHERIDAN AVE	45TH ST	46TH XOVR	PCC	1,802	5	9,009	89	Good
SW_0528	SHERIDAN AVE	46TH XOVR	46TH ST	PCC	45	5	227	80	Good
SW_1540	SHERIDAN AVE	28TH ST	29TH ST	PCC	365	4	1,460	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1665	SHERIDAN AVE	41ST ST	41ST CT	BR	45	9	402	80	Good
SW_1666	SHERIDAN AVE	41ST CT	42ND ST	PCC	189	10	1,893	80	Good
SW_1673	SHERIDAN AVE	41ST CT	42ND ST	PCC	189	7	1,320	-	U.C./N.A.
SW_1736	SHERIDAN AVE	29TH ST	30TH ST	PCC	273	5	1,364	73	Good
SW_1846	SHERIDAN AVE	41ST ST	41ST CT	BR	79	7	552	80	Good
SW_1917	SHERIDAN AVE	31ST ST	34TH ST	PCC	622	5	3,108	80	Good
SW_1921	SHERIDAN AVE	28TH ST	29TH ST	PCC	124	5	621	90	Excellent
SW_2040	SHERIDAN AVE	PINE TREE DR	28TH ST	PCC	261	6	1,568	90	Excellent
SW_2041	SHERIDAN AVE	31ST ST	34TH ST	PCC	622	5	3,110	80	Good
SW_2154	SHERIDAN AVE	34TH ST	37TH ST	PCC	621	5	3,104	80	Good
SW_2249	SHERIDAN AVE	34TH ST	37TH ST	PCC	607	5	3,033	80	Good
SW_2512	SHERIDAN AVE	37TH ST	40TH ST	PCC	632	5	3,159	80	Good
SW_2535	SHERIDAN AVE	40TH CT	41ST ST	BR	330	7	2,310	80	Good
SW_2578	SHERIDAN AVE	40TH CT	41ST ST	PCC	311	10	3,107	80	Good
SW_2585	SHERIDAN AVE	37TH ST	40TH ST	PCC	659	5	3,296	80	Good
SW_0793	SHORE DR	BAY DR	FAIRWAY DR	PCC	704	6	4,223	80	Good
SW_0967	SHORE DR	BAY DR	FAIRWAY DR	PCC	564	5	2,820	77	Good
SW_0998	SHORE DR	BAY DR	FAIRWAY DR	PCC	454	5	2,271	90	Excellent
SW_1092	SHORE DR	BAY DR	RAY ST	PCC	1,527	6	9,160	67	Good
SW_1093	SHORE DR	BAY DR	RAY ST	PCC	1,497	6	8,985	66	Good
SW_1144	SHORE DR	MITCHELL ST	SARAZEN ST	PCC	1,404	5	7,020	68	Good
SW_1172	SHORE DR	RAY ST	HAGEN ST	PCC	1,082	5	5,410	80	Good
SW_1194	SHORE DR	VARDON ST	MITCHELL ST	PCC	1,135	5	5,673	80	Good
SW_1212	SHORE DR	RAY ST	HAGEN ST	PCC	1,072	5	5,358	90	Excellent
SW_1229	SHORE DR	HAGEN ST	JONES ST	PCC	1,644	5	8,220	100	Excellent
SW_1236	SHORE DR	FAIRWAY DR	VARDON ST	PCC	1,621	5	8,103	80	Good
SW_1291	SHORE DR	JONES ST	BIARRITZ DR	PCC	673	5	3,363	78	Good
SW_1338	SHORE DR	HAGEN ST	JONES ST	PCC	1,659	5	8,293	90	Excellent
SW_1403	SHORE DR	JONES ST	BIARRITZ DR	PCC	716	5	3,581	90	Excellent
SW_1469	SHORE DR	BIARRITZ DR	FAIRWAY DR	PCC	83	5	413	90	Excellent
SW_1470	SHORE DR	BIARRITZ DR	FAIRWAY DR	PCC	299	13	3,888	80	Good
SW_1510	SHORE DR	FAIRWAY DR	SARAZEN ST	PCC	819	5	4,095	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0527	STILLWATER DR	86TH ST	STILLWATER DR	PCC	561	4	2,244	90	Excellent
SW_0721	STILLWATER DR	STILLWATER DR	WEST END	PCC	2,563	4	10,252	89	Good
SW_1086	STILLWATER DR	STILLWATER DR	WEST END	PCC	2,548	4	10,191	90	Excellent
SW_1175	STILLWATER DR	HAWTHORNE AVE	STILLWATER DR	PCC	441	4	1,765	90	Excellent
SW_1266	STILLWATER DR	HAWTHORNE AVE	STILLWATER DR	PCC	288	7	2,016	90	Excellent
SW_1284	STILLWATER DR	86TH ST	STILLWATER DR	PCC	325	7	2,273	90	Excellent
SW_3166	SULLIVAN DR	ALTON RD	ALTON RD	PCC	12	9	107	90	Excellent
SW_0622	SUNSET DR	20TH ST	BAY RD	PCC	75	5	374	90	Excellent
SW_2753	SUNSET DR	20TH ST	BAY RD	PCC	91	6	548	90	Excellent
SW_2764	SUNSET DR	BAY RD	21ST ST	PCC	318	5	1,591	80	Good
SW_2772	SUNSET DR	BAY RD	21ST ST	PCC	165	5	826	90	Excellent
SW_2801	SUNSET DR	22ND ST	23RD ST	PCC	246	5	1,228	80	Good
SW_3012	SUNSET DR	27TH ST	28TH ST	PCC	316	6	1,894	80	Good
SW_1679	TATUM WATERWAY DR	77TH ST	78TH ST	PCC	486	5	2,430	76	Good
SW_1779	TATUM WATERWAY DR	77TH ST	78TH ST	PCC	886	5	4,430	80	Good
SW_1809	TATUM WATERWAY DR	78TH ST	DICKENS AVE	PCC	599	5	2,997	80	Good
SW_1833	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	PCC	69	9	625	90	Excellent
SW_1841	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	PCC	435	6	2,611	80	Good
SW_1878	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	PCC	310	6	1,862	77	Good
SW_1895	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	PCC	47	4	187	80	Good
SW_1904	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	PCC	51	5	256	80	Good
SW_2087	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	PCC	315	6	1,888	90	Excellent
SW_2113	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	PCC	336	5	1,678	80	Good
SW_2201	TATUM WATERWAY DR	78TH ST	DICKENS AVE	PCC	310	5	1,549	80	Good
SW_0292	TROUVILLE ESPLANADE	BAY DR	BIARRITZ DR	PCC	293	5	1,464	80	Good
SW_0563	TROUVILLE ESPLANADE	71ST ST	NORMANDY DR	PCC	299	11	3,290	70	Good
SW_1851	TROUVILLE ESPLANADE	BIARRITZ DR	71ST ST	PCC	320	5	1,600	80	Good
SW_1862	TROUVILLE ESPLANADE	71ST ST	BIARRITZ DR	PCC	284	5	1,419	80	Good
SW_2070	TROUVILLE ESPLANADE	CALAIS DR	TROUVILLE ESPLANADE	PCC	159	6	952	90	Excellent
SW_2072	TROUVILLE ESPLANADE	TROUVILLE ESPLANADE	CALAIS DR	PCC	139	6	833	69	Good
SW_2426	TROUVILLE ESPLANADE	CALAIS DR	MARSEILLE DR	PCC	206	5	1,030	71	Good
SW_2449	TROUVILLE ESPLANADE	MARSEILLE DR	NORMANDY DR	PCC	242	6	1,450	63	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0086	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	178	8	1,424	80	Good
SW_0347	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	145	11	1,595	90	Excellent
SW_0617	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	267	7	1,868	63	Good
SW_0639	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	PCC	347	6	2,081	80	Good
SW_0664	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	PCC	276	6	1,658	90	Excellent
SW_0775	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	PCC	182	4	730	90	Excellent
SW_2397	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	PCC	143	6	856	80	Good
SW_2523	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	131	6	786	80	Good
SW_2665	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	151	8	1,204	80	Good
SW_2690	VENETIAN CSWY	VENETIAN RIVO ALTO WAY	DI LIDO DR	PCC	157	7	1,096	80	Good
SW_2851	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	183	7	1,280	90	Excellent
SW_2858	VENETIAN CSWY	VENETIAN RIVO ALTO WAY	DI LIDO DR	PCC	175	6	1,047	90	Excellent
SW_2862	VENETIAN CSWY	VENETIAN RIVO ALTO WAY	DI LIDO DR	PCC	617	6	3,699	80	Good
SW_2863	VENETIAN CSWY	VENETIAN RIVO ALTO WAY	DI LIDO DR	PCC	158	7	1,105	90	Excellent
SW_2902	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	147	8	1,179	90	Excellent
SW_2916	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	PCC	630	6	3,778	80	Good
SW_2920	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	PCC	635	6	3,807	80	Good
SW_2944	VENETIAN CSWY	VENETIAN RIVO ALTO WAY	DI LIDO DR	PCC	608	6	3,649	80	Good
SW_2900	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	PCC	251	5	1,256	90	Excellent
SW_2943	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	PCC	256	5	1,282	78	Good
SW_2755	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	PCC	254	5	1,270	80	Good
SW_2952	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	PCC	256	5	1,281	80	Good
SW_0545	VENETIAN SAN MARINO WAY	SAN MARINO DR	SAN MARINO DR	PCC	225	10	2,249	80	Good
SW_2919	VENETIAN SAN MARINO WAY	SAN MARINO DR	SAN MARINO DR	PCC	306	8	2,446	90	Excellent
SW_0291	VENETIAN WAY	ISLAND AVE	ISLAND AVE	PCC	468	5	2,338	90	Excellent
SW_0497	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	333	6	1,999	80	Good
SW_0521	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	150	4	601	80	Good
SW_0579	VENETIAN WAY	DADE BLVD	ISLAND AVE	PCC	228	5	1,139	80	Good
SW_2761	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	298	7	2,088	80	Good
SW_2774	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	301	4	1,206	80	Good
SW_2783	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	297	7	2,081	80	Good
SW_2804	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	152	4	607	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_2824	VENETIAN WAY	DADE BLVD	ISLAND AVE	PCC	464	5	2,319	90	Excellent
SW_2825	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	187	5	936	90	Excellent
SW_2966	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	PCC	1,752	6	10,513	80	Good
SW_2977	VENETIAN WAY	ISLAND AVE	ISLAND AVE	PCC	737	7	5,161	76	Good
SW_2990	VENETIAN WAY	DADE BLVD	ISLAND AVE	PCC	277	6	1,662	90	Excellent
SW_3095	VENETIAN WAY	ISLAND AVE	ISLAND AVE	PCC	521	5	2,607	80	Good
SW_3096	VENETIAN WAY	ISLAND AVE	ISLAND AVE	PCC	24	5	120	90	Excellent
SW_1145	VERDUN DR	MARSEILLE DR	CALAIS DR	PCC	289	5	1,446	80	Good
SW_1720	VERDUN DR	MARSEILLE DR	CALAIS DR	PCC	749	6	4,492	80	Good
SW_2062	VERDUN DR	VERDUN CT	MARSEILLE DR	PCC	289	5	1,446	76	Good
SW_2325	VICHY DR	71ST ST	MAIMONIDES ST	PCC	106	4	425	80	Good
SW_2387	VICHY DR	MAIMONIDES ST	NORMANDY DR	PCC	111	5	554	70	Good
SW_2427	VICHY DR	MAIMONIDES ST	NORMANDY DR	PCC	102	8	818	80	Good
SW_2450	VICHY DR	71ST ST	MAIMONIDES ST	PCC	98	5	492	80	Good
SW_0029	WASHINGTON AVE	POINTE DR	COMMERCE ST	PCC	260	14	3,643	90	Excellent
SW_0038	WASHINGTON AVE	COMMERCE ST	1ST ST	PCC	297	13	3,862	80	Good
SW_0053	WASHINGTON AVE	1ST ST	2ND ST	PCC	409	13	5,314	70	Good
SW_0062	WASHINGTON AVE	2ND ST	3RD ST	PCC	408	12	4,895	56	Fair
SW_0130	WASHINGTON AVE	3RD ST	4TH ST	PCC	439	11	4,832	80	Good
SW_0177	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	PCC	55	12	659	80	Good
SW_0178	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	PCC	257	12	3,086	70	Good
SW_0204	WASHINGTON AVE	3RD ST	2ND ST	PCC	652	19	12,381	80	Good
SW_0211	WASHINGTON AVE	2ND ST	1ST ST	PCC	405	12	4,865	80	Good
SW_0251	WASHINGTON AVE	COMMERCE CT	COMMERCE ST	PCC	255	13	3,309	80	Good
SW_0436	WASHINGTON AVE	6TH ST	7TH ST	PCC	563	15	8,438	90	Excellent
SW_0440	WASHINGTON AVE	5TH ST	6TH ST	PCC	302	11	3,326	90	Excellent
SW_0524	WASHINGTON AVE	POINTE CT	POINTE DR	PCC	253	10	2,534	80	Good
SW_0689	WASHINGTON AVE	4TH ST	5TH ST	PCC	254	9	2,282	90	Excellent
SW_0726	WASHINGTON AVE	13TH ST	14TH ST	PCC	405	11	4,456	80	Good
SW_0750	WASHINGTON AVE	PENNSYLVANIA AVE	5TH ST	PCC	424	13	5,512	90	Excellent
SW_0814	WASHINGTON AVE	5TH ST	4TH ST	PCC	238	13	3,091	90	Excellent
SW_0815	WASHINGTON AVE	7TH ST	PENNSYLVANIA AVE	PCC	418	14	5,847	90	Excellent

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0818	WASHINGTON AVE	12TH ST	13TH ST	PCC	412	11	4,535	80	Good
SW_0823	WASHINGTON AVE	4TH ST	3RD ST	PCC	357	14	5,000	90	Excellent
SW_0845	WASHINGTON AVE	4TH ST	3RD ST	BR	214	18	3,851	80	Good
SW_0880	WASHINGTON AVE	11TH ST	12TH ST	PCC	337	11	3,703	90	Excellent
SW_0975	WASHINGTON AVE	10TH ST	11TH ST	PCC	410	19	7,797	80	Good
SW_0985	WASHINGTON AVE	7TH ST	8TH ST	PCC	406	18	7,304	80	Good
SW_0996	WASHINGTON AVE	9TH ST	10TH ST	PCC	410	19	7,789	90	Excellent
SW_1013	WASHINGTON AVE	8TH ST	9TH ST	PCC	413	16	6,602	80	Good
SW_1311	WASHINGTON AVE	LINCOLN RD	16TH ST	PCC	538	16	8,606	70	Good
SW_1358	WASHINGTON AVE	LINCOLN LN	17TH ST	PCC	347	15	5,199	70	Good
SW_1365	WASHINGTON AVE	16TH ST	15TH ST	PCC	506	10	5,058	80	Good
SW_1386	WASHINGTON AVE	17TH ST	JACKIE GLEASON DR	PCC	325	5	1,626	80	Good
SW_1402	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	PCC	181	5	903	90	Excellent
SW_1407	WASHINGTON AVE	15TH ST	ESPANOLA WAY	PCC	214	11	2,356	80	Good
SW_1422	WASHINGTON AVE	18TH ST	19TH ST	PCC	371	5	1,853	90	Excellent
SW_1431	WASHINGTON AVE	18TH ST	19TH ST	PCC	429	10	4,294	90	Excellent
SW_1461	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	PCC	217	9	1,954	90	Excellent
SW_1466	WASHINGTON AVE	ESPANOLA WAY	14TH ST	PCC	511	12	6,134	80	Good
SW_1468	WASHINGTON AVE	19TH ST	20TH ST	PCC	611	9	5,497	90	Excellent
SW_1508	WASHINGTON AVE	20TH ST	21ST ST	PCC	272	5	1,359	90	Excellent
SW_1514	WASHINGTON AVE	14TH ST	13TH ST	PCC	404	13	5,255	80	Good
SW_1526	WASHINGTON AVE	21ST ST	WASHINGTON CT	PCC	165	4	659	90	Excellent
SW_1543	WASHINGTON AVE	WASHINGTON CT	DADE BLVD	PCC	120	6	722	80	Good
SW_1563	WASHINGTON AVE	WASHINGTON CT	DADE BLVD	PCC	69	4	277	80	Good
SW_1580	WASHINGTON AVE	21ST ST	WASHINGTON CT	PCC	149	5	743	80	Good
SW_1587	WASHINGTON AVE	13TH ST	12TH ST	PCC	483	7	3,384	80	Good
SW_1590	WASHINGTON AVE	20TH ST	21ST ST	PCC	260	5	1,301	80	Good
SW_1604	WASHINGTON AVE	19TH ST	20TH ST	PCC	499	5	2,497	80	Good
SW_1627	WASHINGTON AVE	12TH ST	11TH ST	PCC	313	13	4,067	90	Excellent
SW_1651	WASHINGTON AVE	11TH ST	10TH ST	PCC	413	11	4,548	80	Good
SW_1667	WASHINGTON AVE	10TH ST	9TH ST	PCC	418	11	4,603	80	Good
SW_1683	WASHINGTON AVE	9TH ST	8TH ST	PCC	385	11	4,231	80	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_1697	WASHINGTON AVE	8TH ST	7TH ST	PCC	432	10	4,323	80	Good
SW_1909	WASHINGTON AVE	LINCOLN LN	17TH ST	PCC	378	9	3,399	80	Good
SW_2025	WASHINGTON AVE	16TH ST	LINCOLN RD	BR	34	12	406	80	Good
SW_2052	WASHINGTON AVE	16TH ST	LINCOLN RD	PCC	492	16	7,872	80	Good
SW_2091	WASHINGTON AVE	15TH ST	16TH ST	PCC	552	9	4,965	80	Good
SW_2099	WASHINGTON AVE	ESPANOLA WAY	15TH ST	PCC	204	10	2,042	90	Excellent
SW_2191	WASHINGTON AVE	14TH ST	ESPANOLA WAY	PCC	530	11	5,835	80	Good
SW_3121	WASHINGTON AVE	LINCOLN LN	17TH ST	PCC	176	16	2,814	-	U.C./N.A.
SW_1570	WASHINGTON CT	22ND ST	WASHINGTON AVE	PCC	37	5	184	90	Excellent
SW_1691	WASHINGTON CT	22ND ST	WASHINGTON AVE	PCC	351	5	1,757	80	Good
SW_1699	WASHINGTON CT	22ND ST	WASHINGTON AVE	PCC	298	14	4,167	90	Excellent
SW_0732	WAYNE AVE	BRUCE ST	MICHAEL ST	AC	586	9	5,277	20	Poor
SW_0831	WAYNE AVE	BRUCE ST	MICHAEL ST	PCC	273	5	1,363	90	Excellent
SW_0885	WAYNE AVE	73RD ST	BRUCE ST	PCC	509	4	2,036	80	Good
SW_0938	WAYNE AVE	RAYMOND ST	73RD ST	PCC	39	9	351	90	Excellent
SW_0978	WAYNE AVE	RAYMOND ST	73RD ST	PCC	34	4	136	90	Excellent
SW_1126	WAYNE AVE	73RD ST	BRUCE ST	PCC	541	5	2,707	80	Good
SW_1305	WAYNE AVE	BRUCE ST	MICHAEL ST	PCC	218	5	1,090	80	Good
SW_3140	WAYNE AVE	BRUCE ST	MICHAEL ST	PCC	140	10	1,401	90	Excellent
SW_3141	WAYNE AVE	BRUCE ST	MICHAEL ST	PCC	108	10	1,079	80	Good
SW_0056	WEST AVE	18TH ST	20TH ST	PCC	685	7	4,795	67	Good
SW_0080	WEST AVE	18TH ST	20TH ST	PCC	665	6	3,991	77	Good
SW_0084	WEST AVE	DADE BLVD	18TH ST	PCC	219	7	1,531	80	Good
SW_0088	WEST AVE	DADE BLVD	18TH ST	PCC	263	5	1,316	80	Good
SW_0191	WEST AVE	LINCOLN RD	17TH ST	PCC	519	6	3,112	80	Good
SW_0643	WEST AVE	15TH TER	16TH ST	PCC	203	6	1,221	70	Good
SW_0709	WEST AVE	15TH ST	15TH TER	PCC	249	6	1,494	70	Good
SW_0738	WEST AVE	15TH TER	16TH ST	PCC	202	5	1,008	90	Excellent
SW_0752	WEST AVE	FLAMINGO WAY	15TH ST	PCC	245	6	1,468	80	Good
SW_0788	WEST AVE	14TH CT	FLAMINGO WAY	PCC	67	5	333	80	Good
SW_0826	WEST AVE	15TH ST	15TH TER	PCC	252	5	1,262	80	Good
SW_0859	WEST AVE	14TH TER	14TH CT	PCC	132	5	660	70	Good

Segment ID	Street	Street From	Street To	Surface	Length	Width	Area	SCI	Sidewalk Rating
SW_0869	WEST AVE	14TH ST	14TH TER	PCC	226	6	1,357	70	Good
SW_0904	WEST AVE	FLAMINGO WAY	15TH ST	PCC	222	6	1,334	80	Good
SW_0917	WEST AVE	MONAD TER	14TH ST	PCC	313	6	1,878	80	Good
SW_0943	WEST AVE	13TH ST	MONAD TER	PCC	96	6	578	60	Good
SW_0955	WEST AVE	14TH CT	FLAMINGO WAY	PCC	64	6	384	90	Excellent
SW_0974	WEST AVE	14TH TER	14TH CT	PCC	135	5	677	90	Excellent
SW_1009	WEST AVE	12TH ST	13TH ST	PCC	440	7	3,078	78	Good
SW_1039	WEST AVE	MONAD TER	14TH ST	PCC	300	8	2,404	80	Good
SW_1042	WEST AVE	13TH ST	MONAD TER	PCC	126	5	628	80	Good
SW_1061	WEST AVE	14TH ST	14TH TER	PCC	209	5	1,043	80	Good
SW_1063	WEST AVE	11TH ST	12TH ST	PCC	285	5	1,426	80	Good
SW_1081	WEST AVE	12TH ST	13TH ST	PCC	469	5	2,345	80	Good
SW_1089	WEST AVE	10TH ST	11TH ST	PCC	408	6	2,450	80	Good
SW_1097	WEST AVE	11TH ST	12TH ST	PCC	368	5	1,840	80	Good
SW_1110	WEST AVE	10TH ST	11TH ST	PCC	433	5	2,167	80	Good
SW_1160	WEST AVE	9TH ST	10TH ST	PCC	437	5	2,187	80	Good
SW_1181	WEST AVE	8TH ST	9TH ST	PCC	417	5	2,086	80	Good
SW_1218	WEST AVE	6TH ST	8TH ST	PCC	896	7	6,272	80	Good
SW_1232	WEST AVE	9TH ST	10TH ST	PCC	393	6	2,358	80	Good
SW_1251	WEST AVE	ALTON RD	6TH ST	PCC	270	9	2,432	80	Good
SW_1269	WEST AVE	ALTON RD	6TH ST	PCC	32	5	160	90	Excellent
SW_1318	WEST AVE	ALTON RD	6TH ST	PCC	382	5	1,909	-	U.C./N.A.
SW_1334	WEST AVE	8TH ST	9TH ST	PCC	362	5	1,811	77	Good
SW_1391	WEST AVE	6TH ST	8TH ST	PCC	717	6	4,301	100	Excellent
SW_1542	WEST AVE	LINCOLN RD	17TH ST	PCC	507	6	3,042	80	Good
SW_3108	WEST AVE	6TH ST	8TH ST	PCC	141	6	848	80	Good

Appendix B:
Distress Priority Rankings



Kimley»Horn

Common Sidewalk Distress Definitions

Buckling occurs in hot weather, usually at a transverse crack or joint that is not wide enough to permit slab expansion. The insufficient width usually is caused by infiltration of incompressible materials into the joint space. When expansion cannot relieve enough pressure, a localized upward movement of the slab edges or shattering will occur in the vicinity of the joint. Buckling can also be caused by tree root displacement underneath the sidewalk.

Faulting is the difference in elevation across a joint or crack. Some common causes of faulting include:

1. Settlement because of soft foundation
2. Pumping or eroding of material from under the slab.
3. Curling of the slab edges due to temperature and moisture changes

Shattered Slabs are slabs with cracks that break the slab into four or more pieces due to overloading and/or inadequate support. This distress type is considered a structural distress.

Spalling is the breakdown of the slab within approximately 1.5 ft of the joint or corner. Spalls usually do not extend vertically through the slab, rather they intersect the joint at an angle. Spalling results from:

1. Excessive stresses at the joint caused by traffic or by infiltration of incompressible materials.
2. Weak concrete at the joint caused by overworking.
3. Water accumulation in the joint and freeze-thaw action

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0098	SW_0421	10TH ST	OCEAN CT	COLLINS AVE	Faulting	15	8	120	90	$1,400	1
D_0262	SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	Shattered Slab	10	5	50	90	$900	1
D_0100	SW_0293	10TH ST	LENOX AVE	ALTON RD	Other	5	5	25	80	$500	3
D_0102	SW_0306	10TH ST	LENOX AVE	ALTON RD	Other	5	6	30	80	$500	3
D_0275	SW_2163	41ST ST	PRAIRIE AVE	CHASE AVE	Other - Brick	12	5	60	80	$1,100	3
D_0124	SW_1014	5TH ST	MICHIGAN AVE	JEFFERSON CT	Other	10	10	100	80	$900	3
D_0125	SW_1014	5TH ST	MICHIGAN AVE	JEFFERSON CT	Shattered Slab	10	10	100	80	$900	3
D_0136	SW_1188	5TH ST	MERIDIAN AVE	MERIDIAN CT	Spalling	5	11	55	80	$500	3
D_0027	SW_0771	86TH ST	HARDING AVE	BYRON AVE	Shattered Slab	5	6	30	80	$500	3
D_0078	SW_0771	86TH ST	HARDING AVE	BYRON AVE	Shattered Slab	10	6	60	80	$900	3
D_0104	SW_0322	ALTON RD	10TH ST	11TH ST	Faulting	10	11	110	80	$900	3
D_0393	SW_1504	JEFFERSON AVE	5TH ST	6TH ST	Shattered Slab	10	8	80	80	$900	3
D_0110	SW_0401	LENOX AVE	4TH ST	5TH ST	Other	25	6	150	80	$2,300	3
D_0315	SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	Shattered Slab	20	5	100	80	$1,800	3
D_0137	SW_1216	MICHIGAN AVE	5TH ST	6TH ST	Shattered Slab	30	8	240	80	$2,700	3
D_0138	SW_1216	MICHIGAN AVE	5TH ST	6TH ST	Faulting	15	8	120	80	$1,400	3
D_0269	SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Shattered Slab	16	5	80	80	$1,500	3
D_0270	SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Shattered Slab	4	5	20	80	$400	3
D_0271	SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Shattered Slab	9	5	45	80	$900	3
D_0164	SW_1420	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	Shattered Slab	10	5	50	70	$900	20
D_0163	SW_1325	16TH ST	WASHINGTON AVE	DREXEL AVE	Shattered Slab	25	5	125	70	$2,300	20
D_0277	SW_2231	40TH ST	PRAIRIE CT	CHASE AVE	Faulting	4	5	20	70	$400	20
D_0266	SW_1947	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Faulting	5	5	25	70	$500	20
D_0193	SW_2093	65TH ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	10	7	70	70	$900	20
D_0086	SW_1265	71ST ST	VICHY DR	RUE VERSAILLES	Shattered Slab	10	12	120	70	$900	20
D_0033	SW_1622	73RD ST	COLLINS AVE	COLLINS CT	Shattered Slab	10	6	60	70	$900	20
D_0392	SW_1503	74TH ST	COLLINS AVE	COLLINS CT	Shattered Slab	10	8	80	70	$900	20
D_0016	SW_0335	ABBOTT AVE	71ST ST	69TH ST	Other	5	5	25	70	$500	20
D_0194	SW_0467	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	Shattered Slab	5	7	35	70	$500	20

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0040	SW_0498	ABBOTT AVE	71ST ST	69TH ST	Faulting	10	5	50	70	$900	20
D_0062	SW_0498	ABBOTT AVE	71ST ST	69TH ST	Shattered Slab	5	5	25	70	$500	20
D_0099	SW_0253	ALTON RD	8TH ST	9TH ST	Other	5	6	30	70	$500	20
D_0325	SW_2765	ALTON RD	ALTON RD	MICHIGAN AVE	Buckling	6	5	30	70	$600	20
D_0326	SW_2765	ALTON RD	ALTON RD	MICHIGAN AVE	Shattered Slab	25	5	125	70	$2,300	20
D_0367	SW_2965	ALTON RD	43RD ST	I 195	Shattered Slab	10	5	50	70	$900	20
D_0023	SW_1990	BAY DR	NORMANDY DR	MARSEILLE DR	Shattered Slab	6	6	36	70	$600	20
D_0095	SW_0134	BAY RD	DADE BLVD	18TH ST	Shattered Slab	10	6	60	70	$900	20
D_0020	SW_1021	BIARRITZ DR	EAST END	RUE NOTRE DAME	Buckling	10	5	50	70	$900	20
D_0044	SW_1021	BIARRITZ DR	EAST END	RUE NOTRE DAME	Shattered Slab	15	5	75	70	$1,400	20
D_0067	SW_1256	COLLINS AVE	63RD ST	64TH ST	Shattered Slab	5	7	35	70	$500	20
D_0310	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Shattered Slab	15	6	90	70	$1,400	20
D_0170	SW_1874	DREXEL AVE	15TH ST	16TH ST	Shattered Slab	15	5	75	70	$1,400	20
D_0171	SW_1874	DREXEL AVE	15TH ST	16TH ST	Other	5	5	25	70	$500	20
D_0172	SW_1891	DREXEL AVE	LINCOLN RD	16TH ST	Shattered Slab	5	5	25	70	$500	20
D_0189	SW_0934	HARDING AVE	NORTH END	87TH TER	Shattered Slab	10	7	70	70	$900	20
D_0005	SW_0935	HARDING AVE	87TH TER	87TH ST	Other	10	8	80	70	$900	20
D_0192	SW_1861	HARDING AVE	69TH ST	71ST ST	Shattered Slab	10	6	60	70	$900	20
D_0106	SW_0361	LENOX AVE	9TH ST	10TH ST	Shattered Slab	40	5	200	70	$3,600	20
D_0108	SW_0375	LENOX AVE	7TH ST	8TH ST	Shattered Slab	30	4	120	70	$2,700	20
D_0093	SW_0152	MICHIGAN AVE	6TH ST	7TH ST	Faulting	20	4	80	70	$1,800	20
D_0119	SW_0776	MICHIGAN AVE	3RD ST	4TH ST	Faulting	10	5	50	70	$900	20
D_0131	SW_0993	PENNSYLVANIA AVE	9TH ST	10TH ST	Shattered Slab	20	5	100	70	$1,800	20
D_0276	SW_0575	PINE TREE DR	47TH ST	46TH ST	Faulting	20	6	120	70	$1,800	20
D_0267	SW_1971	PINE TREE DR	44TH ST	42ND ST	Shattered Slab	25	5	125	70	$2,300	20
D_0178	SW_0550	16TH ST	ALTON RD	ALTON CT	Shattered Slab	15	6	90	60	$1,400	55
D_0087	SW_0023	18TH ST	WEST AVE	BAY RD	Other	6	6	36	60	$600	55
D_0094	SW_0023	18TH ST	WEST AVE	BAY RD	Shattered Slab	20	6	120	60	$1,800	55
D_0331	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Shattered Slab	15	7	105	60	$1,400	55

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0332	SW_2811	19TH ST	MICHIGAN AVE	ALTON RD	Shattered Slab	20	5	100	60	$1,800	55
D_0111	SW_0431	1ST ST	MERIDIAN AVE	JEFFERSON AVE	Buckling	10	7	70	60	$900	55
D_0002	SW_1517	20TH ST	LIBERTY AVE	PARK AVE	Shattered Slab	10	6	60	60	$900	55
D_0118	SW_0757	3RD ST	JEFFERSON CT	MICHIGAN AVE	Shattered Slab	5	8	40	60	$500	55
D_0120	SW_0795	3RD ST	EUCLID AVE	EUCLID CT	Faulting	5	7	35	60	$500	55
D_0121	SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	Faulting	10	8	80	60	$900	55
D_0122	SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	Shattered Slab	10	8	80	60	$900	55
D_0390	SW_1800	41ST ST	PINE TREE DR	PINE TREE DR	Other - Brick	10	5	50	60	$900	55
D_0354	SW_2869	43RD CT	JEFFERSON AVE	MICHIGAN AVE	Buckling	10	4	40	60	$900	55
D_0357	SW_2893	43RD ST	ALTON RD	ALTON RD	Shattered Slab	10	6	60	60	$900	55
D_0127	SW_0758	5TH ST	EUCLID CT	MERIDIAN AVE	Shattered Slab	5	15	75	60	$500	55
D_0043	SW_0969	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Shattered Slab	4	6	24	60	$400	55
D_0065	SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Shattered Slab	5	6	30	60	$500	55
D_0024	SW_2301	71ST ST	GRANVILLE CT	RUE GRANVILLE	Faulting	5	5	25	60	$500	55
D_0011	SW_1413	75TH ST	COLLINS AVE	COLLINS CT	Shattered Slab	5	7	35	60	$500	55
D_0017	SW_0488	ABBOTT AVE	69TH ST	INDIAN CREEK DR	Faulting	10	6	60	60	$900	55
D_0333	SW_0333	ALTON RD	ALTON RD	SUNSET DR	Shattered Slab	40	6	240	60	$3,600	55
D_0387	SW_3084	ALTON RD	BARRY ST	39TH ST	Buckling	30	6	180	60	$2,700	55
D_0091	SW_0007	BAY RD	18TH ST	20TH ST	Shattered Slab	19	8	152	60	$1,800	55
D_0081	SW_0015	BAY RD	18TH ST	20TH ST	Shattered Slab	15	6	90	60	$1,400	55
D_0014	SW_2560	BONITA DR	BONITA DR	71ST ST	Other	5	5	25	60	$500	55
D_0060	SW_2666	BONITA DR	71ST ST	NW END	Shattered Slab	10	6	60	60	$900	55
D_0053	SW_0781	BYRON AVE	86TH ST	NORTH END	Shattered Slab	15	8	120	60	$1,400	55
D_0195	SW_0501	COLLINS AVE	76TH ST	77TH ST	Other	3	5	15	60	$300	55
D_0198	SW_0748	COLLINS AVE	76TH ST	77TH ST	Faulting	20	5	100	60	$1,800	55
D_0199	SW_1702	COLLINS AVE	74TH ST	75TH ST	Other	45	11	495	60	$4,100	55
D_0389	SW_2160	COLLINS AVE	63RD ST	64TH ST	Shattered Slab	15	6	90	60	$1,400	55
D_0165	SW_1456	ESPANOLA WAY	DREXEL AVE	PENNSYLVANIA AVE	Shattered Slab	6	11	66	60	$600	55
D_0123	SW_0951	EUCLID AVE	3RD ST	4TH ST	Faulting	20	12	240	60	$1,800	55

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0281	SW_2643	FLAMINGO DR	35TH ST	40TH ST	Shattered Slab	35	5	175	60	$3,200	55
D_0036	SW_2368	HARDING AVE	67TH ST	69TH ST	Shattered Slab	30	6	180	60	$2,700	55
D_0148	SW_0005	LENOX AVE	15TH ST	16TH ST	Shattered Slab	5	5	25	60	$500	55
D_0149	SW_0011	LENOX AVE	15TH ST	16TH ST	Faulting	6	5	30	60	$600	55
D_0150	SW_0031	LENOX AVE	14TH ST	15TH ST	Spalling	20	4	80	60	$1,800	55
D_0151	SW_0049	LENOX AVE	13TH ST	14TH ST	Shattered Slab	10	4	40	60	$900	55
D_0105	SW_0367	LENOX AVE	8TH ST	9TH ST	Spalling	5	7	35	60	$500	55
D_0107	SW_0367	LENOX AVE	8TH ST	9TH ST	Shattered Slab	25	7	175	60	$2,300	55
D_0157	SW_0478	LENOX AVE	17TH ST	18TH ST	Shattered Slab	6	5	30	60	$600	55
D_0158	SW_0494	LENOX AVE	17TH ST	18TH ST	Faulting	10	5	50	60	$900	55
D_0173	SW_0226	LINCOLN RD	WEST AVE	BAY RD	Faulting	20	8	160	60	$1,800	55
D_0177	SW_3100	LINCOLN RD	LINCOLN CT	WEST END	Faulting	10	8	80	60	$900	55
D_0058	SW_1787	MARSEILLE DR	BAY DR	RUE VERSAILLES	Other	2	6	12	60	$200	55
D_0112	SW_0444	MERIDIAN AVE	1ST ST	2ND ST	Shattered Slab	15	9	135	60	$1,400	55
D_0101	SW_0315	MICHIGAN AVE	10TH ST	11TH ST	Shattered Slab	20	5	100	60	$1,800	55
D_0103	SW_0315	MICHIGAN AVE	10TH ST	11TH ST	Other	15	5	75	60	$1,400	55
D_0156	SW_0393	MICHIGAN AVE	17TH ST	18TH ST	Shattered Slab	5	5	25	60	$500	55
D_0117	SW_0722	MICHIGAN AVE	2ND ST	3RD ST	Shattered Slab	5	6	30	60	$500	55
D_0077	SW_0791	MICHIGAN AVE	15TH ST	16TH ST	Buckling	10	5	50	60	$900	55
D_0001	SW_0895	MICHIGAN AVE	17TH ST	18TH ST	Shattered Slab	5	5	25	60	$500	55
D_0143	SW_1409	MICHIGAN AVE	10TH ST	11TH ST	Other	15	5	75	60	$1,400	55
D_0329	SW_2780	MICHIGAN AVE	19TH ST	ALTON RD	Shattered Slab	20	8	160	60	$1,800	55
D_0378	SW_3034	MICHIGAN AVE	43RD ST	43RD CT	Shattered Slab	6	4	24	60	$600	55
D_0379	SW_3034	MICHIGAN AVE	43RD ST	43RD CT	Shattered Slab	6	4	24	60	$600	55
D_0019	SW_0884	NORMANDY DR	GRANVILLE CT	VERDUN DR	Shattered Slab	6	5	30	60	$600	55
D_0046	SW_1331	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Other	9	15	135	60	$900	55
D_0089	SW_0045	PURDY AVE	18TH ST	20TH ST	Other	2	5	10	60	$200	55
D_0018	SW_0559	RUE VERSAILLES	BAY DR	BIARRITZ DR	Buckling	10	6	60	60	$900	55
D_0268	SW_0505	SHERIDAN AVE	45TH ST	46TH XOVR	Shattered Slab	15	5	75	60	$1,400	55

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0068	SW_2062	VERDUN DR	VERDUN CT	MARSEILLE DR	Faulting	6	5	30	60	$600	55
D_0069	SW_2062	VERDUN DR	VERDUN CT	MARSEILLE DR	Faulting	6	5	30	60	$600	55
D_0097	SW_0062	WASHINGTON AVE	2ND ST	3RD ST	Shattered Slab	15	12	180	60	$1,400	55
D_0113	SW_0524	WASHINGTON AVE	POINTE CT	POINTE DR	Other	20	10	200	60	$1,800	55
D_0114	SW_0524	WASHINGTON AVE	POINTE CT	POINTE DR	Shattered Slab	5	10	50	60	$500	55
D_0088	SW_0056	WEST AVE	18TH ST	20TH ST	Spalling	20	7	140	60	$1,800	55
D_0183	SW_1334	WEST AVE	8TH ST	9TH ST	Shattered Slab	10	5	50	60	$900	55
D_0167	SW_1578	13TH ST	WASHINGTON AVE	DREXEL AVE	Shattered Slab	20	6	120	50	$1,800	124
D_0179	SW_0702	15TH ST	ALTON RD	ALTON CT	Shattered Slab	10	8	80	50	$900	124
D_0181	SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	Shattered Slab	10	6	60	50	$900	124
D_0188	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	Shattered Slab	35	6	210	50	$3,200	124
D_0186	SW_1867	18TH ST	COLLINS AVE	JAMES AVE	Other	10	7	70	50	$900	124
D_0187	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	Shattered Slab	30	8	240	50	$2,700	124
D_0166	SW_0021	20TH ST	WEST AVE	BAY RD	Shattered Slab	20	6	120	50	$1,800	124
D_0295	SW_2688	26TH ST	FLAMINGO PL	PINE TREE DR	Faulting	25	7	175	50	$2,300	124
D_0260	SW_2476	28TH ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	5	4	20	50	$500	124
D_0236	SW_1826	35TH ST	BOARD WALK	COLLINS AVE	Shattered Slab	20	5	100	50	$1,800	124
D_0214	SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	5	5	25	50	$500	124
D_0216	SW_2740	41ST ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	5	5	25	50	$500	124
D_0311	SW_2513	62ND ST	LA GORCE DR	ALTON RD	Shattered Slab	20	5	100	50	$1,800	124
D_0034	SW_1961	67TH ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	10	13	130	50	$900	124
D_0128	SW_0824	6TH ST	EUCLID CT	MERIDIAN AVE	Shattered Slab	20	7	140	50	$1,800	124
D_0139	SW_1238	6TH ST	MERIDIAN CT	JEFFERSON AVE	Shattered Slab	5	5	25	50	$500	124
D_0061	SW_0339	71ST ST	ABBOTT AVE	ABBOTT CT	Other	10	10	100	50	$900	124
D_0254	SW_2246	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Faulting	5	6	30	50	$500	124
D_0255	SW_2246	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Other	5	6	30	50	$500	124
D_0129	SW_0877	7TH ST	EUCLID CT	MERIDIAN AVE	Shattered Slab	25	4	100	50	$2,300	124
D_0032	SW_1387	80TH ST	COLLINS AVE	COLLINS CT	Shattered Slab	15	6	90	50	$1,400	124
D_0057	SW_1443	80TH ST	COLLINS AVE	COLLINS CT	Shattered Slab	10	5	50	50	$900	124

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0080	SW_1443	80TH ST	COLLINS AVE	COLLINS CT	Buckling	5	5	25	50	$500	124
D_0191	SW_1443	80TH ST	COLLINS AVE	COLLINS CT	Shattered Slab	10	5	50	50	$900	124
D_0391	SW_1502	80TH ST	HARDING AVE	ABBOTT AVE	Shattered Slab	15	5	75	50	$1,400	124
D_0008	SW_1300	81ST ST	COLLINS AVE	COLLINS CT	Shattered Slab	10	6	60	50	$900	124
D_0030	SW_1143	83RD ST	COLLINS AVE	COLLINS CT	Shattered Slab	10	5	50	50	$900	124
D_0090	SW_0068	ALTON RD	ALTON RD	18TH ST	Shattered Slab	10	7	70	50	$900	124
D_0153	SW_0196	ALTON RD	14TH CT	15TH ST	Spalling	15	8	120	50	$1,400	124
D_0154	SW_0196	ALTON RD	14TH CT	15TH ST	Shattered Slab	35	8	280	50	$3,200	124
D_0038	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Shattered Slab	8	6	48	50	$800	124
D_0042	SW_0686	BAY DR	BREST ESPLANADE	RUE VERSAILLES	Buckling	10	5	50	50	$900	124
D_0013	SW_2086	BAY DR	RUE GRANVILLE	NORMANDY DR	Shattered Slab	20	4	80	50	$1,800	124
D_0366	SW_2959	BAY RD	I 195	43RD ST	Shattered Slab	5	5	25	50	$500	124
D_0041	SW_0697	BIARRITZ DR	71ST ST	NORMANDY DR	Shattered Slab	8	6	48	50	$800	124
D_0015	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Shattered Slab	33	4	132	50	$3,000	124
D_0037	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Shattered Slab	18	4	72	50	$1,700	124
D_0321	SW_2539	CHASE AVE	34TH ST	ALTON RD	Shattered Slab	5	6	30	50	$500	124
D_0039	SW_0364	COLLINS AVE	82ND ST	83RD ST	Buckling	5	6	30	50	$500	124
D_0059	SW_0457	COLLINS AVE	79TH ST	80TH ST	Buckling	5	5	25	50	$500	124
D_0184	SW_1327	COLLINS AVE	17TH ST	18TH ST	Shattered Slab	5	11	55	50	$500	124
D_0071	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Shattered Slab	20	7	140	50	$1,800	124
D_0200	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Shattered Slab	20	7	140	50	$1,800	124
D_0202	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Shattered Slab	5	7	35	50	$500	124
D_0205	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Spalling	5	7	35	50	$500	124
D_0206	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Shattered Slab	10	7	70	50	$900	124
D_0072	SW_2003	COLLINS AVE	INDIAN CREEK DR	46TH ST	Shattered Slab	15	8	120	50	$1,400	124
D_0204	SW_2003	COLLINS AVE	INDIAN CREEK DR	46TH ST	Shattered Slab	5	8	40	50	$500	124
D_0207	SW_2400	COLLINS AVE	46TH ST	53RD ST	Shattered Slab	20	10	200	50	$1,800	124
D_0135	SW_1130	EUCLID AVE	6TH ST	7TH ST	Shattered Slab	30	5	150	50	$2,700	124
D_0133	SW_1159	EUCLID AVE	6TH ST	7TH ST	Spalling	10	5	50	50	$900	124

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0134	SW_1159	EUCLID AVE	6TH ST	7TH ST	Shattered Slab	30	5	150	50	$2,700	124
D_0003	SW_0718	HARDING AVE	67TH ST	69TH ST	Shattered Slab	15	6	90	50	$1,400	124
D_0079	SW_1055	HARDING AVE	85TH ST	84TH ST	Other	5	5	25	50	$500	124
D_0219	SW_0584	HAWTHORNE AVE	BAYSIDE LN	CRESPI BLVD	Spalling	5	5	25	50	$500	124
D_0220	SW_0584	HAWTHORNE AVE	BAYSIDE LN	CRESPI BLVD	Buckling	20	5	100	50	$1,800	124
D_0227	SW_0803	INDIAN CREEK DR	41ST ST	42ND ST	Shattered Slab	5	9	45	50	$500	124
D_0147	SW_1495	JEFFERSON AVE	6TH ST	7TH ST	Other	10	5	50	50	$900	124
D_0109	SW_0385	LENOX AVE	6TH ST	7TH ST	Shattered Slab	5	6	30	50	$500	124
D_0174	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	Shattered Slab	15	8	120	50	$1,400	124
D_0175	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	Shattered Slab	10	8	80	50	$900	124
D_0176	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	Shattered Slab	10	8	80	50	$900	124
D_0226	SW_0731	MARSEILLE DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Faulting	6	5	30	50	$600	124
D_0073	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Shattered Slab	6	5	30	50	$600	124
D_0074	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Shattered Slab	6	5	30	50	$600	124
D_0075	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Faulting	6	5	30	50	$600	124
D_0076	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Shattered Slab	6	5	30	50	$600	124
D_0140	SW_1287	MERIDIAN AVE	6TH ST	7TH ST	Buckling	10	6	60	50	$900	124
D_0141	SW_1287	MERIDIAN AVE	6TH ST	7TH ST	Buckling	10	6	60	50	$900	124
D_0222	SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Faulting	6	6	36	50	$600	124
D_0223	SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Faulting	6	6	36	50	$600	124
D_0063	SW_1246	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Shattered Slab	6	5	30	50	$600	124
D_0130	SW_0927	PENNSYLVANIA AVE	8TH ST	9TH ST	Faulting	10	5	50	50	$900	124
D_0168	SW_1737	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	Spalling	5	8	40	50	$500	124
D_0169	SW_1774	PENNSYLVANIA AVE	8TH ST	9TH ST	Shattered Slab	10	6	60	50	$900	124
D_0302	SW_2667	PINE TREE DR	SHERIDAN AVE	28TH ST	Shattered Slab	30	5	150	50	$2,700	124
D_0064	SW_1679	TATUM WATERWAY DR	77TH ST	78TH ST	Shattered Slab	20	5	100	50	$1,800	124
D_0092	SW_0080	WEST AVE	18TH ST	20TH ST	Shattered Slab	18	6	108	50	$1,700	124
D_0182	SW_1009	WEST AVE	12TH ST	13TH ST	Shattered Slab	10	7	70	50	$900	124
D_0335	SW_2829	23RD ST	ALTON RD	BAY RD	Shattered Slab	25	5	125	40	$2,300	203

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0259	SW_2433	28TH ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	5	5	25	40	$500	203
D_0115	SW_0680	2ND ST	JEFFERSON CT	MICHIGAN AVE	Shattered Slab	20	6	120	40	$1,800	203
D_0116	SW_0706	2ND ST	JEFFERSON AVE	JEFFERSON CT	Shattered Slab	5	5	25	40	$500	203
D_0252	SW_2204	31ST ST	COLLINS AVE	INDIAN CREEK DR	Shattered Slab	5	6	30	40	$500	203
D_0253	SW_2212	31ST ST	BOARD WALK	COLLINS AVE	Other	20	5	100	40	$1,800	203
D_0353	SW_2866	43RD CT	MERIDIAN AVE	ADAMS AVE	Buckling	10	4	40	40	$900	203
D_0339	SW_0534	51ST ST	ALTON RD	BAY RD	Buckling	5	5	25	40	$500	203
D_0324	SW_1103	51ST ST	LA GORCE DR	LAKEVIEW DR	Shattered Slab	10	5	50	40	$900	203
D_0340	SW_2530	51ST ST	ALTON RD	BAY RD	Spalling	5	5	25	40	$500	203
D_0278	SW_2295	54TH ST	PINE TREE DR	LA GORCE DR	Shattered Slab	20	5	100	40	$1,800	203
D_0288	SW_2520	54TH ST	ALTON RD	BAY RD	Buckling	10	5	50	40	$900	203
D_0273	SW_2049	58TH ST	PINE TREE DR	LA GORCE DR	Shattered Slab	5	6	30	40	$500	203
D_0274	SW_2083	58TH ST	PINE TREE DR	LA GORCE DR	Shattered Slab	5	4	20	40	$500	203
D_0285	SW_2713	63RD ST	PINE TREE DR	LA GORCE DR	Shattered Slab	5	5	25	40	$500	203
D_0217	SW_0442	71ST ST	TROUVILLE ESPLANADE	RUE BORDEAUX	Shattered Slab	6	5	30	40	$600	203
D_0201	SW_1797	71ST ST	BEACH WALK	COLLINS AVE	Other	6	9	54	40	$600	203
D_0047	SW_1322	73RD ST	DICKENS AVE	WAYNE AVE	Shattered Slab	15	5	75	40	$1,400	203
D_0026	SW_2414	73RD ST	CARLYLE AVE	DICKENS AVE	Shattered Slab	5	5	25	40	$500	203
D_0010	SW_1320	ABBOTT AVE	82ND ST	82ND TER	Other	20	6	120	40	$1,800	203
D_0371	SW_2984	ADAMS AVE	43RD CT	44TH CT	Shattered Slab	27	4	108	40	$2,500	203
D_0322	SW_0214	ALTON RD	BAY RD	29TH ST	Shattered Slab	10	9	90	40	$900	203
D_0346	SW_0464	ALTON RD	53RD ST	52ND ST	Buckling	10	5	50	40	$900	203
D_0304	SW_1406	ALTON RD	59TH ST	58TH ST	Shattered Slab	5	5	25	40	$500	203
D_0306	SW_1801	ALTON RD	60TH ST	59TH ST	Buckling	10	5	50	40	$900	203
D_0307	SW_2014	ALTON RD	62ND ST	60TH ST	Buckling	10	5	50	40	$900	203
D_0290	SW_2546	ALTON RD	56TH ST	54TH ST	Buckling	10	5	50	40	$900	203
D_0343	SW_2546	ALTON RD	56TH ST	54TH ST	Shattered Slab	15	5	75	40	$1,400	203
D_0291	SW_2663	ALTON RD	57TH ST	58TH ST	Buckling	15	4	60	40	$1,400	203
D_0292	SW_2680	ALTON RD	58TH ST	59TH ST	Shattered Slab	10	5	50	40	$900	203

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0293	SW_2680	ALTON RD	58TH ST	59TH ST	Shattered Slab	15	5	75	40	$1,400	203
D_0294	SW_2694	ALTON RD	59TH ST	60TH ST	Buckling	25	5	125	40	$2,300	203
D_0296	SW_2694	ALTON RD	59TH ST	60TH ST	Buckling	10	5	50	40	$900	203
D_0297	SW_2694	ALTON RD	59TH ST	60TH ST	Shattered Slab	10	5	50	40	$900	203
D_0327	SW_2770	ALTON RD	51ST ST	52ND ST	Shattered Slab	25	5	125	40	$2,300	203
D_0330	SW_2792	ALTON RD	54TH ST	56TH ST	Spalling	10	5	50	40	$900	203
D_0344	SW_2796	ALTON RD	57TH ST	56TH ST	Buckling	10	5	50	40	$900	203
D_0345	SW_2796	ALTON RD	57TH ST	56TH ST	Buckling	10	5	50	40	$900	203
D_0349	SW_2849	ALTON RD	60TH ST	62ND ST	Shattered Slab	30	5	150	40	$2,700	203
D_0350	SW_2849	ALTON RD	60TH ST	62ND ST	Buckling	10	5	50	40	$900	203
D_0368	SW_2972	ALTON RD	ALTON RD	44TH ST	Buckling	5	5	25	40	$500	203
D_0347	SW_3159	ALTON RD	48TH ST	LAKEVIEW DR	Shattered Slab	10	6	60	40	$900	203
D_0328	SW_2781	BARRY ST	MERIDIAN AVE	GARDEN AVE	Other	3	5	15	40	$300	203
D_0035	SW_2018	BAY DR	TROUVILLE ESPLANADE	WEST END	Shattered Slab	5	6	30	40	$500	203
D_0286	SW_2267	BAY RD	63RD ST	PINE TREE DR	Other	3	5	15	40	$300	203
D_0341	SW_2793	BAY RD	52ND ST	53RD ST	Shattered Slab	20	5	100	40	$1,800	203
D_0342	SW_2793	BAY RD	52ND ST	53RD ST	Shattered Slab	5	5	25	40	$500	203
D_0380	SW_3035	BAY RD	29TH ST	ALTON RD	Shattered Slab	30	5	150	40	$2,700	203
D_0258	SW_2293	COLLINS AVE	29TH ST	30TH ST	Spalling	10	9	90	40	$900	203
D_0161	SW_1226	EUCLID AVE	15TH ST	16TH ST	Shattered Slab	5	6	30	40	$500	203
D_0180	SW_0965	FLAMINGO WAY	WEST AVE	BAY RD	Shattered Slab	35	5	175	40	$3,200	203
D_0159	SW_0682	JEFFERSON AVE	15TH ST	16TH ST	Shattered Slab	20	5	100	40	$1,800	203
D_0314	SW_0471	LA GORCE DR	56TH ST	55TH ST	Shattered Slab	15	5	75	40	$1,400	203
D_0316	SW_2522	LA GORCE DR	54TH ST	53RD ST	Buckling	10	5	50	40	$900	203
D_0279	SW_2564	LA GORCE DR	56TH ST	55TH ST	Shattered Slab	5	5	25	40	$500	203
D_0312	SW_2630	LA GORCE DR	59TH ST	58TH ST	Buckling	20	5	100	40	$1,800	203
D_0280	SW_2647	LA GORCE DR	61ST ST	60TH ST	Shattered Slab	15	5	75	40	$1,400	203
D_0282	SW_2658	LA GORCE DR	62ND ST	61ST ST	Shattered Slab	15	5	75	40	$1,400	203
D_0283	SW_2658	LA GORCE DR	62ND ST	61ST ST	Shattered Slab	5	5	25	40	$500	203

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0284	SW_2697	LA GORCE DR	63RD ST	62ND ST	Buckling	10	5	50	40	$900	203
D_0313	SW_2721	LA GORCE DR	57TH ST	56TH ST	Spalling	10	5	50	40	$900	203
D_0025	SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Faulting	6	5	30	40	$600	203
D_0213	SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Spalling	6	5	30	40	$600	203
D_0132	SW_1060	MERIDIAN AVE	10TH ST	11TH ST	Buckling	20	5	100	40	$1,800	203
D_0142	SW_1408	MERIDIAN AVE	9TH ST	10TH ST	Faulting	5	5	25	40	$500	203
D_0152	SW_0133	MICHIGAN AVE	13TH ST	14TH ST	Shattered Slab	10	5	50	40	$900	203
D_0052	SW_3115	MICHIGAN AVE	12TH ST	13TH ST	Faulting	10	7	70	40	$900	203
D_0021	SW_1165	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Shattered Slab	4	5	20	40	$400	203
D_0045	SW_1165	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Shattered Slab	6	5	30	40	$600	203
D_0394	SW_1726	PARK AVE	22ND ST	23RD ST	Shattered Slab	25	7	175	40	$2,300	203
D_0301	SW_1002	PINE TREE DR	30TH ST	31ST ST	Spalling	12	5	60	40	$1,100	203
D_0308	SW_2208	PINE TREE DR	SHERIDAN AVE	25TH ST	Shattered Slab	15	6	90	40	$1,400	203
D_0287	SW_2313	PINE TREE DR	24TH TER	25TH ST	Shattered Slab	15	4	60	40	$1,400	203
D_0309	SW_2314	PINE TREE DR	25TH ST	24TH TER	Shattered Slab	30	6	180	40	$2,700	203
D_0337	SW_0462	PRAIRIE AVE	23RD ST	PRAIRIE AVE	Spalling	10	7	70	40	$900	203
D_0338	SW_0519	PRAIRIE AVE	DADE BLVD	23RD ST	Shattered Slab	15	5	75	40	$1,400	203
D_0338	SW_0519	PRAIRIE AVE	DADE BLVD	23RD ST	Shattered Slab	15	5	75	40	$1,400	203
D_0085	SW_0482	RUE NOTRE DAME	BAY DR	BIARRITZ DR	Shattered Slab	5	5	25	40	$500	203
D_0210	SW_2449	TROUVILLE ESPLANADE	MARSEILLE DR	NORMANDY DR	Faulting	6	6	36	40	$600	203
D_0211	SW_2449	TROUVILLE ESPLANADE	MARSEILLE DR	NORMANDY DR	Faulting	6	6	36	40	$600	203
D_0212	SW_2449	TROUVILLE ESPLANADE	MARSEILLE DR	NORMANDY DR	Faulting	6	6	36	40	$600	203
D_0369	SW_2977	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Faulting	6	7	42	40	$600	203
D_0370	SW_2977	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Buckling	25	7	175	40	$2,300	203
D_0185	SW_1535	24TH ST	PROMENADE ST	COLLINS AVE	Shattered Slab	10	12	120	30	$900	286
D_0256	SW_2285	30TH ST	COLLINS AVE	INDIAN CREEK DR	Other	10	5	50	30	$900	286
D_0257	SW_2285	30TH ST	COLLINS AVE	INDIAN CREEK DR	Other	5	5	25	30	$500	286
D_0299	SW_0490	35TH ST	FLAMINGO DR	PINE TREE DR	Shattered Slab	10	5	50	30	$900	286
D_0300	SW_0502	35TH ST	FLAMINGO DR	PINE TREE DR	Buckling	15	5	75	30	$1,400	286

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0221	SW_0598	43RD ST	COLLINS AVE	INDIAN CREEK DR	Other	10	6	60	30	$900	286
D_0360	SW_2921	44TH ST	ALTON RD	BAY RD	Other	5	5	25	30	$500	286
D_0320	SW_2549	51ST ST	51ST ST	ALTON RD	Buckling	10	4	40	30	$900	286
D_0203	SW_2056	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Shattered Slab	30	6	180	30	$2,700	286
D_0012	SW_1926	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Shattered Slab	15	5	75	30	$1,400	286
D_0334	SW_2821	BAY RD	21ST ST	23RD ST	Shattered Slab	10	5	50	30	$900	286
D_0374	SW_3006	BAY RD	21ST ST	23RD ST	Shattered Slab	40	5	200	30	$3,600	286
D_0385	SW_3046	BRIDGE RD	MAC ARTHUR CSWY	STAR ISLAND DR	Shattered Slab	5	6	30	30	$500	286
D_0048	SW_2020	BYRON AVE	82ND TER	84TH ST	Shattered Slab	5	6	30	30	$500	286
D_0050	SW_2424	CALAIS DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Faulting	6	5	30	30	$600	286
D_0358	SW_2896	DI LIDO DR	VENETIAN DI LIDO WAY	5TH DI LIDO TER	Shattered Slab	35	5	175	30	$3,200	286
D_0160	SW_1169	EUCLID AVE	ESPANOLA WAY	15TH ST	Shattered Slab	5	6	30	30	$500	286
D_0162	SW_1288	EUCLID AVE	16TH ST	LINCOLN LN	Shattered Slab	5	6	30	30	$500	286
D_0289	SW_2557	FLAMINGO PL	25TH ST	26TH ST	Faulting	20	4	80	30	$1,800	286
D_0218	SW_0571	HAWTHORNE AVE	CRESPI BLVD	79TH ST	Buckling	20	4	80	30	$1,800	286
D_0215	SW_2677	HAWTHORNE AVE	BISCAYNE POINT RD	82ND ST	Other	10	5	50	30	$900	286
D_0146	SW_1486	JEFFERSON AVE	7TH ST	8TH ST	Faulting	15	5	75	30	$1,400	286
D_0373	SW_2998	JEFFERSON AVE	44TH CT	46TH ST	Shattered Slab	6	4	24	30	$600	286
D_0323	SW_0677	LAKEVIEW DR	50TH ST	51ST ST	Spalling	5	4	20	30	$500	286
D_0049	SW_2309	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Shattered Slab	9	6	54	30	$900	286
D_0272	SW_1997	PINE TREE DR	51ST ST	47TH ST	Spalling	6	5	30	30	$600	286
D_0348	SW_2861	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Shattered Slab	70	5	350	30	$6,300	286
D_0364	SW_2945	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	Shattered Slab	55	5	275	30	$5,000	286
D_0066	SW_0721	STILLWATER DR	STILLWATER DR	WEST END	Shattered Slab	20	4	80	30	$1,800	286
D_0197	SW_1878	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	Shattered Slab	10	6	60	30	$900	286
D_0083	SW_2072	TROUVILLE ESPLANADE	TROUVILLE ESPLANADE	CALAIS DR	Shattered Slab	15	6	90	30	$1,400	286
D_0051	SW_2426	TROUVILLE ESPLANADE	CALAIS DR	MARSEILLE DR	Faulting	6	5	30	30	$600	286
D_0208	SW_2426	TROUVILLE ESPLANADE	CALAIS DR	MARSEILLE DR	Faulting	6	5	30	30	$600	286
D_0209	SW_2426	TROUVILLE ESPLANADE	CALAIS DR	MARSEILLE DR	Faulting	6	5	30	30	$600	286

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0359	SW_0617	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	Shattered Slab	20	7	140	30	$1,800	286
D_0361	SW_2943	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Buckling	30	5	150	30	$2,700	286
D_0362	SW_2928	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	Buckling	20	5	100	20	$1,800	322
D_0372	SW_2993	BAY RD	47TH ST	48TH ST	Shattered Slab	30	5	150	20	$2,700	322
D_0375	SW_3024	BAY RD	47TH ST	48TH ST	Shattered Slab	15	5	75	20	$1,400	322
D_0376	SW_3024	BAY RD	47TH ST	48TH ST	Shattered Slab	15	5	75	20	$1,400	322
D_0377	SW_3024	BAY RD	47TH ST	48TH ST	Shattered Slab	15	5	75	20	$1,400	322
D_0096	SW_0184	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Other	14	12	168	20	$1,300	322
D_0384	SW_3044	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	Buckling	10	8	80	20	$900	322
D_0386	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Shattered Slab	15	10	150	20	$1,400	322
D_0317	SW_2580	MERIDIAN AVE	23RD ST	28TH ST	Shattered Slab	25	5	125	20	$2,300	322
D_0318	SW_2109	PRAIRIE AVE	31ST ST	34TH ST	Shattered Slab	25	7	175	20	$2,300	322
D_0319	SW_2109	PRAIRIE AVE	31ST ST	34TH ST	Shattered Slab	15	7	105	20	$1,400	322
D_0264	SW_2357	PRAIRIE AVE	CHASE AVE	45TH ST	Shattered Slab	20	5	100	20	$1,800	322
D_0365	SW_2946	RIVO ALTO DR	1ST RIVO ALTO TER	2ND RIVO ALTO TER	Other	12	5	60	20	$1,100	322
D_0084	SW_0448	RUE BORDEAUX	BAY DR	BIARRITZ DR	Shattered Slab	20	5	100	20	$1,800	322
D_0305	SW_1736	SHERIDAN AVE	29TH ST	30TH ST	Buckling	20	5	100	20	$1,800	322
D_0298	SW_2738	CHASE AVE	34TH ST	CHASE AVE	Faulting	5	5	25	10	$500	337
D_0004	SW_0967	SHORE DR	BAY DR	FAIRWAY DR	Shattered Slab	15	5	75	10	$1,400	337
D_0054	SW_1092	SHORE DR	BAY DR	RAY ST	Shattered Slab	30	6	180	10	$2,700	337
D_0056	SW_1092	SHORE DR	BAY DR	RAY ST	Spalling	7	6	42	10	$700	337
D_0190	SW_1092	SHORE DR	BAY DR	RAY ST	Spalling	5	6	30	10	$500	337
D_0006	SW_1093	SHORE DR	BAY DR	RAY ST	Shattered Slab	12	6	72	10	$1,100	337
D_0029	SW_1093	SHORE DR	BAY DR	RAY ST	Shattered Slab	12	6	72	10	$1,100	337
D_0055	SW_1093	SHORE DR	BAY DR	RAY ST	Shattered Slab	33	6	198	10	$3,000	337
D_0009	SW_1144	SHORE DR	MITCHELL ST	SARAZEN ST	Buckling	24	5	120	10	$2,200	337
D_0031	SW_1291	SHORE DR	JONES ST	BIARRITZ DR	Shattered Slab	15	5	75	10	$1,400	337
D_0303	SW_1208	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	Shattered Slab	12	5	60	0	$1,100	347
D_0336	SW_0107	49TH ST	LAKEVIEW DR	CHEROKEE AVE	Buckling	5	5	25	0	$500	347

Distress Point ID	Sidewalk Segment ID	Street Name	Street From	Street To	Distress Type	Distress Length (ft)	Sidewalk Width (ft)	Repair Area (SF)	Priority Ranking Score	Cost	Rank
D_0351	SW_2854	4TH RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Other	6	5	30	0	$600	347
D_0356	SW_2879	8TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Shattered Slab	5	5	25	0	$500	347
D_0261	SW_2607	BISCAYNE POINT RD	CECIL ST	CLEVELAND RD	Shattered Slab	25	5	125	0	$2,300	347
D_0263	SW_2294	DAYTONIA RD	FOWLER ST	DAYTONIA RD	Shattered Slab	10	5	50	0	$900	347
D_0265	SW_2294	DAYTONIA RD	FOWLER ST	DAYTONIA RD	Shattered Slab	30	5	150	0	$2,700	347
D_0355	SW_2882	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	Shattered Slab	25	5	125	0	$2,300	347
D_0363	SW_2932	DI LIDO DR	1ST DI LIDO TER	2ND DI LIDO TER	Other	5	5	25	0	$500	347
D_0144	SW_1447	JEFFERSON AVE	8TH ST	9TH ST	Shattered Slab	5	4	20	0	$500	347
D_0145	SW_1447	JEFFERSON AVE	8TH ST	9TH ST	Shattered Slab	10	4	40	0	$900	347
D_0352	SW_2856	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	Shattered Slab	6	5	30	0	$600	347

Appendix C:
Curb Ramp Inventory and Condition



Kimley»Horn

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0277	SW_3065	10TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2031	SW_1005	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2072	SW_1005	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2073	SW_1005	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2095	SW_1025	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2112	SW_1015	10TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2146	SW_1015	10TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2165	SW_1025	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2183	SW_1035	10TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2209	SW_1025	10TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2232	SW_1035	10TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2260	SW_1035	10TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2561	SW_1132	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2624	SW_1132	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_3006	SW_0293	10TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_3666	SW_1133	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_3667	SW_1133	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4145	SW_1133	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4149	SW_0300	10TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4154	SW_1132	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4160	SW_0293	10TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4166	SW_1151	10TH ST	WEST AVE	WEST END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4177	SW_1133	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4182	SW_0306	10TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4201	SW_1170	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4211	SW_1151	10TH ST	WEST AVE	WEST END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4214	SW_0306	10TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4232	SW_0306	10TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4250	SW_1202	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Damaged	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4266	SW_0306	10TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4272	SW_1202	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4273	SW_1190	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4289	SW_1170	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4300	SW_1170	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4314	SW_1170	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4339	SW_1133	10TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4418	SW_1202	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4429	SW_1202	10TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4576	SW_1398	10TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4586	SW_1417	10TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4588	SW_1418	10TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4601	SW_1418	10TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4615	SW_1424	10TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4616	SW_1424	10TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4617	SW_1424	10TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4729	SW_1675	10TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4730	SW_1689	10TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4754	SW_1675	10TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4767	SW_0421	10TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4768	SW_1689	10TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4779	SW_0421	10TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4793	SW_1689	10TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4804	SW_0421	10TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4805	SW_3070	10TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4836	SW_3070	10TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4852	SW_0425	10TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4860	SW_0428	10TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4866	SW_0425	10TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4874	SW_0428	10TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4879	SW_3079	10TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4889	SW_3066	10TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4897	SW_3079	10TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4904	SW_3066	10TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4920	SW_0435	10TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4927	SW_0435	10TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4933	SW_3065	10TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0171	SW_0526	11TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0182	SW_0526	11TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0194	SW_0533	11TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1207	SW_0908	11TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1229	SW_0919	11TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1264	SW_0908	11TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1284	SW_0908	11TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1305	SW_0910	11TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1306	SW_0894	11TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1325	SW_0931	11TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1388	SW_0945	11TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1396	SW_0931	11TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1453	SW_0956	11TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1469	SW_0945	11TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1487	SW_0956	11TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1507	SW_0966	11TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2267	SW_1041	11TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2279	SW_1071	11TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2287	SW_1070	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2300	SW_1051	11TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2316	SW_1070	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2321	SW_1040	11TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2322	SW_1040	11TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2352	SW_1070	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2355	SW_1041	11TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2356	SW_1041	11TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2358	SW_1051	11TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2378	SW_1079	11TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2396	SW_1070	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2413	SW_1079	11TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2431	SW_1079	11TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2449	SW_1071	11TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3280	SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3288	SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4306	SW_0325	11TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4368	SW_0331	11TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4394	SW_0325	11TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4423	SW_0538	11TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4564	SW_1432	11TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4565	SW_1436	11TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4566	SW_1436	11TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4589	SW_1436	11TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4602	SW_1432	11TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4618	SW_1432	11TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4671	SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4672	SW_1658	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4693	SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4694	SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4702	SW_1657	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4734	SW_0526	11TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4737	SW_0533	11TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4739	SW_1658	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4750	SW_1658	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4751	SW_1658	11TH ST	WASHINGTON AVE	WASHINGTON CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4769	SW_0836	11TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4770	SW_0836	11TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4783	SW_0836	11TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4784	SW_0847	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4792	SW_0847	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4798	SW_0847	11TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0267	SW_0583	12TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0283	SW_0583	12TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0314	SW_0717	12TH ST	MICHIGAN AVE	12TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0331	SW_0717	12TH ST	MICHIGAN AVE	12TH ST	Flamingo/Lummus E	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0802	SW_0827	12TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0851	SW_0840	12TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0896	SW_0065	12TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0900	SW_0851	12TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0932	SW_0070	12TH ST	12TH ST	LENOX AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0961	SW_0065	12TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0979	SW_0862	12TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1000	SW_0870	12TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1050	SW_0870	12TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1081	SW_0861	12TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1085	SW_0863	12TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1120	SW_0863	12TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1158	SW_0863	12TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2128	SW_1010	12TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2189	SW_1010	12TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2212	SW_1010	12TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2224	SW_1010	12TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2244	SW_1050	12TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2298	SW_1050	12TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4538	SW_1611	12TH ST	12TH ST	PENNSYLVANIA AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4568	SW_1611	12TH ST	12TH ST	PENNSYLVANIA AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4621	SW_1602	12TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4633	SW_1602	12TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4645	SW_1618	12TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4662	SW_1637	12TH ST	DREXEL AVE	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4808	SW_0878	12TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4815	SW_1637	12TH ST	DREXEL AVE	12TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4822	SW_1637	12TH ST	DREXEL AVE	12TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4823	SW_0878	12TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4830	SW_0891	12TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4854	SW_0903	12TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4862	SW_0915	12TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4868	SW_0915	12TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4869	SW_0903	12TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0031	SW_0953	13TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0098	SW_0789	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0115	SW_0789	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0204	SW_0100	13TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0235	SW_0093	13TH ST	MICHIGAN AVE	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0313	SW_0789	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0360	SW_0779	13TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0464	SW_0768	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0562	SW_0799	13TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0591	SW_0789	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0642	SW_0799	13TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0695	SW_0114	13TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0706	SW_0808	13TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0724	SW_0109	13TH ST	MICHIGAN AVE	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1066	SW_0093	13TH ST	MICHIGAN AVE	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1192	SW_0093	13TH ST	MICHIGAN AVE	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1213	SW_0983	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1247	SW_0100	13TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1281	SW_0109	13TH ST	MICHIGAN AVE	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1300	SW_0114	13TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1354	SW_0114	13TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1982	SW_0954	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2016	SW_0954	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2035	SW_0954	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2079	SW_0983	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2116	SW_0983	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2150	SW_0983	13TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4416	SW_1541	13TH ST	DREXEL CT	PENNSYLVANIA AVE	Flamingo/Lummus F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4445	SW_1541	13TH ST	DREXEL CT	PENNSYLVANIA AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4460	SW_1553	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4472	SW_1541	13TH ST	DREXEL CT	PENNSYLVANIA AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4486	SW_1553	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4497	SW_1560	13TH ST	DREXEL CT	PENNSYLVANIA AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4509	SW_1578	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4510	SW_1560	13TH ST	DREXEL CT	PENNSYLVANIA AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4523	SW_1560	13TH ST	DREXEL CT	PENNSYLVANIA AVE	Flamingo/Lummus F	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4537	SW_1578	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4550	SW_1578	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Damaged	Not Adequate	Not Adequate	Not Adequate	Not Adequate		$2,500
R_4670	SW_0981	13TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4680	SW_0972	13TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4791	SW_0768	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4797	SW_0779	13TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4875	SW_0953	13TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4881	SW_0953	13TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4882	SW_0972	13TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4907	SW_0964	13TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4913	SW_0972	13TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4914	SW_0981	13TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4922	SW_0964	13TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_5011	SW_1553	13TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5131	SW_0761	13TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_5142	SW_0768	13TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5193	SW_0761	13TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1651	SW_0798	14TH CT	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1678	SW_0798	14TH CT	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1707	SW_0817	14TH CT	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1733	SW_0837	14TH CT	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1734	SW_0838	14TH CT	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1759	SW_0838	14TH CT	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4604	SW_1080	14TH PL	EUCLID AVE	EUCLID CT	Flamingo/Lummus D	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4620	SW_1069	14TH PL	EUCLID AVE	EUCLID CT	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5018	SW_1049	14TH PL	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5028	SW_1059	14TH PL	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5029	SW_1069	14TH PL	EUCLID AVE	EUCLID CT	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5030	SW_1059	14TH PL	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5032	SW_1080	14TH PL	EUCLID AVE	EUCLID CT	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4167	SW_1203	14th PLACE	OCEAN DR	OCEAN CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4237	SW_1203	14th PLACE	OCEAN DR	OCEAN CT	City Center B	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0557	SW_0175	14TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0558	SW_0157	14TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0576	SW_0164	14TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0613	SW_0147	14TH ST	MICHIGAN AVE	MICHIGAN CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1384	SW_0157	14TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1409	SW_0147	14TH ST	MICHIGAN AVE	MICHIGAN CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1448	SW_0147	14TH ST	MICHIGAN AVE	MICHIGAN CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1449	SW_0157	14TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1466	SW_0175	14TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1480	SW_2209	14TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1485	SW_0164	14TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1498	SW_2214	14TH ST	COLLINS AVE	COLLINS CT	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1504	SW_0164	14TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1540	SW_2214	14TH ST	COLLINS AVE	COLLINS CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1847	SW_0850	14TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1858	SW_0850	14TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1875	SW_0892	14TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1905	SW_0916	14TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1921	SW_0892	14TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1949	SW_0907	14TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1968	SW_0916	14TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1969	SW_0907	14TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2105	SW_1011	14TH ST	BAY RD	WEST END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2127	SW_1011	14TH ST	BAY RD	WEST END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2434	SW_1161	14TH ST	OCEAN CT	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2488	SW_1161	14TH ST	OCEAN CT	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2492	SW_1505	14TH ST	DREXEL AVE	DREXEL CT	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2580	SW_1171	14TH ST	OCEAN DR	OCEAN CT	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4286	SW_1488	14TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4332	SW_1488	14TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4333	SW_1505	14TH ST	DREXEL AVE	DREXEL CT	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4361	SW_1505	14TH ST	DREXEL AVE	DREXEL CT	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4373	SW_1524	14TH ST	DREXEL AVE	DREXEL CT	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4414	SW_1524	14TH ST	DREXEL AVE	DREXEL CT	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4428	SW_1513	14TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4644	SW_1026	14TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4867	SW_1012	14TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4880	SW_1027	14TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4915	SW_0994	14TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4935	SW_0994	14TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5001	SW_0994	14TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_5005	SW_1007	14TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5008	SW_1008	14TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_5009	SW_1008	14TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5010	SW_1007	14TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus F	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_5013	SW_1026	14TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5016	SW_1026	14TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus F	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_5046	SW_1488	14TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5050	SW_0693	14TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5052	SW_0694	14TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5065	SW_0693	14TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5076	SW_0703	14TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5088	SW_0694	14TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1981	SW_0995	14TH TER	WEST AVE	BAY RD	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2104	SW_0995	14TH TER	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0095	SW_1180	15TH ST	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0293	SW_1189	15TH ST	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0342	SW_0230	15TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0387	SW_0208	15TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0419	SW_0763	15TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0574	SW_0737	15TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0816	SW_0216	15TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1397	SW_2260	15TH ST	BEACH WALK	OCEAN DR	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1412	SW_0736	15TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1414	SW_0702	15TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1415	SW_0702	15TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1451	SW_0736	15TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1549	SW_2260	15TH ST	BEACH WALK	OCEAN DR	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1567	SW_0737	15TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1718	SW_2251	15TH ST	OCEAN DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1724	SW_0208	15TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1744	SW_2260	15TH ST	BEACH WALK	OCEAN DR	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1750	SW_0848	15TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1776	SW_0216	15TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1788	SW_2261	15TH ST	BEACH WALK	OCEAN DR	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1806	SW_0216	15TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1818	SW_2261	15TH ST	BEACH WALK	OCEAN DR	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1842	SW_0230	15TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1902	SW_0254	15TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1904	SW_0879	15TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1915	SW_2261	15TH ST	BEACH WALK	OCEAN DR	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1918	SW_0254	15TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1939	SW_0254	15TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1966	SW_0254	15TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	-	-	-	-	Under Construction		
R_2032	SW_0254	15TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2295	SW_1383	15TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2503	SW_1390	15TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2517	SW_1420	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2578	SW_1420	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2658	SW_1425	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3431	SW_0737	15TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_4144	SW_1425	15TH ST	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4389	SW_1227	15TH ST	OCEAN DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4427	SW_0780	15TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4471	SW_0763	15TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4606	SW_1227	15TH ST	OCEAN DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4647	SW_2251	15TH ST	OCEAN DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_5087	SW_1180	15TH ST	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_1283	SW_0651	15TH TER	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1302	SW_0676	15TH TER	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1303	SW_0676	15TH TER	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1304	SW_0676	15TH TER	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1323	SW_0653	15TH TER	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1324	SW_0692	15TH TER	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1387	SW_0692	15TH TER	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1595	SW_0760	15TH TER	WEST AVE	BAY RD	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1677	SW_0807	15TH TER	WEST AVE	BAY RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1706	SW_0807	15TH TER	WEST AVE	BAY RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0023	SW_0273	16TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0281	SW_0262	16TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0366	SW_0792	16TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0367	SW_0809	16TH ST	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0447	SW_0819	16TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0466	SW_0841	16TH ST	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0644	SW_2075	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0770	SW_2075	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0771	SW_1231	16TH ST	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0805	SW_2075	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0846	SW_2075	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0853	SW_2075	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0933	SW_1231	16TH ST	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0946	SW_2084	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1036	SW_1240	16TH ST	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_1140	SW_1250	16TH ST	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_1152	SW_0509	16TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1154	SW_0550	16TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1155	SW_0556	16TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_1156	SW_0552	16TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1157	SW_0556	16TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1193	SW_1259	16TH ST	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_1194	SW_0510	16TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1225	SW_0509	16TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1226	SW_0509	16TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1227	SW_0552	16TH ST	ALTON CT	WEST AVE	Flamingo/Lummus E	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_1282	SW_1240	16TH ST	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_1385	SW_1259	16TH ST	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_1506	SW_0743	16TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1920	SW_1317	16TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1940	SW_1317	16TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1967	SW_1317	16TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2005	SW_0262	16TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2053	SW_1325	16TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2114	SW_0273	16TH ST	LENOX CT	ALTON RD	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2147	SW_0279	16TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2166	SW_0288	16TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2185	SW_0288	16TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2211	SW_1354	16TH ST	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2233	SW_0288	16TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2506	SW_2084	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4267	SW_2084	16TH ST	COLLINS AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4320	SW_0509	16TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4340	SW_0550	16TH ST	ALTON RD	ALTON CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4372	SW_0819	16TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4426	SW_0841	16TH ST	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4444	SW_0809	16TH ST	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4458	SW_0792	16TH ST	JEFFERSON AVE	MICHIGAN AVE	Flamingo/Lummus D	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4493	SW_1325	16TH ST	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0001	SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0294	SW_1940	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0300	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0311	SW_3125	17TH ST	JACKIE GLEASON DR	DREXEL AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0325	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0344	SW_3125	17TH ST	JACKIE GLEASON DR	DREXEL AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0389	SW_1940	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0407	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0476	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0478	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0524	SW_0182	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0578	SW_1958	17TH ST	PENNSYLVANIA AVE	CONVENTION CENTER DR	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0580	SW_0182	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0581	SW_0182	17TH ST	ALTON CT	WEST AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0589	SW_0182	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0615	SW_1986	17TH ST	CONVENTION CENTER DR	MERIDIAN CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0628	SW_0182	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0629	SW_0182	17TH ST	ALTON CT	WEST AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0631	SW_0148	17TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0697	SW_1939	17TH ST	JACKIE GLEASON DR	DREXEL AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0704	SW_1986	17TH ST	CONVENTION CENTER DR	MERIDIAN CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0710	SW_0932	17TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0711	SW_0947	17TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0713	SW_0947	17TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0721	SW_0183	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0722	SW_0183	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0725	SW_0947	17TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0736	SW_1986	17TH ST	CONVENTION CENTER DR	MERIDIAN CT	City Center A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0796	SW_0183	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0814	SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0829	SW_2015	17TH ST	PENNSYLVANIA AVE	CONVENTION CENTER DR	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0832	SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0837	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0848	SW_1554	17TH ST	ALTON RD	ALTON CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0854	SW_0284	17TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0877	SW_2005	17TH ST	MERIDIAN CT	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0880	SW_2016	17TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0997	SW_2066	17TH ST	MERIDIAN CT	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0998	SW_0932	17TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1037	SW_2050	17TH ST	CONVENTION CENTER DR	MERIDIAN CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1038	SW_2066	17TH ST	MERIDIAN CT	MERIDIAN AVE	City Center A	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1141	SW_2066	17TH ST	MERIDIAN CT	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1699	SW_1379	17TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1708	SW_1379	17TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1709	SW_1393	17TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1725	SW_1379	17TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2576	SW_0356	17TH ST	MICHIGAN AVE	LENOX AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2620	SW_0344	17TH ST	LENOX CT	ALTON RD	City Center A	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2636	SW_0344	17TH ST	LENOX CT	ALTON RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2657	SW_0344	17TH ST	LENOX CT	ALTON RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_3610	SW_0386	17TH ST	LENOX AVE	LENOX CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3708	SW_1940	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4143	SW_0386	17TH ST	LENOX AVE	LENOX CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4153	SW_0386	17TH ST	LENOX AVE	LENOX CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4462	SW_1949	17TH ST	COLLINS AVE	JAMES AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4474	SW_1941	17TH ST	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4859	SW_1941	17TH ST	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4872	SW_1941	17TH ST	COLLINS AVE	JAMES AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4936	SW_1923	17TH ST	JACKIE GLEASON DR	DREXEL AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4983	SW_1561	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4988	SW_1561	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4990	SW_1561	17TH ST	ALTON CT	WEST AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4991	SW_0148	17TH ST	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5068	SW_1940	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_5074	SW_1941	17TH ST	COLLINS AVE	JAMES AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5075	SW_1940	17TH ST	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0181	SW_0023	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0193	SW_0028	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0219	SW_0028	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0230	SW_0028	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0633	SW_0918	18TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0698	SW_0918	18TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0709	SW_0957	18TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0761	SW_0987	18TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0762	SW_0987	18TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0763	SW_0997	18TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0787	SW_0997	18TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1025	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1072	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1086	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1101	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1113	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1161	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1635	SW_0072	18TH ST	ALTON RD	WEST AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1660	SW_0072	18TH ST	ALTON RD	WEST AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1680	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1761	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1795	SW_1404	18TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1809	SW_1405	18TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1810	SW_1404	18TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1820	SW_1404	18TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1830	SW_0023	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1861	SW_1405	18TH ST	JAMES AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1888	SW_0023	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2061	SW_0096	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2090	SW_0096	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2131	SW_0096	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2172	SW_0096	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2179	SW_0096	18TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2339	SW_0137	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2371	SW_0137	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2373	SW_0137	18TH ST	WEST AVE	BAY RD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3448	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3465	SW_1142	18TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4195	SW_0434	18TH ST	MICHIGAN AVE	LENOX AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4236	SW_0449	18TH ST	MICHIGAN AVE	LENOX AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4248	SW_0957	18TH ST	JEFFERSON AVE	MICHIGAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4774	SW_1875	18TH ST	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4788	SW_1867	18TH ST	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4794	SW_1867	18TH ST	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4835	SW_1875	18TH ST	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4865	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4878	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4887	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4895	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4896	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4902	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4919	SW_1965	18TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4974	SW_2139	18TH ST	DADE BLVD	ALTON RD	Lower North Bay Road A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4980	SW_2164	18TH ST	DADE BLVD	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5061	SW_2164	18TH ST	DADE BLVD	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0025	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0507	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0559	SW_2811	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0577	SW_2811	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0744	SW_0968	19TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0855	SW_1044	19TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0869	SW_1044	19TH ST	MERIDIAN AVE	JEFFERSON AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0939	SW_1073	19TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0970	SW_1073	19TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0971	SW_1073	19TH ST	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1848	SW_1477	19TH ST	PARK AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1941	SW_1441	19TH ST	JAMES AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1952	SW_1441	19TH ST	JAMES AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1953	SW_1441	19TH ST	JAMES AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1984	SW_1490	19TH ST	JAMES AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_3483	SW_1490	19TH ST	JAMES AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4117	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4124	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5097	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5098	SW_1272	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5100	SW_1272	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5104	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5108	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5110	SW_2809	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5125	SW_2811	19TH ST	MICHIGAN AVE	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3580	SW_2933	1ST DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3594	SW_2933	1ST DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3595	SW_2934	1ST DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3660	SW_2957	1ST RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3677	SW_2957	1ST RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3684	SW_2958	1ST RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0383	SW_0530	1ST ST	JEFFERSON AVE	MERIDIAN AVE	South Pointe D	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0653	SW_0530	1ST ST	JEFFERSON AVE	MERIDIAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1189	SW_0633	1ST ST	ALTON RD	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1210	SW_0652	1ST ST	JEFFERSON AVE	ALTON RD	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1244	SW_0652	1ST ST	JEFFERSON AVE	ALTON RD	South Pointe D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2180	SW_0470	1ST ST	WASHINGTON AVE	MERIDIAN AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2305	SW_0530	1ST ST	JEFFERSON AVE	MERIDIAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4230	SW_0240	1ST ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4253	SW_0303	1ST ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4264	SW_0240	1ST ST	OCEAN DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4277	SW_0235	1ST ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4278	SW_0303	1ST ST	COLLINS AVE	COLLINS CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4279	SW_0275	1ST ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4317	SW_0275	1ST ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4365	SW_0290	1ST ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4392	SW_0295	1ST ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4406	SW_0295	1ST ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4408	SW_0334	1ST ST	BEACH SVRD	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4421	SW_0295	1ST ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4438	SW_0334	1ST ST	BEACH SVRD	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4452	SW_1538	1ST ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4718	SW_0357	1ST ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4726	SW_1538	1ST ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4778	SW_0357	1ST ST	OCEAN CT	COLLINS AVE	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4961	SW_0431	1ST ST	MERIDIAN AVE	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5014	SW_0431	1ST ST	MERIDIAN AVE	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5022	SW_0431	1ST ST	MERIDIAN AVE	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5024	SW_0431	1ST ST	MERIDIAN AVE	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Not Adequate	Not Adequate	Not Adequate		$2,500
R_5058	SW_0470	1ST ST	WASHINGTON AVE	MERIDIAN AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5190	SW_0515	1ST ST	MERIDIAN AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0055	SW_0061	20TH ST	BAY RD	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0097	SW_0033	20TH ST	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0296	SW_0012	20TH ST	SUNSET DR	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0297	SW_0012	20TH ST	SUNSET DR	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0312	SW_0012	20TH ST	SUNSET DR	WEST AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0346	SW_0021	20TH ST	WEST AVE	BAY RD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0391	SW_0021	20TH ST	WEST AVE	BAY RD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0443	SW_0021	20TH ST	WEST AVE	BAY RD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0445	SW_1775	20TH ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0463	SW_0021	20TH ST	WEST AVE	BAY RD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0465	SW_1766	20TH ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0540	SW_0002	20TH ST	SUNSET DR	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0995	SW_0012	20TH ST	SUNSET DR	WEST AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1095	SW_0061	20TH ST	BAY RD	WEST AVE	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2064	SW_1492	20TH ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2156	SW_1517	20TH ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2192	SW_1883	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2202	SW_1866	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2213	SW_1517	20TH ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2401	SW_1629	20TH ST	PARK AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4648	SW_1766	20TH ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4686	SW_1766	20TH ST	COLLINS AVE	LIBERTY AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4765	SW_1866	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4775	SW_1866	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4776	SW_1866	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4795	SW_1866	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4803	SW_1883	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4813	SW_1883	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4820	SW_1883	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4827	SW_1883	20TH ST	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0739	SW_1717	21ST ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0803	SW_1707	21ST ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2289	SW_1589	21ST ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2303	SW_1785	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2337	SW_1759	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2345	SW_1669	21ST ST	PARK AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2362	SW_1589	21ST ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2568	SW_1660	21ST ST	PARK AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2606	SW_1669	21ST ST	PARK AVE	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2625	SW_1669	21ST ST	PARK AVE	WASHINGTON AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4553	SW_1690	21ST ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4571	SW_1707	21ST ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4636	SW_1717	21ST ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4657	SW_1759	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4666	SW_1785	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4676	SW_1785	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4697	SW_1785	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4724	SW_1785	21ST ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5188	SW_2819	21ST ST	ALTON RD	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1122	SW_1638	22ND ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1249	SW_1668	22ND ST	LIBERTY AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1337	SW_1619	22ND ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2416	SW_1682	22ND ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2435	SW_1698	22ND ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2514	SW_1639	22ND ST	LIBERTY AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2553	SW_1639	22ND ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2662	SW_1684	22ND ST	PARK AVE	WASHINGTON CT	City Center B	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2663	SW_1684	22ND ST	PARK AVE	WASHINGTON CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2699	SW_1718	22ND ST	PARK AVE	WASHINGTON CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4316	SW_1638	22ND ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4348	SW_1638	22ND ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4448	SW_1668	22ND ST	LIBERTY AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4526	SW_1682	22ND ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4527	SW_1682	22ND ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4582	SW_1698	22ND ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4594	SW_1698	22ND ST	MIAMI BEACH DR	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1508	SW_1588	23RD ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1539	SW_1569	23RD ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1566	SW_1588	23RD ST	COLLINS AVE	LIBERTY AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2507	SW_1476	23RD ST	PARK AVE	DADE BLVD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2525	SW_1489	23RD ST	LIBERTY AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2589	SW_1685	23RD ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2643	SW_1685	23RD ST	LIBERTY AVE	PARK AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2671	SW_1685	23RD ST	LIBERTY AVE	PARK AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2733	SW_1739	23RD ST	PARK AVE	DADE BLVD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_3691	SW_2488	23RD ST	PRAIRIE AVE	MERIDIAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3705	SW_2538	23RD ST	PRAIRIE AVE	MERIDIAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3730	SW_2538	23RD ST	PRAIRIE AVE	MERIDIAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_4227	SW_1569	23RD ST	COLLINS AVE	LIBERTY AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4238	SW_1579	23RD ST	COLLINS AVE	EAST END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4252	SW_1579	23RD ST	COLLINS AVE	EAST END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4276	SW_1588	23RD ST	COLLINS AVE	LIBERTY AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0924	SW_0678	24TH ST	PROMENADE ST	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0943	SW_0678	24TH ST	PROMENADE ST	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1621	SW_1535	24TH ST	PROMENADE ST	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2399	SW_1440	24TH ST	FLAMINGO DR	PINE TREE DR	Bayshore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2436	SW_1440	24TH ST	FLAMINGO DR	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2518	SW_2257	24TH ST	FLAMINGO DR	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2537	SW_2257	24TH ST	FLAMINGO DR	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2538	SW_2257	24TH ST	FLAMINGO DR	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2556	SW_2257	24TH ST	FLAMINGO DR	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_4071	SW_1535	24TH ST	PROMENADE ST	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4147	SW_1535	24TH ST	PROMENADE ST	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4179	SW_1535	24TH ST	PROMENADE ST	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2572	SW_2280	24TH TER	FLAMINGO PL	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2683	SW_2280	24TH TER	FLAMINGO PL	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2723	SW_2359	24TH TER	FLAMINGO DR	FLAMINGO PL	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0791	SW_2656	25TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0825	SW_2656	25TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2668	SW_2331	25TH ST	FLAMINGO PL	PINE TREE DR	Bayshore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2761	SW_2389	25TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2786	SW_2389	25TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2796	SW_2389	25TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2814	SW_2389	25TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2892	SW_2565	25TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3001	SW_2565	25TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_4059	SW_2735	25TH ST	PROMENADE ST	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4064	SW_2656	25TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_0663	SW_2577	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0676	SW_2577	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0690	SW_2577	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_0717	SW_2592	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0730	SW_2592	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2921	SW_2536	26TH ST	FLAMINGO PL	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2943	SW_2536	26TH ST	FLAMINGO PL	PINE TREE DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3058	SW_2579	26TH ST	FLAMINGO DR	FLAMINGO PL	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_4013	SW_1732	26TH ST	INDIAN CREEK DR	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4018	SW_2633	26TH ST	INDIAN CREEK DR	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4019	SW_2633	26TH ST	INDIAN CREEK DR	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4077	SW_2592	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4083	SW_2577	26TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4121	SW_1714	26TH ST	INDIAN CREEK DR	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3874	SW_2503	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3875	SW_2503	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3884	SW_2503	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3886	SW_2516	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3912	SW_2516	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3916	SW_2516	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3917	SW_2516	27TH ST	PROMENADE ST	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3949	SW_2591	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3968	SW_2591	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3982	SW_2591	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3987	SW_2606	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3991	SW_2606	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3997	SW_2606	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3998	SW_2606	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4093	SW_2591	27TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2746	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2754	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2763	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2797	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2845	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2872	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2884	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2893	SW_1483	28TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3285	SW_2691	28TH ST	FLAMINGO DR	PINE TREE DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3809	SW_2433	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3835	SW_2476	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3840	SW_2476	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3846	SW_2476	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3872	SW_2476	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3876	SW_2533	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3877	SW_2533	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3893	SW_2533	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3899	SW_2533	28TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0131	SW_2835	29TH ST	ALTON RD	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0132	SW_2835	29TH ST	ALTON RD	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1698	SW_2320	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3746	SW_2320	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3753	SW_2322	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3754	SW_2373	29TH ST	PROMENADE ST	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3774	SW_2322	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3782	SW_2415	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3801	SW_2432	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3806	SW_2432	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3807	SW_2443	29TH ST	COLLINS AVE	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3808	SW_2443	29TH ST	COLLINS AVE	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3814	SW_2420	29TH ST	PROMENADE ST	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3818	SW_2443	29TH ST	COLLINS AVE	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3823	SW_2432	29TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4015	SW_3021	29TH ST	BAY RD	LAKE AVE	Lower North Bay Road A	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3550	SW_2930	2ND DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3551	SW_2930	2ND DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3559	SW_2931	2ND DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3565	SW_2931	2ND DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3659	SW_2955	2ND RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3665	SW_2954	2ND RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3672	SW_2955	2ND RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0056	SW_0103	2ND ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0091	SW_0018	2ND ST	MICHIGAN AVE	ALTON RD	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1136	SW_2171	2ND ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1171	SW_0103	2ND ST	OCEAN DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1172	SW_0103	2ND ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1175	SW_2171	2ND ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1271	SW_0680	2ND ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1289	SW_0687	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1317	SW_0680	2ND ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1375	SW_0706	2ND ST	JEFFERSON AVE	JEFFERSON CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1400	SW_0687	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1446	SW_0706	2ND ST	JEFFERSON AVE	JEFFERSON CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1464	SW_0714	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1483	SW_0706	2ND ST	JEFFERSON AVE	JEFFERSON CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1502	SW_0706	2ND ST	JEFFERSON AVE	JEFFERSON CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1553	SW_0714	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1554	SW_0733	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1665	SW_0733	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2091	SW_0424	2ND ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_2109	SW_0433	2ND ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_2453	SW_0714	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2470	SW_0687	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4453	SW_0318	2ND ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4502	SW_0341	2ND ST	OCEAN DR	OCEAN CT	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4515	SW_0341	2ND ST	OCEAN DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4528	SW_0323	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4529	SW_0323	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4542	SW_0341	2ND ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4572	SW_1724	2ND ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4595	SW_0323	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4609	SW_0345	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_4627	SW_1724	2ND ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4677	SW_0345	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4687	SW_0345	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4758	SW_0349	2ND ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4777	SW_0345	2ND ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4829	SW_0714	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4845	SW_0687	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4861	SW_0687	2ND ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4873	SW_0424	2ND ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4912	SW_0424	2ND ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5023	SW_0433	2ND ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3622	SW_2285	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3638	SW_2254	30TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3655	SW_2274	30TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3663	SW_2274	30TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3675	SW_2274	30TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3687	SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3694	SW_2285	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3695	SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3697	SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3702	SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3703	SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3717	SW_2318	30TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3498	SW_2188	31ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3509	SW_2188	31ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3519	SW_2204	31ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3572	SW_2204	31ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3579	SW_2212	31ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3585	SW_2220	31ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3600	SW_2204	31ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3607	SW_2220	31ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3266	SW_2057	32ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3267	SW_2057	32ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3314	SW_2080	32ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3326	SW_2080	32ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3345	SW_2080	32ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3356	SW_2115	32ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3357	SW_2115	32ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3358	SW_2057	32ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3378	SW_2146	32ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3398	SW_2115	32ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2115	SW_2022	33RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3146	SW_1993	33RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3169	SW_1993	33RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3188	SW_1993	33RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3219	SW_1993	33RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3228	SW_2022	33RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3346	SW_2720	33RD ST	FLAMINGO DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2958	SW_1705	34TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3076	SW_1896	34TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3095	SW_1896	34TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3096	SW_1945	34TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3109	SW_1945	34TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3121	SW_1945	34TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3122	SW_1937	34TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3130	SW_1945	34TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3148	SW_2297	34TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3278	SW_2384	34TH ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3379	SW_0493	34TH ST	PRAIRIE AVE	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3473	SW_2573	34TH ST	PRAIRIE AVE	CHASE AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3490	SW_2594	34TH ST	CHASE AVE	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3500	SW_2594	34TH ST	CHASE AVE	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_4055	SW_0820	34TH ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4069	SW_0820	34TH ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4113	SW_2771	34TH ST	GARDEN AVE	ALTON RD	Bayshore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4937	SW_2771	34TH ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2096	SW_1783	35TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2844	SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2854	SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2855	SW_1783	35TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2868	SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2869	SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2870	SW_1826	35TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2901	SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2912	SW_1826	35TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3359	SW_3191	35TH ST	FLAMINGO DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3390	SW_0502	35TH ST	FLAMINGO DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3400	SW_0490	35TH ST	FLAMINGO DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3507	SW_1771	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3508	SW_1771	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3538	SW_1771	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3570	SW_1782	35TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3584	SW_1798	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_5158	SW_1771	35TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2234	SW_1731	36TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2296	SW_1721	36TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2319	SW_1721	36TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3265	SW_1648	36TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3302	SW_1664	36TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3387	SW_1648	36TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3409	SW_1721	36TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3426	SW_1721	36TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3444	SW_1664	36TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3496	SW_1745	36TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3506	SW_1745	36TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3518	SW_1731	36TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2676	SW_2332	37TH ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2684	SW_0529	37TH ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2714	SW_1208	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2770	SW_1208	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2805	SW_2471	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2806	SW_1357	37TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2841	SW_2471	37TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3123	SW_2619	37TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3145	SW_1352	37TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3156	SW_1352	37TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3227	SW_1352	37TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3235	SW_1415	37TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3244	SW_1397	37TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3253	SW_1415	37TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3254	SW_1415	37TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3275	SW_1455	37TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3283	SW_1455	37TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2999	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3013	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3014	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3015	SW_1235	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3023	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3025	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3035	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3046	SW_1235	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3047	SW_1235	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3056	SW_1209	38TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3075	SW_1616	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3094	SW_1235	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3107	SW_1209	38TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3108	SW_1285	38TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3120	SW_1235	38TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3178	SW_1285	38TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3196	SW_1285	38TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3208	SW_1285	38TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2551	SW_0991	39TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2900	SW_0991	39TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2911	SW_0991	39TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2937	SW_0991	39TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2997	SW_1148	39TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2998	SW_1148	39TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3026	SW_1127	39TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3036	SW_1127	39TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3074	SW_1127	39TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3343	SW_2561	39TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3784	SW_2623	39TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3794	SW_2298	39TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3984	SW_2298	39TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3992	SW_2623	39TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4956	SW_2791	39TH ST	GARDEN AVE	ALTON RD	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4969	SW_2791	39TH ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_5138	SW_2623	39TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5143	SW_2623	39TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3513	SW_2927	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3522	SW_2927	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3523	SW_2928	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3532	SW_2928	3RD DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1989	SW_2845	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2049	SW_3175	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2085	SW_2848	3RD RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0086	SW_2315	3RD ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0600	SW_2315	3RD ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0865	SW_0077	3RD ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0919	SW_0077	3RD ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1054	SW_0085	3RD ST	COLLINS AVE	COLLINS CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1096	SW_0085	3RD ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1173	SW_0090	3RD ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1176	SW_0090	3RD ST	COLLINS AVE	COLLINS CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1316	SW_0090	3RD ST	COLLINS AVE	COLLINS CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1436	SW_0143	3RD ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1463	SW_0143	3RD ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1500	SW_0150	3RD ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1582	SW_0150	3RD ST	OCEAN DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1606	SW_0165	3RD ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1641	SW_0740	3RD ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1666	SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1695	SW_0740	3RD ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1720	SW_0165	3RD ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1722	SW_0740	3RD ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1773	SW_0757	3RD ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1803	SW_0757	3RD ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1804	SW_0757	3RD ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1892	SW_0784	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1937	SW_0784	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1963	SW_0795	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2000	SW_0795	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2001	SW_0784	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2003	SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2022	SW_0795	3RD ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2029	SW_1003	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2111	SW_0804	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4256	SW_1003	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4308	SW_1003	3RD ST	MERIDIAN AVE	MERIDIAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0957	SW_2231	40TH ST	PRAIRIE CT	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0976	SW_2231	40TH ST	PRAIRIE CT	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0977	SW_2231	40TH ST	PRAIRIE CT	CHASE AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0992	SW_2231	40TH ST	PRAIRIE CT	CHASE AVE	Bayshore C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1334	SW_2304	40TH ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1382	SW_2304	40TH ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1688	SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1704	SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1714	SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1730	SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1731	SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1756	SW_2518	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1974	SW_2635	40TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1988	SW_2635	40TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1998	SW_2635	40TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2223	SW_2686	40TH ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2278	SW_2733	40TH ST	PRAIRIE CT	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2292	SW_2733	40TH ST	PRAIRIE CT	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2623	SW_0961	40TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2724	SW_0637	40TH ST	FLAMINGO DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2753	SW_2679	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2866	SW_0899	40TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2881	SW_0899	40TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2924	SW_0961	40TH ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2941	SW_2679	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2974	SW_2620	40TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3187	SW_2620	40TH ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3237	SW_2679	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3246	SW_2679	40TH ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3376	SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3386	SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3408	SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3417	SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3434	SW_2605	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3435	SW_2640	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3458	SW_2640	40TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3826	SW_2749	40TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3940	SW_2683	40TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3945	SW_2749	40TH ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0665	SW_0618	41ST ST	GARDEN AVE	I 195	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0692	SW_0618	41ST ST	GARDEN AVE	I 195	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0703	SW_0618	41ST ST	GARDEN AVE	I 195	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0754	SW_2785	41ST ST	JEFFERSON AVE	GARDEN AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0860	SW_2163	41ST ST	PRAIRIE AVE	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0925	SW_2163	41ST ST	PRAIRIE AVE	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0974	SW_1656	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0975	SW_1656	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1012	SW_1656	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1013	SW_1656	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1117	SW_1800	41ST ST	PINE TREE DR	PINE TREE DR	Nautilus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1129	SW_1828	41ST ST	PINE TREE DR	SHERIDAN AVE	Nautilus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1149	SW_1828	41ST ST	PINE TREE DR	SHERIDAN AVE	Nautilus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1150	SW_2719	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1530	SW_2719	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1592	SW_2704	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1771	SW_2511	41ST ST	INDIAN CREEK DR	PINE TREE DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1800	SW_2556	41ST ST	PINE TREE DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1814	SW_2556	41ST ST	PINE TREE DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1837	SW_2704	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1838	SW_2556	41ST ST	PINE TREE DR	PINE TREE DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1854	SW_2699	41ST ST	PINE TREE DR	SHERIDAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2100	SW_2704	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2102	SW_2719	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2144	SW_2704	41ST ST	SHERIDAN AVE	ROYAL PALM AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2160	SW_2719	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3144	SW_2515	41ST ST	INDIAN CREEK DR	PINE TREE DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3207	SW_2511	41ST ST	INDIAN CREEK DR	PINE TREE DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3443	SW_2692	41ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3485	SW_2692	41ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3504	SW_2692	41ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3516	SW_2692	41ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3546	SW_2740	41ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3569	SW_2740	41ST ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3634	SW_2511	41ST ST	INDIAN CREEK DR	PINE TREE DR	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3676	SW_2622	41ST ST	CHASE AVE	MERIDIAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3682	SW_2622	41ST ST	CHASE AVE	MERIDIAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3748	SW_2622	41ST ST	CHASE AVE	MERIDIAN AVE	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3762	SW_2622	41ST ST	CHASE AVE	MERIDIAN AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3854	SW_2559	41ST ST	MERIDIAN AVE	JEFFERSON AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3860	SW_2559	41ST ST	MERIDIAN AVE	JEFFERSON AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3867	SW_2559	41ST ST	MERIDIAN AVE	JEFFERSON AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3871	SW_0644	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3878	SW_2638	41ST ST	JEFFERSON AVE	GARDEN AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3882	SW_0644	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3890	SW_0644	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3897	SW_0644	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3900	SW_2638	41ST ST	JEFFERSON AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3903	SW_0644	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3905	SW_2638	41ST ST	JEFFERSON AVE	GARDEN AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3911	SW_0783	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3915	SW_0783	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3923	SW_0783	41ST ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3932	SW_2638	41ST ST	JEFFERSON AVE	GARDEN AVE	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4041	SW_3037	41ST ST	CHASE AVE	MERIDIAN AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4045	SW_3039	41ST ST	CHASE AVE	MERIDIAN AVE	Nautilus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4049	SW_3039	41ST ST	CHASE AVE	MERIDIAN AVE	Nautilus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4098	SW_1575	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4111	SW_1722	41ST ST	PRAIRIE AVE	CHASE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4116	SW_1722	41ST ST	PRAIRIE AVE	CHASE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4119	SW_1575	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4851	SW_1575	41ST ST	ROYAL PALM AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5102	SW_2810	41ST ST	GARDEN AVE	I 195	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_5107	SW_2810	41ST ST	GARDEN AVE	I 195	Bayshore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5120	SW_2810	41ST ST	GARDEN AVE	I 195	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0784	SW_2788	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0876	SW_2788	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0928	SW_2788	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0945	SW_2788	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0955	SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1048	SW_0173	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1076	SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1090	SW_1681	42ND ST	PINE TREE DR	SHERIDAN AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1205	SW_0173	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1219	SW_1955	42ND ST	PINE TREE DR	SHERIDAN AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1220	SW_1947	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1240	SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1260	SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1335	SW_0252	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1369	SW_0252	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1383	SW_0252	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1432	SW_3182	42ND ST	PINE TREE DR	PINE TREE DR	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1433	SW_0252	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1434	SW_0252	42ND ST	JEFFERSON AVE	NAUTILUS DR	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1445	SW_0281	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1478	SW_3182	42ND ST	PINE TREE DR	PINE TREE DR	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1497	SW_0281	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1548	SW_0281	42ND ST	MERIDIAN AVE	JEFFERSON AVE	Nautilus G	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1563	SW_3183	42ND ST	PINE TREE DR	PINE TREE DR	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1577	SW_3183	42ND ST	PINE TREE DR	PINE TREE DR	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_3418	SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3428	SW_1881	42ND ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3599	SW_0384	42ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3613	SW_0455	42ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3615	SW_0455	42ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3618	SW_0384	42ND ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3773	SW_0629	42ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3805	SW_0629	42ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3813	SW_0629	42ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3822	SW_0634	42ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3831	SW_0634	42ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3838	SW_0634	42ND ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5183	SW_2023	42ND ST	POST AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5197	SW_2023	42ND ST	POST AVE	PRAIRIE AVE	Nautilus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1564	SW_2866	43RD CT	MERIDIAN AVE	ADAMS AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2755	SW_2869	43RD CT	JEFFERSON AVE	MICHIGAN AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2764	SW_2869	43RD CT	JEFFERSON AVE	MICHIGAN AVE	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2789	SW_2869	43RD CT	JEFFERSON AVE	MICHIGAN AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3758	SW_2981	43RD CT	ADAMS AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0122	SW_0404	43RD ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0152	SW_2162	43RD ST	ROYAL PALM AVE	POST AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0167	SW_0426	43RD ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0207	SW_2247	43RD ST	ROYAL PALM AVE	POST AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1816	SW_0612	43RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1886	SW_0598	43RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2825	SW_2872	43RD ST	MICHIGAN AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2833	SW_2872	43RD ST	MICHIGAN AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3061	SW_2893	43RD ST	ALTON RD	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3090	SW_2893	43RD ST	ALTON RD	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3100	SW_2893	43RD ST	ALTON RD	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3138	SW_2903	43RD ST	MOUNT SINAI HOSPITAL PR	MOUNT SINAI HOSPITAL PR	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3150	SW_2899	43RD ST	ALTON RD	MOUNT SINAI HOSPITAL PR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3502	SW_0611	43RD ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3739	SW_0598	43RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3752	SW_0612	43RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3760	SW_0611	43RD ST	BOARD WALK	COLLINS AVE	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3772	SW_0612	43RD ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_1617	SW_2986	44TH CT	MERIDIAN AVE	ADAMS AVE	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1648	SW_2989	44TH CT	MERIDIAN AVE	ADAMS AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2959	SW_3029	44TH CT	MICHIGAN AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2977	SW_3031	44TH CT	NAUTILUS DR	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3749	SW_2975	44TH CT	NAUTILUS DR	ALTON RD	Nautilus F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3785	SW_2978	44TH CT	ADAMS AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3855	SW_2986	44TH CT	MERIDIAN AVE	ADAMS AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3868	SW_2989	44TH CT	MERIDIAN AVE	ADAMS AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3895	SW_2995	44TH CT	ADAMS AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3914	SW_2995	44TH CT	ADAMS AVE	JEFFERSON AVE	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3934	SW_3005	44TH CT	MICHIGAN AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3946	SW_2975	44TH CT	NAUTILUS DR	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4021	SW_3029	44TH CT	MICHIGAN AVE	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0246	SW_2286	44TH ST	POST AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0247	SW_2326	44TH ST	POST AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0264	SW_2312	44TH ST	ROYAL PALM AVE	POST AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0273	SW_2312	44TH ST	ROYAL PALM AVE	POST AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0355	SW_2388	44TH ST	ROYAL PALM AVE	POST AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1296	SW_1981	44TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1297	SW_1995	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1312	SW_1981	44TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1313	SW_1996	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1332	SW_2098	44TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1351	SW_1995	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1366	SW_2013	44TH ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1381	SW_2098	44TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1393	SW_2098	44TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1421	SW_2098	44TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3337	SW_2742	44TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3402	SW_2921	44TH ST	ALTON RD	BAY RD	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3583	SW_2742	44TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3830	SW_0635	44TH ST	COLLINS AVE	INDIAN CREEK DR	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5133	SW_2326	44TH ST	POST AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5139	SW_2286	44TH ST	POST AVE	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0153	SW_0438	45TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0310	SW_2485	45TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0320	SW_2374	45TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0398	SW_2374	45TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0416	SW_2421	45TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0425	SW_2421	45TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0473	SW_2485	45TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0486	SW_2421	45TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0535	SW_2485	45TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0750	SW_2626	45TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1077	SW_3179	45TH ST	PINE TREE DR	PINE TREE DR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1091	SW_3179	45TH ST	PINE TREE DR	PINE TREE DR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1133	SW_3180	45TH ST	PINE TREE DR	PINE TREE DR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1188	SW_3180	45TH ST	PINE TREE DR	PINE TREE DR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1406	SW_2106	45TH ST	PINE TREE DR	SHERIDAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1422	SW_2116	45TH ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1431	SW_2116	45TH ST	SHERIDAN AVE	ROYAL PALM AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3908	SW_2997	45TH ST	ALTON RD	BAY RD	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0502	SW_2434	46TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0702	SW_0574	46TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0729	SW_2646	46TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0766	SW_2646	46TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0843	SW_0574	46TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1715	SW_2910	46TH ST	MERIDIAN AVE	ADAMS AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3080	SW_2895	46TH ST	NAUTILUS DR	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3136	SW_2897	46TH ST	MICHIGAN AVE	NAUTILUS CT	Nautilus F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3201	SW_2911	46TH ST	ADAMS AVE	JEFFERSON AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3248	SW_2911	46TH ST	ADAMS AVE	JEFFERSON AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3279	SW_2913	46TH ST	JEFFERSON AVE	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3777	SW_3019	46TH ST	NAUTILUS DR	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1999	SW_2844	47TH CT	48TH ST	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2027	SW_2847	47TH CT	MICHIGAN AVE	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2103	SW_2847	47TH CT	MICHIGAN AVE	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0520	SW_2526	47TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0553	SW_0627	47TH ST	PINE TREE DR	47TH CT	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0606	SW_2526	47TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0624	SW_2526	47TH ST	POST AVE	PRAIRIE AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0873	SW_0586	47TH ST	ROYAL PALM AVE	POST AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0893	SW_0592	47TH ST	PRAIRIE AVE	MERIDIAN AVE	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0908	SW_0608	47TH ST	PRAIRIE AVE	MERIDIAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1828	SW_2805	47TH ST	MERIDIAN AVE	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1839	SW_2805	47TH ST	MERIDIAN AVE	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1856	SW_2805	47TH ST	MERIDIAN AVE	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1901	SW_2841	47TH ST	MERIDIAN AVE	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1930	SW_2841	47TH ST	MERIDIAN AVE	MICHIGAN AVE	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2823	SW_2874	47TH ST	MICHIGAN AVE	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3004	SW_3161	47TH ST	MICHIGAN AVE	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3005	SW_2886	47TH ST	MICHIGAN AVE	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3019	SW_3163	47TH ST	MICHIGAN AVE	ALTON RD	Nautilus F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3768	SW_2979	47TH ST	ALTON RD	BAY RD	Nautilus D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2407	SW_2859	48TH ST	47TH CT	ALTON RD	Nautilus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2464	SW_2859	48TH ST	47TH CT	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2500	SW_2859	48TH ST	47TH CT	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2519	SW_2859	48TH ST	47TH CT	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2543	SW_2859	48TH ST	47TH CT	ALTON RD	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2575	SW_2859	48TH ST	47TH CT	ALTON RD	Nautilus F	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_3849	SW_2987	48TH ST	ALTON RD	BAY RD	Nautilus D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3464	SW_2924	4TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3474	SW_2924	4TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3493	SW_2925	4TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3501	SW_2925	4TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2145	SW_2852	4TH RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2162	SW_2852	4TH RIVO ALTO TER	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0107	SW_0046	4TH ST	OCEAN DR	EAST END	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0221	SW_0073	4TH ST	OCEAN DR	EAST END	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0231	SW_0073	4TH ST	OCEAN DR	EAST END	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0257	SW_0073	4TH ST	OCEAN DR	EAST END	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0259	SW_3127	4TH ST	MICHIGAN AVE	MICHIGAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0278	SW_0030	4TH ST	MICHIGAN AVE	MICHIGAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0384	SW_0681	4TH ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0385	SW_0688	4TH ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0386	SW_0681	4TH ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0429	SW_0688	4TH ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0598	SW_0046	4TH ST	OCEAN DR	EAST END	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0599	SW_0046	4TH ST	OCEAN DR	EAST END	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0646	SW_0030	4TH ST	MICHIGAN AVE	MICHIGAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0682	SW_0041	4TH ST	LENOX AVE	ALTON RD	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0815	SW_0048	4TH ST	LENOX AVE	ALTON RD	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0864	SW_0048	4TH ST	LENOX AVE	ALTON RD	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0948	SW_0054	4TH ST	MICHIGAN AVE	MICHIGAN CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0982	SW_0054	4TH ST	MICHIGAN AVE	MICHIGAN CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1053	SW_0054	4TH ST	MICHIGAN AVE	MICHIGAN CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1499	SW_0138	4TH ST	COLLINS CT	WASHINGTON AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1519	SW_0154	4TH ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1636	SW_0154	4TH ST	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1871	SW_0785	4TH ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1916	SW_0200	4TH ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1976	SW_0200	4TH ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1977	SW_2718	4TH ST	JEFFERSON AVE	JEFFERSON CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2020	SW_0236	4TH ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2039	SW_2681	4TH ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2069	SW_2681	4TH ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2134	SW_0913	4TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2135	SW_1128	4TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2154	SW_0236	4TH ST	OCEAN DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2155	SW_3013	4TH ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2204	SW_3013	4TH ST	OCEAN CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2286	SW_1128	4TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2411	SW_1117	4TH ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2566	SW_1117	4TH ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2618	SW_1094	4TH ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2654	SW_1106	4TH ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4162	SW_1094	4TH ST	EUCLID AVE	EUCLID CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4173	SW_1078	4TH ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4234	SW_1047	4TH ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4467	SW_1128	4TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4468	SW_1078	4TH ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4505	SW_1047	4TH ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4518	SW_1047	4TH ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4519	SW_2718	4TH ST	JEFFERSON AVE	JEFFERSON CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4533	SW_1047	4TH ST	JEFFERSON CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4560	SW_1106	4TH ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4585	SW_1078	4TH ST	MERIDIAN CT	JEFFERSON AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4614	SW_1117	4TH ST	EUCLID AVE	EUCLID CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4642	SW_1094	4TH ST	EUCLID AVE	EUCLID CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3775	SW_2730	51ST ST	LAKEVIEW DR	LAKEVIEW DR	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_3781	SW_0443	51ST ST	LAKEVIEW DR	BLACK HAWK AVE	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_3783	SW_0443	51ST ST	LAKEVIEW DR	BLACK HAWK AVE	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_3793	SW_0456	51ST ST	BLACK HAWK AVE	CHEROKEE AVE	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_3810	SW_0456	51ST ST	BLACK HAWK AVE	CHEROKEE AVE	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_3819	SW_2155	51ST ST	CHEROKEE AVE	51ST ST	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4099	SW_0057	51ST ST	CHEROKEE AVE	51ST ST	Lakeview A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0752	SW_2757	52ND ST	ALTON RD	BAY RD	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0768	SW_2758	52ND ST	ALTON RD	BAY RD	La Gorce C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1600	SW_2386	52ND ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1647	SW_2386	52ND ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1659	SW_2438	52ND ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1687	SW_2438	52ND ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3742	SW_2587	52ND ST	LA GORCE DR	WEST END	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0783	SW_2786	53RD ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0863	SW_2802	53RD ST	ALTON RD	BAY RD	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1423	SW_2339	53RD ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1444	SW_2339	53RD ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1477	SW_2351	53RD ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1515	SW_2351	53RD ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_4940	SW_1388	53RD ST	EAST END	ALTON RD	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0958	SW_2823	54TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_1203	SW_2278	54TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1333	SW_2278	54TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1352	SW_2295	54TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1368	SW_2295	54TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_2957	SW_2520	54TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0956	SW_2245	55TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1031	SW_2245	55TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1062	SW_2266	55TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1108	SW_2266	55TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0894	SW_2198	56TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0910	SW_2198	56TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0911	SW_2206	56TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0912	SW_2206	56TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1032	SW_0166	56TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_1110	SW_0213	56TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3640	SW_2727	56TH ST	LA GORCE DR	WEST END	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0751	SW_2114	57TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0792	SW_2114	57TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0794	SW_2127	57TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0874	SW_2127	57TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1134	SW_2803	57TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_1204	SW_3158	57TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3586	SW_2682	57TH ST	LA GORCE DR	WEST END	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3593	SW_2689	57TH ST	LA GORCE DR	WEST END	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0649	SW_2049	58TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0664	SW_2049	58TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0677	SW_2083	58TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0731	SW_2083	58TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_1395	SW_0271	58TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_2832	SW_0277	58TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0571	SW_1539	59TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0588	SW_1539	59TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0607	SW_1983	59TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0639	SW_1983	59TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_2903	SW_1532	59TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_2928	SW_1650	59TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_2697	SW_0466	5TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2715	SW_0466	5TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2725	SW_0546	5TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2730	SW_0546	5TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0110	SW_0715	5TH ST	WASHINGTON AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0493	SW_0445	5TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0505	SW_0723	5TH ST	COLLINS CT	COLLINS AVE	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0542	SW_3063	5TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0575	SW_0715	5TH ST	WASHINGTON AVE	COLLINS CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0654	SW_0741	5TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0684	SW_0741	5TH ST	WASHINGTON AVE	EUCLID AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0817	SW_0758	5TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1018	SW_0064	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1097	SW_0064	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1178	SW_0064	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1267	SW_0099	5TH ST	MICHIGAN CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1287	SW_0083	5TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1315	SW_0099	5TH ST	MICHIGAN CT	MICHIGAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1398	SW_0099	5TH ST	MICHIGAN CT	MICHIGAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1661	SW_0270	5TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1692	SW_0260	5TH ST	OCEAN CT	OCEAN DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2208	SW_0833	5TH ST	EUCLID AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2340	SW_0255	5TH ST	COLLINS AVE	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2393	SW_0255	5TH ST	COLLINS AVE	OCEAN CT	South Pointe A	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2410	SW_0260	5TH ST	OCEAN CT	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2419	SW_0270	5TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2438	SW_0566	5TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2469	SW_0566	5TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2483	SW_0876	5TH ST	EUCLID CT	EUCLID AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2511	SW_0876	5TH ST	EUCLID CT	EUCLID AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2619	SW_1188	5TH ST	MERIDIAN AVE	MERIDIAN CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2621	SW_1188	5TH ST	MERIDIAN AVE	MERIDIAN CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2656	SW_1188	5TH ST	MERIDIAN AVE	MERIDIAN CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3024	SW_1200	5TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3031	SW_1200	5TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3042	SW_1200	5TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3073	SW_1200	5TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3309	SW_3063	5TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_3629	SW_1188	5TH ST	MERIDIAN AVE	MERIDIAN CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4016	SW_1200	5TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4082	SW_0939	5TH ST	MERIDIAN CT	MERIDIAN AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4139	SW_0939	5TH ST	MERIDIAN CT	MERIDIAN AVE	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4296	SW_1014	5TH ST	MICHIGAN AVE	JEFFERSON CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4355	SW_1014	5TH ST	MICHIGAN AVE	JEFFERSON CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4395	SW_1014	5TH ST	MICHIGAN AVE	JEFFERSON CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4558	SW_0410	5TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4584	SW_0410	5TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4613	SW_0758	5TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4848	SW_1416	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4856	SW_1416	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4909	SW_1416	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4917	SW_1416	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4924	SW_0064	5TH ST	MAC ARTHUR CSWY	LENOX AVE	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0522	SW_0624	60TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0536	SW_0624	60TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0554	SW_0670	60TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0570	SW_0670	60TH ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_2989	SW_1890	60TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3018	SW_1908	60TH ST	ALTON RD	BAY RD	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0321	SW_0570	61ST ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0426	SW_0570	61ST ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0440	SW_0596	61ST ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0474	SW_0596	61ST ST	PINE TREE DR	LA GORCE DR	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0011	SW_2713	63RD ST	PINE TREE DR	LA GORCE DR	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0030	SW_0365	63RD ST	AQUA AVE	PINE TREE DR	Allison Island B	Good	Adequate	Adequate	Adequate	Adequate		
R_0039	SW_0365	63RD ST	AQUA AVE	PINE TREE DR	Allison Island B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0052	SW_0365	63RD ST	AQUA AVE	PINE TREE DR	Allison Island B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0066	SW_0365	63RD ST	AQUA AVE	PINE TREE DR	Allison Island B	Good	Adequate	Adequate	Adequate	Adequate		
R_0082	SW_0380	63RD ST	INDIAN CREEK DR	AQUA AVE	Allison Island B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0169	SW_0454	63RD ST	PINE TREE DR	AQUA AVE	Allison Island A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0178	SW_0430	63RD ST	INDIAN CREEK DR	AQUA AVE	Allison Island A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0209	SW_0508	63RD ST	PINE TREE DR	AQUA AVE	Allison Island A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0217	SW_0454	63RD ST	PINE TREE DR	AQUA AVE	Allison Island A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2067	SW_2701	63RD ST	LA GORCE DR	PINE TREE DR	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_2123	SW_2701	63RD ST	LA GORCE DR	PINE TREE DR	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3214	SW_2149	63RD ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_3261	SW_2165	63RD ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3262	SW_2165	63RD ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_3286	SW_2377	63RD ST	LA GORCE DR	ALTON RD	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3294	SW_2377	63RD ST	LA GORCE DR	ALTON RD	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3298	SW_2210	63RD ST	INDIAN CREEK DR	COLLINS AVE	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3310	SW_2210	63RD ST	INDIAN CREEK DR	COLLINS AVE	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3334	SW_2210	63RD ST	INDIAN CREEK DR	COLLINS AVE	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3375	SW_2200	63RD ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3406	SW_2210	63RD ST	INDIAN CREEK DR	COLLINS AVE	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_3668	SW_2323	63RD ST	INDIAN CREEK DR	AQUA AVE	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_3673	SW_2327	63RD ST	INDIAN CREEK DR	AQUA AVE	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_3689	SW_2327	63RD ST	INDIAN CREEK DR	AQUA AVE	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_4226	SW_2200	63RD ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3092	SW_2077	65TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3104	SW_2093	65TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3164	SW_2093	65TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_4275	SW_2077	65TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4376	SW_2077	65TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0088	SW_0712	67TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0105	SW_0712	67TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_2949	SW_1961	67TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore E	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2968	SW_1961	67TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_4431	SW_0712	67TH ST	COLLINS AVE	INDIAN CREEK DR	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0002	SW_0025	69TH ST	COLLINS AVE	HARDING AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_0015	SW_0025	69TH ST	COLLINS AVE	HARDING AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0032	SW_0025	69TH ST	COLLINS AVE	HARDING AVE	North Shore E	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1562	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1575	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1599	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1614	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1629	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1631	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1646	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1671	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1686	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1703	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1713	SW_1936	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1769	SW_1953	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1785	SW_1953	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1813	SW_1953	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1836	SW_1953	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1851	SW_1953	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1884	SW_1953	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_1973	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1997	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_2011	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2025	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2045	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2047	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_2066	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3678	SW_2344	69TH ST	HARDING AVE	ABBOTT AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3709	SW_2335	69TH ST	HARDING AVE	ABBOTT AVE	North Shore E	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3722	SW_2335	69TH ST	HARDING AVE	ABBOTT AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3735	SW_2344	69TH ST	HARDING AVE	ABBOTT AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3902	SW_2481	69TH ST	INDIAN CREEK DR	WEST END	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3910	SW_2481	69TH ST	INDIAN CREEK DR	WEST END	North Shore E	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3936	SW_2531	69TH ST	BYRON AVE	INDIAN CREEK DR	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3942	SW_2531	69TH ST	BYRON AVE	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_4088	SW_0343	69TH ST	ABBOTT AVE	BYRON AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4447	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4488	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4524	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4552	SW_2037	69TH ST	BEACH WALK	COLLINS AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4593	SW_1885	69TH ST	COLLINS AVE	HARDING AVE	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5007	SW_0346	69TH ST	ABBOTT AVE	BYRON AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_2747	SW_0698	6TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2771	SW_0698	6TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2778	SW_2588	6TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2798	SW_2588	6TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0070	SW_3076	6TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0073	SW_0305	6TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0261	SW_0765	6TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0886	SW_3114	6TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0918	SW_3114	6TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0985	SW_0805	6TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1023	SW_0786	6TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1033	SW_0824	6TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1065	SW_0824	6TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1099	SW_0805	6TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1191	SW_0824	6TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1373	SW_0113	6TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1374	SW_0113	6TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1437	SW_3064	6TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1462	SW_0124	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1481	SW_0113	6TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1501	SW_0124	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1552	SW_0119	6TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1584	SW_0119	6TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1585	SW_0124	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1607	SW_0396	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1640	SW_0140	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1664	SW_0140	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2545	SW_0286	6TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2546	SW_3064	6TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2633	SW_0296	6TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2653	SW_2685	6TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3308	SW_3077	6TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_3341	SW_3076	6TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3362	SW_3077	6TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4164	SW_1238	6TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4170	SW_0319	6TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4171	SW_0319	6TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4174	SW_1238	6TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4175	SW_1230	6TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4176	SW_1230	6TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4184	SW_1230	6TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4185	SW_1239	6TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4186	SW_1238	6TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4187	SW_1258	6TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4196	SW_1238	6TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4197	SW_1239	6TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4198	SW_1258	6TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4206	SW_0305	6TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4209	SW_1239	6TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4532	SW_0396	6TH ST	MICHIGAN CT	LENOX AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4622	SW_1366	6TH ST	ALTON RD	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_4646	SW_1366	6TH ST	ALTON RD	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4655	SW_1366	6TH ST	ALTON RD	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4664	SW_1366	6TH ST	ALTON RD	WEST AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0007	SW_0969	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0008	SW_1186	71ST ST	INDIAN CREEK DR	BONITA DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0019	SW_0969	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0049	SW_3152	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0118	SW_0969	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0126	SW_0969	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0199	SW_0713	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0213	SW_0713	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0216	SW_1302	71ST ST	RUE NOTRE DAME	VICHY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0244	SW_1302	71ST ST	RUE NOTRE DAME	VICHY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0271	SW_1380	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0307	SW_2354	71ST ST	BIARRITZ DR	GRANVILLE CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0308	SW_1380	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0374	SW_0829	71ST ST	RUE VENDOME	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0424	SW_3147	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1418	SW_1914	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1429	SW_2253	71ST ST	GRANVILLE CT	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1493	SW_1797	71ST ST	BEACH WALK	COLLINS AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_1513	SW_1811	71ST ST	BEACH WALK	COLLINS AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_1602	SW_2632	71ST ST	BONITA DR	NORMANDY DR	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1754	SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1835	SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1865	SW_2194	71ST ST	BIARRITZ DR	GRANVILLE CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1887	SW_2632	71ST ST	BONITA DR	NORMANDY DR	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1910	SW_2194	71ST ST	BIARRITZ DR	GRANVILLE CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1925	SW_2253	71ST ST	GRANVILLE CT	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1972	SW_2301	71ST ST	GRANVILLE CT	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2018	SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2024	SW_2632	71ST ST	BONITA DR	NORMANDY DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2037	SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2065	SW_2624	71ST ST	BONITA DR	NORMANDY DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2082	SW_2354	71ST ST	BIARRITZ DR	GRANVILLE CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2215	SW_2416	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2217	SW_2423	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2644	SW_1806	71ST ST	COLLINS AVE	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2680	SW_1806	71ST ST	COLLINS AVE	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2690	SW_1807	71ST ST	COLLINS AVE	HARDING AVE	North Shore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2692	SW_1807	71ST ST	COLLINS AVE	HARDING AVE	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3289	SW_2159	71ST ST	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3515	SW_2270	71ST ST	HARDING AVE	HARDING CT	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3535	SW_2270	71ST ST	HARDING AVE	HARDING CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3536	SW_2288	71ST ST	HARDING CT	ABBOTT AVE	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3539	SW_2302	71ST ST	RUE NOTRE DAME	VICHY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3545	SW_0442	71ST ST	TROUVILLE ESPLANADE	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3548	SW_2302	71ST ST	RUE NOTRE DAME	VICHY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3556	SW_2246	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3571	SW_2246	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3577	SW_2246	71ST ST	RUE BORDEAUX	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3605	SW_2288	71ST ST	HARDING CT	ABBOTT AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3611	SW_2307	71ST ST	HARDING CT	ABBOTT AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3635	SW_2308	71ST ST	HARDING AVE	HARDING CT	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3669	SW_0564	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3680	SW_2423	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3685	SW_2423	71ST ST	RUE GRANVILLE	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3711	SW_2302	71ST ST	RUE NOTRE DAME	VICHY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3853	SW_2502	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3859	SW_2502	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3885	SW_2502	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3892	SW_2502	71ST ST	VICHY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3898	SW_2534	71ST ST	VERSAILLES CT	RUE VENDOME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3939	SW_2534	71ST ST	VERSAILLES CT	RUE VENDOME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3953	SW_2534	71ST ST	VERSAILLES CT	RUE VENDOME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3962	SW_2624	71ST ST	BONITA DR	NORMANDY DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3986	SW_2712	71ST ST	CARLYLE AVE	INDIAN CREEK DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3994	SW_2639	71ST ST	BONITA DR	NORMANDY DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4032	SW_2671	71ST ST	CARLYLE AVE	INDIAN CREEK DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4042	SW_2678	71ST ST	INDIAN CREEK DR	BONITA DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4058	SW_2703	71ST ST	BYRON AVE	CARLYLE AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4079	SW_2712	71ST ST	CARLYLE AVE	INDIAN CREEK DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4103	SW_0131	71ST ST	BYRON AVE	CARLYLE AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4115	SW_0131	71ST ST	BYRON AVE	CARLYLE AVE	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4744	SW_2712	71ST ST	CARLYLE AVE	INDIAN CREEK DR	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4975	SW_0144	71ST ST	ABBOTT AVE	ABBOTT CT	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4984	SW_0339	71ST ST	ABBOTT AVE	ABBOTT CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5091	SW_3151	71ST ST	VERSAILLES CT	RUE VENDOME	Normandy Isles A	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2237	SW_1678	72ND ST	HARDING CT	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2308	SW_1700	72ND ST	COLLINS AVE	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2327	SW_1700	72ND ST	COLLINS AVE	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2423	SW_1700	72ND ST	COLLINS AVE	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2440	SW_1727	72ND ST	COLLINS AVE	HARDING AVE	North Shore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2475	SW_1727	72ND ST	COLLINS AVE	HARDING AVE	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2515	SW_1727	72ND ST	COLLINS AVE	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3063	SW_2054	72ND ST	HARDING AVE	ABBOTT CT	North Shore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3118	SW_2071	72ND ST	BYRON AVE	CARLYLE AVE	North Shore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3127	SW_2071	72ND ST	BYRON AVE	CARLYLE AVE	North Shore D	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3140	SW_2073	72ND ST	CARLYLE AVE	DICKENS AVE	North Shore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3143	SW_2131	72ND ST	CARLYLE AVE	DICKENS AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3153	SW_2101	72ND ST	CARLYLE AVE	DICKENS AVE	North Shore D	Damaged	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3154	SW_2101	72ND ST	CARLYLE AVE	DICKENS AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3184	SW_2131	72ND ST	CARLYLE AVE	DICKENS AVE	North Shore D	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_3250	SW_2158	72ND ST	BYRON AVE	CARLYLE AVE	North Shore D	Damaged	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3272	SW_2173	72ND ST	ABBOTT CT	BYRON AVE	North Shore D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3342	SW_2184	72ND ST	HARDING AVE	ABBOTT CT	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3366	SW_2215	72ND ST	HARDING CT	HARDING AVE	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3383	SW_2215	72ND ST	HARDING CT	HARDING AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3416	SW_2215	72ND ST	HARDING CT	HARDING AVE	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3456	SW_2226	72ND ST	HARDING AVE	HARDING CT	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0243	SW_1322	73RD ST	DICKENS AVE	WAYNE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0336	SW_1340	73RD ST	DICKENS AVE	WAYNE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0871	SW_1549	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0906	SW_1362	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1008	SW_1381	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1011	SW_1381	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1028	SW_1381	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1043	SW_1381	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1089	SW_1549	73RD ST	OCEAN TER	COLLINS AVE	North Shore C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1971	SW_1564	73RD ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1995	SW_1622	73RD ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2007	SW_1622	73RD ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2081	SW_1622	73RD ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2118	SW_1622	73RD ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2201	SW_2414	73RD ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2291	SW_2447	73RD ST	BYRON CT	CARLYLE AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2328	SW_2490	73RD ST	DICKENS AVE	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2909	SW_1943	73RD ST	HARDING CT	BYRON AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2920	SW_1943	73RD ST	HARDING CT	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2948	SW_1943	73RD ST	HARDING CT	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3021	SW_2501	73RD ST	CARLYLE AVE	BYRON AVE	North Shore C	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3032	SW_1989	73RD ST	BYRON AVE	HARDING AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0688	SW_1573	74TH ST	OCEAN TER	COLLINS AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1218	SW_1573	74TH ST	OCEAN TER	COLLINS AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1239	SW_1608	74TH ST	OCEAN TER	COLLINS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1849	SW_1503	74TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1877	SW_1503	74TH ST	COLLINS AVE	COLLINS CT	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1879	SW_1520	74TH ST	COLLINS AVE	COLLINS CT	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1896	SW_1503	74TH ST	COLLINS AVE	COLLINS CT	North Shore C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1908	SW_1520	74TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2198	SW_2425	74TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2200	SW_2413	74TH ST	BYRON CT	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2218	SW_2431	74TH ST	BYRON CT	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2219	SW_2431	74TH ST	BYRON CT	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2220	SW_2413	74TH ST	BYRON CT	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2238	SW_2417	74TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2239	SW_2417	74TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2794	SW_1903	74TH ST	HARDING CT	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2803	SW_1903	74TH ST	HARDING CT	BYRON AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2837	SW_1919	74TH ST	HARDING CT	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2887	SW_1919	74TH ST	HARDING CT	BYRON AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4893	SW_1503	74TH ST	COLLINS AVE	COLLINS CT	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0438	SW_1125	75TH ST	OCEAN TER	ATLANTIC WAY	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0471	SW_1647	75TH ST	OCEAN TER	ATLANTIC WAY	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0500	SW_1454	75TH ST	DICKENS AVE	WEST END	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0605	SW_1537	75TH ST	DICKENS AVE	WEST END	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0620	SW_1537	75TH ST	DICKENS AVE	WEST END	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0635	SW_1537	75TH ST	DICKENS AVE	WEST END	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0650	SW_1537	75TH ST	DICKENS AVE	WEST END	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0857	SW_1606	75TH ST	BYRON AVE	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1259	SW_1647	75TH ST	OCEAN TER	ATLANTIC WAY	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1329	SW_1647	75TH ST	OCEAN TER	ATLANTIC WAY	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1726	SW_1370	75TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1753	SW_1370	75TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1767	SW_3130	75TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1783	SW_1413	75TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2141	SW_2405	75TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2175	SW_2405	75TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2176	SW_2406	75TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2195	SW_2407	75TH ST	BYRON CT	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2196	SW_2407	75TH ST	BYRON CT	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2197	SW_2406	75TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2254	SW_2409	75TH ST	BYRON AVE	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2385	SW_2407	75TH ST	BYRON CT	CARLYLE AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2673	SW_1824	75TH ST	HARDING AVE	ABBOTT AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2691	SW_1778	75TH ST	ABBOTT AVE	BYRON AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2694	SW_1825	75TH ST	ABBOTT AVE	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2710	SW_1850	75TH ST	HARDING AVE	ABBOTT AVE	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4884	SW_1370	75TH ST	COLLINS AVE	COLLINS CT	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4894	SW_1370	75TH ST	COLLINS AVE	COLLINS CT	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0415	SW_0830	76TH ST	BEACH WALK	ATLANTIC WAY	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0687	SW_1548	76TH ST	ABBOTT AVE	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0715	SW_1548	76TH ST	ABBOTT AVE	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0727	SW_1593	76TH ST	ABBOTT AVE	BYRON AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1589	SW_1273	76TH ST	COLLINS CT	HARDING AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1612	SW_1314	76TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1627	SW_1282	76TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1700	SW_1321	76TH ST	COLLINS CT	HARDING AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1850	SW_2166	76TH ST	BYRON AVE	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1863	SW_2185	76TH ST	BYRON AVE	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1882	SW_2185	76TH ST	BYRON AVE	CARLYLE AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2119	SW_2381	76TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2139	SW_2381	76TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2158	SW_2385	76TH ST	CARLYLE AVE	DICKENS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2534	SW_1752	76TH ST	HARDING AVE	ABBOTT AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2608	SW_1768	76TH ST	HARDING AVE	ABBOTT AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2626	SW_1795	76TH ST	HARDING AVE	ABBOTT AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2672	SW_1795	76TH ST	HARDING AVE	ABBOTT AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_4918	SW_0830	76TH ST	BEACH WALK	ATLANTIC WAY	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0254	SW_0537	77TH ST	ATLANTIC WAY	COLLINS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0289	SW_0539	77TH ST	ATLANTIC WAY	COLLINS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0309	SW_0539	77TH ST	ATLANTIC WAY	COLLINS AVE	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0533	SW_1435	77TH ST	ABBOTT AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0585	SW_1465	77TH ST	ABBOTT AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0765	SW_1753	77TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0789	SW_1701	77TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0953	SW_1701	77TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0972	SW_1753	77TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0989	SW_1753	77TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1417	SW_1214	77TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1542	SW_1214	77TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1543	SW_1221	77TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1558	SW_1221	77TH ST	COLLINS AVE	COLLINS CT	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1645	SW_2078	77TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1670	SW_2078	77TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1701	SW_2102	77TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1739	SW_2102	77TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2010	SW_2336	77TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2044	SW_2336	77TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2099	SW_2346	77TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2138	SW_2346	77TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2326	SW_1692	77TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2363	SW_1709	77TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2473	SW_1709	77TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3670	SW_3137	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	Biscayne Point A	Good	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3799	SW_0619	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	Biscayne Point A	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3800	SW_0628	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	North Shore B	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3829	SW_3138	77TH ST	TATUM WATERWAY DR	HAWTHORNE AVE	North Shore B	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4960	SW_1701	77TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0212	SW_0514	78TH ST	ATLANTIC WAY	COLLINS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0291	SW_1350	78TH ST	ABBOTT AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0353	SW_1372	78TH ST	ABBOTT AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0375	SW_1350	78TH ST	ABBOTT AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0872	SW_1631	78TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1163	SW_1545	78TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1254	SW_1545	78TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1276	SW_1137	78TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1327	SW_1137	78TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1544	SW_2002	78TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1561	SW_2027	78TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1613	SW_2027	78TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1909	SW_2211	78TH ST	DICKENS AVE	TATUM WATERWAY DR	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1956	SW_2271	78TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1986	SW_2284	78TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1996	SW_2284	78TH ST	CARLYLE AVE	DICKENS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2098	SW_1640	78TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2174	SW_1640	78TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2214	SW_1661	78TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2058	SW_0460	79TH CSWY	SW END	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3176	SW_2142	79TH CSWY	SW END	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0164	SW_0441	79TH ST	COLLINS AVE	ATLANTIC WAY	North Shore B	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0186	SW_1283	79TH ST	BYRON AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0263	SW_1303	79TH ST	BYRON AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0324	SW_1493	79TH ST	COLLINS CT	COLLINS AVE	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1006	SW_1501	79TH ST	COLLINS CT	COLLINS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1058	SW_1462	79TH ST	HARDING AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1126	SW_1501	79TH ST	COLLINS CT	COLLINS AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1404	SW_1944	79TH ST	CARLYLE AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1491	SW_1968	79TH ST	CARLYLE AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1527	SW_1968	79TH ST	CARLYLE AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1768	SW_2150	79TH ST	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1822	SW_2174	79TH ST	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1943	SW_1557	79TH ST	ABBOTT AVE	HARDING AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1954	SW_1521	79TH ST	ABBOTT AVE	HARDING AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1955	SW_1581	79TH ST	ABBOTT AVE	HARDING AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3530	SW_2178	79TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3562	SW_2152	79TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2842	SW_2096	79TH TER	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2843	SW_2089	79TH TER	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3245	SW_2089	79TH TER	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3255	SW_2089	79TH TER	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3338	SW_2096	79TH TER	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3369	SW_2096	79TH TER	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2824	SW_0125	7TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2846	SW_0125	7TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2847	SW_0547	7TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2853	SW_0547	7TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1138	SW_0846	7TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1212	SW_0846	7TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1272	SW_0835	7TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1290	SW_0846	7TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1318	SW_0835	7TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1319	SW_0846	7TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1342	SW_0835	7TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1343	SW_0857	7TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1376	SW_0846	7TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1401	SW_0877	7TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1447	SW_0877	7TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1503	SW_0877	7TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1556	SW_0450	7TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1693	SW_0146	7TH ST	LENOX CT	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1745	SW_0146	7TH ST	LENOX CT	ALTON RD	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1764	SW_0163	7TH ST	MICHIGAN AVE	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1765	SW_0153	7TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1791	SW_0163	7TH ST	MICHIGAN AVE	7TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1802	SW_0156	7TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1832	SW_0156	7TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1869	SW_0163	7TH ST	MICHIGAN AVE	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1891	SW_0174	7TH ST	MICHIGAN AVE	7TH ST	Flamingo/Lummus C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_1936	SW_0174	7TH ST	MICHIGAN AVE	7TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1962	SW_0169	7TH ST	LENOX CT	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2040	SW_0174	7TH ST	MICHIGAN AVE	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4159	SW_0324	7TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4181	SW_0324	7TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4222	SW_0338	7TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4231	SW_0450	7TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4235	SW_1267	7TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4242	SW_0338	7TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4243	SW_0342	7TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4258	SW_1276	7TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4265	SW_2717	7TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4268	SW_1267	7TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4283	SW_1276	7TH ST	JEFFERSON CT	MICHIGAN AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4292	SW_0342	7TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4293	SW_0350	7TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4304	SW_2717	7TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4309	SW_1307	7TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4321	SW_1307	7TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4324	SW_1316	7TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4325	SW_1316	7TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4338	SW_0350	7TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4342	SW_1307	7TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4350	SW_0358	7TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4356	SW_1316	7TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4379	SW_0363	7TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4393	SW_0363	7TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4439	SW_0363	7TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4809	SW_1706	7TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0163	SW_1215	80TH ST	ABBOTT AVE	BYRON AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0822	SW_1387	80TH ST	COLLINS AVE	COLLINS CT	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0856	SW_1387	80TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0903	SW_1387	80TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0940	SW_1443	80TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0952	SW_1443	80TH ST	COLLINS AVE	COLLINS CT	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1026	SW_1443	80TH ST	COLLINS AVE	COLLINS CT	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1115	SW_1796	80TH ST	BYRON AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1821	SW_1472	80TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1862	SW_1502	80TH ST	HARDING AVE	ABBOTT AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2882	SW_1929	80TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2891	SW_1905	80TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3088	SW_1905	80TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3179	SW_1979	80TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0563	SW_1329	81ST ST	COLLINS AVE	COLLINS CT	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0686	SW_1300	81ST ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0746	SW_1300	81ST ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0764	SW_1329	81ST ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1309	SW_1138	81ST ST	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1346	SW_1138	81ST ST	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1362	SW_1164	81ST ST	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1428	SW_1173	81ST ST	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1510	SW_1245	81ST ST	HARDING AVE	ABBOTT AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1571	SW_1245	81ST ST	HARDING AVE	ABBOTT AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1644	SW_1293	81ST ST	HARDING AVE	ABBOTT AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1684	SW_1293	81ST ST	HARDING AVE	ABBOTT AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2973	SW_1854	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3000	SW_1854	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3016	SW_1854	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3186	SW_2542	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3264	SW_2542	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3311	SW_2542	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3335	SW_2542	81ST ST	BISCAYNE POINT RD	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_5126	SW_1329	81ST ST	COLLINS AVE	COLLINS CT	North Shore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0566	SW_1220	82ND ST	COLLINS CT	HARDING AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0603	SW_1244	82ND ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0634	SW_1263	82ND ST	COLLINS CT	HARDING AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1181	SW_1544	82ND ST	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1236	SW_1544	82ND ST	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2851	SW_2355	82ND ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2897	SW_2355	82ND ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2952	SW_2419	82ND ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2969	SW_2371	82ND ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2995	SW_2419	82ND ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3065	SW_2419	82ND ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0499	SW_1184	82ND TER	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0699	SW_1184	82ND TER	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0888	SW_1394	82ND TER	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0921	SW_1394	82ND TER	ABBOTT AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0395	SW_1123	83RD ST	COLLINS CT	HARDING AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0449	SW_1143	83RD ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0468	SW_1193	83RD ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0546	SW_1193	83RD ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0643	SW_1143	83RD ST	COLLINS AVE	COLLINS CT	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1738	SW_1360	83RD ST	HARDING AVE	ABBOTT AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2101	SW_2125	83RD ST	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2274	SW_2125	83RD ST	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2348	SW_2125	83RD ST	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2752	SW_2290	83RD ST	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2768	SW_2290	83RD ST	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2819	SW_2290	83RD ST	HAWTHORNE AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0306	SW_1033	84TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0316	SW_1056	84TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0333	SW_1058	84TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0369	SW_1058	84TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0380	SW_1101	84TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0411	SW_1122	84TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0720	SW_1057	84TH ST	COLLINS CT	HARDING AVE	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0901	SW_1033	84TH ST	COLLINS AVE	COLLINS CT	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0973	SW_1978	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1740	SW_1978	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1799	SW_1978	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1927	SW_2056	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2083	SW_2056	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3344	SW_2056	84TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0079	SW_0051	85TH ST	ATLANTIC WAY	COLLINS AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0104	SW_0067	85TH ST	BYRON AVE	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0172	SW_0728	85TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0305	SW_0058	85TH ST	BYRON AVE	CRESPI BLVD	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0349	SW_0828	85TH ST	BYRON AVE	CRESPI BLVD	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0393	SW_0853	85TH ST	COLLINS AVE	COLLINS CT	North Shore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0467	SW_0872	85TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0804	SW_0853	85TH ST	COLLINS AVE	COLLINS CT	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1057	SW_1853	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1279	SW_1694	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1475	SW_1781	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1495	SW_1853	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1528	SW_1853	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1615	SW_1871	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1658	SW_1871	85TH ST	CRESPI BLVD	HAWTHORNE AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0196	SW_0771	86TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0240	SW_0771	86TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0378	SW_0843	86TH ST	HARDING AVE	BYRON AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1104	SW_1531	86TH ST	CRESPI BLVD	STILLWATER DR	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0045	SW_0959	87TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0060	SW_0959	87TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0061	SW_0977	87TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0100	SW_0977	87TH ST	COLLINS AVE	COLLINS CT	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0009	SW_0006	87TH TER	BEACH SVRD	COLLINS AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0028	SW_0006	87TH TER	BEACH SVRD	COLLINS AVE	North Shore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0037	SW_0006	87TH TER	BEACH SVRD	COLLINS AVE	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0583	SW_0921	87TH TER	COLLINS AVE	HARDING AVE	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1093	SW_0006	87TH TER	BEACH SVRD	COLLINS AVE	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2857	SW_0580	8TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2904	SW_0580	8TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2916	SW_2879	8TH DI LIDO TER	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1484	SW_0890	8TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1523	SW_0890	8TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1555	SW_0890	8TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1594	SW_0914	8TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1609	SW_0902	8TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1619	SW_0902	8TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1642	SW_0902	8TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1649	SW_0914	8TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1674	SW_0914	8TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1675	SW_0940	8TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1723	SW_0940	8TH ST	EUCLID CT	MERIDIAN AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2133	SW_0215	8TH ST	8TH ST	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2161	SW_0207	8TH ST	LENOX CT	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2163	SW_0215	8TH ST	8TH ST	LENOX AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2181	SW_0207	8TH ST	LENOX CT	ALTON RD	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2206	SW_0215	8TH ST	8TH ST	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2230	SW_0221	8TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2285	SW_0225	8TH ST	LENOX AVE	LENOX CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2341	SW_0238	8TH ST	LENOX CT	ALTON RD	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2375	SW_0228	8TH ST	8TH ST	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4322	SW_1295	8TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4323	SW_1295	8TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4326	SW_1332	8TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4329	SW_1343	8TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4341	SW_1295	8TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4357	SW_1308	8TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4359	SW_1343	8TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4366	SW_0372	8TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4370	SW_1308	8TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4382	SW_1308	8TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4396	SW_1332	8TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4398	SW_1332	8TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4409	SW_0372	8TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4412	SW_1343	8TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4422	SW_3073	8TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4466	SW_3073	8TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4479	SW_0379	8TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4480	SW_3072	8TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4503	SW_0383	8TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4516	SW_0387	8TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4517	SW_0387	8TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4530	SW_0387	8TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4543	SW_0383	8TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4556	SW_0388	8TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4597	SW_0388	8TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4598	SW_0397	8TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4611	SW_0397	8TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4663	SW_1355	8TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4674	SW_1377	8TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4683	SW_1377	8TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4695	SW_1384	8TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4772	SW_1758	8TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4773	SW_1757	8TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4833	SW_1758	8TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1697	SW_0941	9TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1747	SW_0941	9TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1775	SW_0941	9TH ST	PENNSYLVANIA CT	EUCLID AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1805	SW_0971	9TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1841	SW_0963	9TH ST	EAST END	WEST END	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1894	SW_0971	9TH ST	PENNSYLVANIA AVE	PENNSYLVANIA CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1919	SW_0963	9TH ST	EAST END	WEST END	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1938	SW_0963	9TH ST	EAST END	WEST END	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2004	SW_0982	9TH ST	EUCLID AVE	EUCLID CT	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2455	SW_1765	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2482	SW_0256	9TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2510	SW_0261	9TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2544	SW_0256	9TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2565	SW_0264	9TH ST	MICHIGAN AVE	LENOX AVE	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2587	SW_0261	9TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2614	SW_0261	9TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2634	SW_0272	9TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2835	SW_0272	9TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4328	SW_1363	9TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4330	SW_1375	9TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4380	SW_1260	9TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4397	SW_1364	9TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4399	SW_1364	9TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4411	SW_1364	9TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4424	SW_1363	9TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Not Adequate	Not Adequate	Not Adequate		$2,500
R_4443	SW_1375	9TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4457	SW_1363	9TH ST	JEFFERSON AVE	JEFFERSON CT	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4470	SW_1375	9TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4473	SW_1241	9TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4495	SW_1389	9TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4498	SW_1241	9TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4511	SW_1260	9TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4520	SW_1389	9TH ST	MERIDIAN CT	JEFFERSON AVE	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4522	SW_1278	9TH ST	ALTON RD	ALTON CT	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4557	SW_0403	9TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4559	SW_0403	9TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4569	SW_1297	9TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4580	SW_1297	9TH ST	ALTON CT	WEST AVE	Flamingo/Lummus C	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4610	SW_3074	9TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4612	SW_3074	9TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4669	SW_1749	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4678	SW_0413	9TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4688	SW_0412	9TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4689	SW_0413	9TH ST	OCEAN DR	OCEAN CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4691	SW_0272	9TH ST	LENOX AVE	ALTON RD	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4700	SW_3071	9TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4709	SW_3068	9TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4711	SW_0412	9TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4719	SW_3071	9TH ST	OCEAN CT	COLLINS AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4736	SW_3068	9TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4748	SW_0417	9TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4752	SW_1749	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4790	SW_0417	9TH ST	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4796	SW_3067	9TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4814	SW_3067	9TH ST	COLLINS AVE	COLLINS CT	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4847	SW_1765	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4855	SW_1765	9TH ST	WASHINGTON AVE	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0046	SW_0498	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0078	SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0127	SW_1195	ABBOTT AVE	80TH ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0397	SW_1414	ABBOTT AVE	77TH ST	78TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0470	SW_1414	ABBOTT AVE	77TH ST	78TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0774	SW_1600	ABBOTT AVE	75TH ST	76TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1145	SW_1471	ABBOTT AVE	82ND ST	82ND TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1292	SW_1552	ABBOTT AVE	81ST ST	82ND ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1834	SW_1174	ABBOTT AVE	80TH ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2194	SW_1085	ABBOTT AVE	77TH ST	78TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2347	SW_1085	ABBOTT AVE	77TH ST	78TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2701	SW_1000	ABBOTT AVE	75TH ST	76TH ST	North Shore C	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3554	SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3589	SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3617	SW_0498	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3837	SW_0488	ABBOTT AVE	69TH ST	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3844	SW_2472	ABBOTT AVE	69TH ST	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3850	SW_2472	ABBOTT AVE	69TH ST	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3857	SW_2472	ABBOTT AVE	69TH ST	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3880	SW_2472	ABBOTT AVE	69TH ST	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_4732	SW_0498	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4977	SW_0335	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4978	SW_0335	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4982	SW_0335	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4986	SW_0335	ABBOTT AVE	71ST ST	69TH ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4989	SW_0352	ABBOTT AVE	NORMANDY BEACH CT	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5071	SW_0467	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5078	SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5079	SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5086	SW_0473	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5090	SW_0467	ABBOTT AVE	72ND ST	NORMANDY BEACH CT	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5195	SW_0488	ABBOTT AVE	69TH ST	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3203	SW_2992	ADAMS AVE	44TH CT	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3795	SW_2980	ADAMS AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3820	SW_2984	ADAMS AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0092	SW_1499	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0099	SW_0282	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0109	SW_1499	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0146	SW_0022	ALTON RD	2ND ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0155	SW_0022	ALTON RD	2ND ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0238	SW_0711	ALTON RD	11TH ST	12TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0253	SW_0711	ALTON RD	11TH ST	12TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0256	SW_0024	ALTON RD	ALTON RD	SUNSET DR	Sunset Harbor A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0260	SW_0257	ALTON RD	15TH ST	15TH TER	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0266	SW_0711	ALTON RD	11TH ST	12TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_0428	SW_1499	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0456	SW_0181	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0491	SW_0022	ALTON RD	2ND ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0495	SW_0196	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0496	SW_0196	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0508	SW_2807	ALTON RD	18TH ST	19TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0525	SW_0197	ALTON RD	DADE BLVD	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0526	SW_0197	ALTON RD	DADE BLVD	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0590	SW_0197	ALTON RD	DADE BLVD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0597	SW_0022	ALTON RD	2ND ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0614	SW_2807	ALTON RD	18TH ST	19TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0627	SW_2889	ALTON RD	NAUTILUS DR	43RD ST	Nautilus G	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0630	SW_0197	ALTON RD	DADE BLVD	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0640	SW_1023	ALTON RD	I 195	NAUTILUS DR	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0652	SW_2798	ALTON RD	51ST ST	BAY RD	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0668	SW_0197	ALTON RD	DADE BLVD	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0670	SW_0197	ALTON RD	DADE BLVD	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0683	SW_0196	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0693	SW_2767	ALTON RD	52ND ST	51ST ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0741	SW_0196	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0743	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0801	SW_0231	ALTON RD	18TH ST	DADE BLVD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0866	SW_1515	ALTON RD	15TH ST	15TH TER	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0883	SW_0059	ALTON RD	4TH ST	MAC ARTHUR CSWY	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0899	SW_0274	ALTON RD	LINCOLN CT	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0916	SW_0059	ALTON RD	4TH ST	MAC ARTHUR CSWY	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1035	SW_0079	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1100	SW_0079	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1137	SW_0616	ALTON RD	COMMERCE ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1139	SW_0079	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1190	SW_0616	ALTON RD	COMMERCE ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1196	SW_1534	ALTON RD	16TH ST	LINCOLN RD	City Center A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1211	SW_0675	ALTON RD	1ST ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1234	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_1245	SW_0675	ALTON RD	1ST ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1270	SW_0675	ALTON RD	1ST ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1339	SW_0092	ALTON RD	MAC ARTHUR CSWY	6TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1371	SW_0092	ALTON RD	MAC ARTHUR CSWY	6TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1413	SW_1515	ALTON RD	15TH ST	15TH TER	Flamingo/Lummus E	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1471	SW_0282	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1505	SW_1506	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1524	SW_0181	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1533	SW_0181	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1565	SW_0181	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1587	SW_0181	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1662	SW_0136	ALTON RD	6TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1673	SW_2798	ALTON RD	51ST ST	BAY RD	La Gorce B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1682	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1690	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1691	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1719	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1742	SW_2840	ALTON RD	BAY RD	48TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1748	SW_0196	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1762	SW_0068	ALTON RD	ALTON RD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1787	SW_2840	ALTON RD	BAY RD	48TH ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_1827	SW_3159	ALTON RD	48TH ST	LAKEVIEW DR	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1931	SW_2299	ALTON RD	54TH ST	56TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1979	SW_3107	ALTON RD	15TH ST	15TH TER	Flamingo/Lummus E	-	-	-	-	Under Construction		
R_2013	SW_2849	ALTON RD	60TH ST	62ND ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2068	SW_2849	ALTON RD	60TH ST	62ND ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2070	SW_1167	ALTON RD	2ND ST	1ST ST	South Pointe C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2076	SW_0265	ALTON RD	15TH TER	16TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2093	SW_0195	ALTON RD	7TH ST	8TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2124	SW_2853	ALTON RD	47TH CT	48TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2261	SW_0302	ALTON RD	16TH ST	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2269	SW_1449	ALTON RD	11TH ST	12TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2280	SW_2853	ALTON RD	47TH CT	48TH ST	Nautilus F	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2288	SW_0302	ALTON RD	16TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2297	SW_1449	ALTON RD	11TH ST	12TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2338	SW_0302	ALTON RD	16TH ST	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2428	SW_0253	ALTON RD	8TH ST	9TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2498	SW_0336	ALTON RD	LINCOLN CT	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2513	SW_0336	ALTON RD	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2530	SW_0336	ALTON RD	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2573	SW_0336	ALTON RD	LINCOLN CT	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2595	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2651	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2800	SW_3047	ALTON RD	MAC ARTHUR CSWY	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2801	SW_3050	ALTON RD	MAC ARTHUR CSWY	4TH ST	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2809	SW_3050	ALTON RD	MAC ARTHUR CSWY	4TH ST	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2816	SW_3050	ALTON RD	MAC ARTHUR CSWY	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2874	SW_3057	ALTON RD	1ST ST	POINTE DR	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2917	SW_3057	ALTON RD	1ST ST	POINTE DR	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2918	SW_3057	ALTON RD	1ST ST	POINTE DR	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2930	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2960	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2961	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2962	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2964	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2979	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2992	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3017	SW_2611	ALTON RD	56TH ST	57TH ST	La Gorce B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3020	SW_3049	ALTON RD	2ND ST	1ST ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3030	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3041	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3049	SW_2611	ALTON RD	56TH ST	57TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3052	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3060	SW_2968	ALTON RD	43RD ST	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3062	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3077	SW_2611	ALTON RD	56TH ST	57TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3081	SW_3062	ALTON RD	4TH ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3089	SW_2611	ALTON RD	56TH ST	57TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3110	SW_2611	ALTON RD	56TH ST	57TH ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3114	SW_2393	ALTON RD	BAY RD	43RD ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3124	SW_2108	ALTON RD	63RD ST	62ND ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3131	SW_2611	ALTON RD	56TH ST	57TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3158	SW_2663	ALTON RD	57TH ST	58TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3181	SW_2223	ALTON RD	LA GORCE DR	63RD ST	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3189	SW_2663	ALTON RD	57TH ST	58TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3190	SW_2223	ALTON RD	LA GORCE DR	63RD ST	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3220	SW_2680	ALTON RD	58TH ST	59TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3268	SW_2680	ALTON RD	58TH ST	59TH ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3277	SW_2694	ALTON RD	59TH ST	60TH ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3304	SW_2694	ALTON RD	59TH ST	60TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3331	SW_2393	ALTON RD	BAY RD	43RD ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3371	SW_2506	ALTON RD	62ND ST	63RD ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3440	SW_1499	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3454	SW_3007	ALTON RD	44TH CT	44TH ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3525	SW_0282	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3526	SW_0282	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3566	SW_3083	ALTON RD	39TH ST	I 195	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3568	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3575	SW_3083	ALTON RD	39TH ST	I 195	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3588	SW_3084	ALTON RD	BARRY ST	39TH ST	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3692	SW_2965	ALTON RD	43RD ST	I 195	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3699	SW_0206	ALTON RD	43RD ST	I 195	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3743	SW_2970	ALTON RD	44TH ST	44TH CT	Nautilus G	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3811	SW_2983	ALTON RD	47TH CT	47TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3861	SW_2589	ALTON RD	51ST ST	51ST ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3887	SW_2589	ALTON RD	51ST ST	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3894	SW_2603	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3906	SW_2745	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3913	SW_2603	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3918	SW_2745	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3925	SW_0399	ALTON RD	BAY RD	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3926	SW_3036	ALTON RD	ALTON RD	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3933	SW_2756	ALTON RD	BAY RD	29TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3954	SW_0266	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3955	SW_0266	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3956	SW_0214	ALTON RD	BAY RD	29TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3960	SW_0266	ALTON RD	LAKEVIEW DR	51ST ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3964	SW_2334	ALTON RD	29TH ST	27TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3970	SW_2799	ALTON RD	48TH ST	LAKEVIEW DR	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3974	SW_2756	ALTON RD	BAY RD	29TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3979	SW_2224	ALTON RD	29TH ST	27TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3988	SW_2334	ALTON RD	29TH ST	27TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3999	SW_0407	ALTON RD	27TH ST	23RD ST	Lower North Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4001	SW_0282	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4040	SW_0407	ALTON RD	27TH ST	23RD ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4044	SW_2763	ALTON RD	23RD ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4060	SW_2763	ALTON RD	23RD ST	ALTON RD	Lower North Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4065	SW_2765	ALTON RD	ALTON RD	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4074	SW_2567	ALTON RD	I 195-ALTON RAMPON	34TH ST	Bayshore D	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_4078	SW_2765	ALTON RD	ALTON RD	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4086	SW_0402	ALTON RD	17TH ST	DADE BLVD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4112	SW_2769	ALTON RD	51ST ST	52ND ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4123	SW_2770	ALTON RD	51ST ST	52ND ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4165	SW_0402	ALTON RD	17TH ST	DADE BLVD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4188	SW_0411	ALTON RD	17TH ST	DADE BLVD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4189	SW_1439	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4200	SW_1434	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4281	SW_0322	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4295	SW_0322	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4305	SW_0322	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4307	SW_0322	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4319	SW_0322	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4352	SW_0322	ALTON RD	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4353	SW_1434	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4367	SW_1434	ALTON RD	9TH ST	10TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4440	SW_1426	ALTON RD	8TH ST	9TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4755	SW_3109	ALTON RD	7TH ST	6TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4800	SW_0092	ALTON RD	MAC ARTHUR CSWY	6TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4807	SW_1459	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4810	SW_1411	ALTON RD	8TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4818	SW_1411	ALTON RD	8TH ST	7TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4825	SW_1411	ALTON RD	8TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4834	SW_1411	ALTON RD	8TH ST	7TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4841	SW_1411	ALTON RD	8TH ST	7TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4905	SW_1484	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4906	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4921	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4934	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4938	SW_2779	ALTON RD	52ND ST	53RD ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4941	SW_1459	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4942	SW_1459	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_4943	SW_0374	ALTON RD	53RD ST	54TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4947	SW_1459	ALTON RD	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4949	SW_2120	ALTON RD	53RD ST	54TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4950	SW_2128	ALTON RD	54TH ST	56TH ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4951	SW_1484	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4952	SW_1985	ALTON RD	BARRY ST	39TH ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4953	SW_1499	ALTON RD	14TH ST	14TH CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_4958	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4959	SW_1506	ALTON RD	14TH CT	15TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_4962	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4963	SW_1534	ALTON RD	16TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4964	SW_0141	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4965	SW_1534	ALTON RD	16TH ST	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_5002	SW_1484	ALTON RD	13TH ST	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5082	SW_2808	ALTON RD	39TH ST	I 195	Bayshore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5130	SW_2250	ALTON RD	19TH ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5137	SW_0259	ALTON RD	ALTON RD	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5147	SW_0268	ALTON RD	ALTON RD	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5151	SW_0313	ALTON RD	ALTON RD	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5152	SW_0313	ALTON RD	ALTON RD	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5155	SW_3168	ALTON RD	20TH ST	20TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5163	SW_2814	ALTON RD	ALTON RD	SUNSET DR	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5166	SW_3168	ALTON RD	20TH ST	20TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_5168	SW_2813	ALTON RD	ALTON RD	SUNSET DR	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5169	SW_0333	ALTON RD	ALTON RD	SUNSET DR	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5170	SW_0333	ALTON RD	ALTON RD	SUNSET DR	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5171	SW_0299	ALTON RD	ALTON RD	SUNSET DR	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4020	SW_0496	BARRY ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4035	SW_2781	BARRY ST	MERIDIAN AVE	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4122	SW_0925	BARRY ST	GARDEN AVE	ALTON RD	Bayshore D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4130	SW_0925	BARRY ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4945	SW_1763	BARRY ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4946	SW_1763	BARRY ST	GARDEN AVE	ALTON RD	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4948	SW_1763	BARRY ST	GARDEN AVE	ALTON RD	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0198	SW_0686	BAY DR	BREST ESPLANADE	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0288	SW_0782	BAY DR	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0317	SW_0782	BAY DR	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0335	SW_0794	BAY DR	BIARRITZ CT	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0351	SW_0794	BAY DR	BIARRITZ CT	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0775	SW_1351	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0990	SW_1351	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1009	SW_1351	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1474	SW_1990	BAY DR	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1511	SW_1990	BAY DR	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1625	SW_1591	BAY DR	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1880	SW_2086	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1991	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2008	SW_1591	BAY DR	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2009	SW_1654	BAY DR	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2043	SW_1645	BAY DR	MARSEILLE DR	SHORE DR	Normandy Shores A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2157	SW_1654	BAY DR	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2252	SW_3148	BAY DR	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_2384	SW_1686	BAY DR	MARSEILLE DR	SHORE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2405	SW_1719	BAY DR	BREST ESPLANADE	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2554	SW_1719	BAY DR	BREST ESPLANADE	RUE VERSAILLES	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2665	SW_1815	BAY DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2674	SW_1815	BAY DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2700	SW_0523	BAY DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2734	SW_1808	BAY DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2758	SW_1808	BAY DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2767	SW_1877	BAY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2782	SW_1877	BAY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2811	SW_1913	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2830	SW_1913	BAY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2982	SW_2018	BAY DR	TROUVILLE ESPLANADE	WEST END	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3103	SW_2086	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Damaged	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3241	SW_2086	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3263	SW_2192	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3273	SW_2192	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3322	SW_2237	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3353	SW_2237	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3364	SW_2237	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3395	SW_2237	BAY DR	RUE GRANVILLE	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_4092	SW_2739	BAY DR	CALAIS DR	NW END	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4110	SW_0037	BAY DR	CALAIS DR	NW END	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4891	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4954	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_4981	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_4987	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4994	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_5066	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5069	SW_0416	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5117	SW_1351	BAY DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0012	SW_2821	BAY RD	21ST ST	23RD ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0040	SW_2830	BAY RD	23RD ST	27TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0053	SW_2830	BAY RD	23RD ST	27TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0067	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0068	SW_0015	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0074	SW_2833	BAY RD	27TH ST	29TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0083	SW_2833	BAY RD	27TH ST	29TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0144	SW_0015	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0145	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0192	SW_0015	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0537	SW_0518	BAY RD	ALTON RD	51ST ST	La Gorce B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0596	SW_0015	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0608	SW_0518	BAY RD	ALTON RD	51ST ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0610	SW_3103	BAY RD	15TH TER	16TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0719	SW_2752	BAY RD	51ST ST	52ND ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_0733	SW_2752	BAY RD	51ST ST	52ND ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_0753	SW_2793	BAY RD	52ND ST	53RD ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_0760	SW_0239	BAY RD	LINCOLN RD	NORTH END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0831	SW_3106	BAY RD	LINCOLN RD	NORTH END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0838	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0845	SW_2793	BAY RD	52ND ST	53RD ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_0887	SW_0015	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0895	SW_2828	BAY RD	53RD ST	54TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_0929	SW_2828	BAY RD	53RD ST	54TH ST	La Gorce C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0994	SW_0129	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1015	SW_0129	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1153	SW_0649	BAY RD	LINCOLN TER	LINCOLN RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1357	SW_3103	BAY RD	15TH TER	16TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1468	SW_3103	BAY RD	15TH TER	16TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1486	SW_0778	BAY RD	15TH TER	16TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1535	SW_0767	BAY RD	15TH TER	16TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1622	SW_0860	BAY RD	15TH ST	15TH TER	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1735	SW_0849	BAY RD	15TH ST	15TH TER	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1758	SW_0849	BAY RD	15TH ST	15TH TER	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1778	SW_0860	BAY RD	15TH ST	15TH TER	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1779	SW_0929	BAY RD	FLAMINGO WAY	15TH ST	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1808	SW_0929	BAY RD	FLAMINGO WAY	15TH ST	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1857	SW_0906	BAY RD	FLAMINGO WAY	15TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1889	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1922	SW_0930	BAY RD	14TH TER	FLAMINGO WAY	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1934	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1935	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1950	SW_0930	BAY RD	14TH TER	FLAMINGO WAY	West Avenue and Bay Road A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1961	SW_0007	BAY RD	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2015	SW_0944	BAY RD	14TH TER	FLAMINGO WAY	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2089	SW_0134	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2125	SW_1037	BAY RD	14TH ST	14TH TER	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2188	SW_1017	BAY RD	14TH ST	14TH TER	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2250	SW_0129	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2283	SW_0129	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2306	SW_0134	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2320	SW_1037	BAY RD	14TH ST	14TH TER	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2369	SW_3171	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2370	SW_0134	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2372	SW_0134	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2392	SW_0134	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2536	SW_2267	BAY RD	63RD ST	PINE TREE DR	La Gorce A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2542	SW_2268	BAY RD	59TH ST	60TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2558	SW_2296	BAY RD	60TH ST	63RD ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2574	SW_2296	BAY RD	60TH ST	63RD ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2613	SW_2268	BAY RD	59TH ST	60TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2649	SW_2352	BAY RD	58TH ST	59TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2705	SW_2352	BAY RD	58TH ST	59TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2722	SW_2375	BAY RD	57TH ST	58TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2762	SW_2390	BAY RD	56TH ST	57TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2769	SW_2375	BAY RD	57TH ST	58TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2776	SW_2390	BAY RD	56TH ST	57TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2820	SW_2487	BAY RD	54TH ST	56TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		
R_2914	SW_2487	BAY RD	54TH ST	56TH ST	La Gorce C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3340	SW_3003	BAY RD	ALTON RD	ED SULLIVAN DR	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3421	SW_3002	BAY RD	ED SULLIVAN DR	44TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3430	SW_3001	BAY RD	44TH ST	45TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3769	SW_2993	BAY RD	47TH ST	48TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3787	SW_2996	BAY RD	45TH ST	47TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3888	SW_2993	BAY RD	47TH ST	48TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3901	SW_2996	BAY RD	45TH ST	47TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3907	SW_2996	BAY RD	45TH ST	47TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3909	SW_3001	BAY RD	44TH ST	45TH ST	Nautilus D	Good	Adequate	Adequate	Adequate	Adequate		
R_3920	SW_3000	BAY RD	SUNSET DR	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3921	SW_3000	BAY RD	SUNSET DR	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3927	SW_3035	BAY RD	29TH ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3951	SW_3006	BAY RD	21ST ST	23RD ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3957	SW_3010	BAY RD	23RD ST	27TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3965	SW_3018	BAY RD	27TH ST	29TH ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_3966	SW_3035	BAY RD	29TH ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5034	SW_0129	BAY RD	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5175	SW_2815	BAY RD	SUNSET DR	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5179	SW_2815	BAY RD	SUNSET DR	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5181	SW_2815	BAY RD	SUNSET DR	MICHIGAN AVE	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5187	SW_2818	BAY RD	MICHIGAN AVE	21ST ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_5198	SW_2821	BAY RD	21ST ST	23RD ST	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2437	SW_0142	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2716	SW_0142	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4156	SW_0193	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4157	SW_0193	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4169	SW_0193	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4180	SW_0193	BEACH SVRD	WASHINGTON AVE	BEACH SVRD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0452	SW_1157	BEACH WALK	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0516	SW_1157	BEACH WALK	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0582	SW_1157	BEACH WALK	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0604	SW_1157	BEACH WALK	74TH ST	75TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0637	SW_1157	BEACH WALK	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0701	SW_1157	BEACH WALK	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0728	SW_1304	BEACH WALK	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0749	SW_1304	BEACH WALK	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0824	SW_1304	BEACH WALK	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3382	SW_0097	BEACH WALK	5TH ST	6TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0005	SW_0960	BIARRITZ DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0047	SW_0898	BIARRITZ DR	BREST ESPLANADE	VENDOME CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0101	SW_0542	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0125	SW_0542	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0138	SW_1021	BIARRITZ DR	EAST END	RUE NOTRE DAME	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0162	SW_0542	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0242	SW_0720	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0255	SW_0720	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0286	SW_0897	BIARRITZ DR	71ST ST	NORMANDY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0518	SW_1480	BIARRITZ DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0534	SW_1641	BIARRITZ DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0549	SW_1641	BIARRITZ DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0550	SW_1607	BIARRITZ DR	NORMANDY DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0661	SW_1480	BIARRITZ DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0988	SW_1442	BIARRITZ DR	SHORE LN	SHORE DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1005	SW_1442	BIARRITZ DR	SHORE LN	SHORE DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1590	SW_2055	BIARRITZ DR	TROUVILLE ESPLANADE	WEST END	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1702	SW_2094	BIARRITZ DR	RUE GRANVILLE	71ST ST	Normandy Isles A	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4027	SW_2696	BIARRITZ DR	CALAIS DR	SHORE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4102	SW_2743	BIARRITZ DR	TROUVILLE ESPLANADE	WEST END	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5164	SW_1559	BIARRITZ DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0215	SW_2205	BISCAYNE POINT RD	FOWLER ST	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0776	SW_2602	BISCAYNE POINT RD	FOWLER ST	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0811	SW_2602	BISCAYNE POINT RD	FOWLER ST	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0859	SW_2693	BISCAYNE POINT RD	NOREMAC AVE	FOWLER ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3528	SW_2734	BISCAYNE POINT RD	HAWTHORNE AVE	WEST END	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3561	SW_2748	BISCAYNE POINT RD	HAWTHORNE AVE	WEST END	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3696	SW_2292	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3701	SW_0590	BISCAYNE POINT RD	HAWTHORNE AVE	NOREMAC AVE	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3716	SW_2693	BISCAYNE POINT RD	NOREMAC AVE	FOWLER ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3816	SW_2428	BISCAYNE POINT RD	NOREMAC AVE	CECIL ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3817	SW_3135	BISCAYNE POINT RD	NOREMAC AVE	CECIL ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3931	SW_2554	BISCAYNE POINT RD	CECIL ST	CLEVELAND RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3996	SW_2607	BISCAYNE POINT RD	CECIL ST	CLEVELAND RD	Biscayne Point C	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0064	SW_1156	BONITA DR	BONITA DR	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0080	SW_1156	BONITA DR	BONITA DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3604	SW_0128	BONITA DR	BONITA DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3609	SW_0128	BONITA DR	BONITA DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3935	SW_2524	BONITA DR	INDIAN CREEK DR	BONITA DR	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3947	SW_2524	BONITA DR	INDIAN CREEK DR	BONITA DR	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4008	SW_2653	BONITA DR	71ST ST	NW END	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4038	SW_2673	BONITA DR	71ST ST	NW END	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4665	SW_1156	BONITA DR	BONITA DR	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0225	SW_0719	BREST ESPLANADE	BAY DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0262	SW_0729	BREST ESPLANADE	BAY DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0270	SW_0729	BREST ESPLANADE	BAY DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0287	SW_0747	BREST ESPLANADE	BAY DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2707	SW_3046	BRIDGE RD	MAC ARTHUR CSWY	STAR ISLAND DR	Star and Terminal Island A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2732	SW_3046	BRIDGE RD	MAC ARTHUR CSWY	STAR ISLAND DR	Star and Terminal Island A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3166	SW_1342	BRUCE ST	WAYNE AVE	GARY AVE	Biscayne Point B	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0117	SW_0557	BYRON AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0139	SW_1710	BYRON AVE	80TH ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0150	SW_1693	BYRON AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0195	SW_0821	BYRON AVE	85TH ST	86TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0214	SW_1693	BYRON AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0226	SW_1687	BYRON AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0268	SW_0801	BYRON AVE	86TH ST	NORTH END	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0282	SW_0781	BYRON AVE	86TH ST	NORTH END	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0303	SW_0810	BYRON AVE	85TH ST	86TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0315	SW_0810	BYRON AVE	85TH ST	86TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0368	SW_1991	BYRON AVE	84TH ST	85TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0547	SW_1655	BYRON AVE	76TH ST	77TH ST	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1042	SW_1741	BYRON AVE	80TH ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1088	SW_1788	BYRON AVE	80TH ST	81ST ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1162	SW_2036	BYRON AVE	82ND ST	82ND TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1363	SW_1927	BYRON AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1391	SW_1935	BYRON AVE	81ST ST	82ND ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1573	SW_2020	BYRON AVE	82ND TER	84TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1798	SW_2143	BYRON AVE	76TH ST	77TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1864	SW_2186	BYRON AVE	75TH ST	76TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2273	SW_2441	BYRON AVE	73RD ST	74TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2829	SW_0999	BYRON AVE	74TH ST	75TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2965	SW_2441	BYRON AVE	73RD ST	74TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3922	SW_2715	BYRON AVE	INDIAN CREEK DR	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_4063	SW_2709	BYRON AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4085	SW_2715	BYRON AVE	INDIAN CREEK DR	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4096	SW_2746	BYRON AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4109	SW_2746	BYRON AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4118	SW_2746	BYRON AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4125	SW_2746	BYRON AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4400	SW_3143	BYRON AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_1044	SW_1530	CALAIS DR	BIARRITZ DR	BAY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1147	SW_1530	CALAIS DR	BIARRITZ DR	BAY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1200	SW_1530	CALAIS DR	BIARRITZ DR	BAY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2216	SW_2424	CALAIS DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2675	SW_2337	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2709	SW_2337	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2744	SW_2337	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2831	SW_2337	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2838	SW_2337	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2967	SW_2008	CALAIS DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3053	SW_2008	CALAIS DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3142	SW_2123	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3152	SW_2123	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3174	SW_2123	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3193	SW_2123	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3206	SW_2123	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3225	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3242	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3281	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3333	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3365	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3424	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3457	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_3476	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3938	SW_0812	CALAIS DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3976	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4017	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4023	SW_2659	CALAIS DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4072	SW_2714	CALAIS DR	BIARRITZ DR	BAY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4076	SW_2714	CALAIS DR	BIARRITZ DR	BAY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4084	SW_2714	CALAIS DR	BIARRITZ DR	BAY DR	Normandy Isles A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1165	SW_1816	CARLYLE AVE	80TH ST	TATUM WATERWAY DR	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1456	SW_2218	CARLYLE AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1560	SW_2227	CARLYLE AVE	78TH ST	79TH ST	North Shore B	Not Present	Adequate	Not Adequate	Not Adequate	Not Adequate		$2,500
R_1812	SW_2263	CARLYLE AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1898	SW_2176	CARLYLE AVE	75TH ST	76TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2221	SW_2442	CARLYLE AVE	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_2257	SW_2474	CARLYLE AVE	74TH ST	75TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2309	SW_2463	CARLYLE AVE	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2406	SW_2741	CARLYLE AVE	71ST ST	72ND ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3967	SW_2676	CARLYLE AVE	INDIAN CREEK DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3972	SW_2581	CARLYLE AVE	INDIAN CREEK DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4046	SW_2676	CARLYLE AVE	INDIAN CREEK DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3833	SW_2445	CECIL ST	CLEVELAND RD	BISCAYNE POINT RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3839	SW_2445	CECIL ST	CLEVELAND RD	BISCAYNE POINT RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3852	SW_2445	CECIL ST	CLEVELAND RD	BISCAYNE POINT RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0913	SW_2213	CHASE AVE	40TH CT	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0926	SW_2213	CHASE AVE	40TH CT	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0927	SW_2213	CHASE AVE	40TH CT	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0944	SW_2213	CHASE AVE	40TH CT	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2330	SW_2207	CHASE AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3327	SW_2726	CHASE AVE	CHASE AVE	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3370	SW_2738	CHASE AVE	34TH ST	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3512	SW_2629	CHASE AVE	34TH ST	CHASE AVE	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3573	SW_2700	CHASE AVE	40TH ST	40TH CT	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3578	SW_2700	CHASE AVE	40TH ST	40TH CT	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4056	SW_3040	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4061	SW_3041	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4066	SW_3041	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4070	SW_3041	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4126	SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4128	SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4132	SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4134	SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4955	SW_1791	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5080	SW_1818	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5081	SW_1818	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5099	SW_1818	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5101	SW_1818	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5109	SW_1844	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5111	SW_1872	CHASE AVE	41ST ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5114	SW_3177	CHASE AVE	44TH ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5121	SW_1897	CHASE AVE	44TH ST	PRAIRIE AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5128	SW_1897	CHASE AVE	44TH ST	PRAIRIE AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_3977	SW_2570	CLEVELAND RD	CECIL ST	BISCAYNE POINT RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_4024	SW_2625	CLEVELAND RD	BISCAYNE POINT RD	HENEDON AVE	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_4028	SW_2641	CLEVELAND RD	HENEDON AVE	BISCAYNE POINT CIR	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_4120	SW_1713	CLEVELAND RD	HENEDON AVE	BISCAYNE POINT CIR	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_5085	SW_1835	CLEVELAND RD	BISCAYNE POINT RD	HENEDON AVE	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_5134	SW_1906	CLEVELAND RD	NOREMAC AVE	CECIL ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_5148	SW_1906	CLEVELAND RD	NOREMAC AVE	CECIL ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0003	SW_0948	COLLINS AVE	85TH ST	86TH ST	North Shore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0004	SW_0949	COLLINS AVE	86TH ST	87TH ST	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0013	SW_1182	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0042	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0044	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0050	SW_0013	COLLINS AVE	87TH ST	87TH TER	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0059	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0065	SW_0026	COLLINS AVE	86TH ST	87TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0076	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_0077	SW_0949	COLLINS AVE	86TH ST	87TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0093	SW_0699	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0116	SW_0989	COLLINS AVE	87TH ST	87TH TER	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0120	SW_0171	COLLINS AVE	82ND ST	83RD ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0124	SW_0989	COLLINS AVE	87TH ST	87TH TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0128	SW_0389	COLLINS AVE	80TH ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0140	SW_0453	COLLINS AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0151	SW_0446	COLLINS AVE	80TH ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0176	SW_0459	COLLINS AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0183	SW_0461	COLLINS AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0197	SW_0459	COLLINS AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0223	SW_0501	COLLINS AVE	76TH ST	77TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0298	SW_1082	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0299	SW_1270	COLLINS AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0359	SW_1134	COLLINS AVE	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0361	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0371	SW_0748	COLLINS AVE	76TH ST	77TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0405	SW_1141	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0406	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0423	SW_1115	COLLINS AVE	75TH ST	76TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0444	SW_1072	COLLINS AVE	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0457	SW_0699	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0472	SW_1187	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0477	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0482	SW_0364	COLLINS AVE	82ND ST	83RD ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0488	SW_1290	COLLINS AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0498	SW_0920	COLLINS AVE	85TH ST	86TH ST	North Shore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0501	SW_1187	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0519	SW_1187	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0548	SW_1187	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0592	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0619	SW_0392	COLLINS AVE	81ST ST	82ND ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0622	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0623	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0636	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0680	SW_1290	COLLINS AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0689	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_0708	SW_1298	COLLINS AVE	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0714	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_0716	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0748	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0852	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0858	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0879	SW_1072	COLLINS AVE	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0881	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0892	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0905	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0907	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0923	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0937	SW_1064	COLLINS AVE	11TH ST	12TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0938	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0942	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0954	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0980	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0991	SW_3185	COLLINS AVE	43RD ST	44TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1001	SW_0989	COLLINS AVE	87TH ST	87TH TER	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1029	SW_1729	COLLINS AVE	72ND ST	73RD ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1046	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1049	SW_1134	COLLINS AVE	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1075	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1082	SW_1120	COLLINS AVE	11TH ST	12TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1105	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1106	SW_1695	COLLINS AVE	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1116	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1121	SW_1298	COLLINS AVE	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1125	SW_0457	COLLINS AVE	79TH ST	80TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1128	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1135	SW_0369	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1148	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1166	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1186	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1187	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1201	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1209	SW_0170	COLLINS AVE	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1230	SW_1064	COLLINS AVE	11TH ST	12TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1231	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1256	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1257	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1265	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1268	SW_0122	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1285	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1288	SW_0122	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1294	SW_1633	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1295	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1307	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1311	SW_1633	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1330	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1340	SW_0122	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1348	SW_1702	COLLINS AVE	74TH ST	75TH ST	North Shore C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1349	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1358	SW_1052	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1359	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1392	SW_1742	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1405	SW_1742	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1416	SW_1120	COLLINS AVE	11TH ST	12TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1419	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1420	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1426	SW_1313	COLLINS AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1430	SW_1790	COLLINS AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_1441	SW_1790	COLLINS AVE	71ST ST	72ND ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1452	SW_1098	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1457	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1458	SW_1064	COLLINS AVE	11TH ST	12TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1476	SW_1810	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1488	SW_1313	COLLINS AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1492	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1494	SW_1810	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1514	SW_1842	COLLINS AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_1516	SW_1842	COLLINS AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_1517	SW_1090	COLLINS AVE	14TH ST	14th PLACE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1529	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1534	SW_2661	COLLINS AVE	24TH ST	25TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1545	SW_1842	COLLINS AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1546	SW_0811	COLLINS AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1579	SW_1335	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1583	SW_0170	COLLINS AVE	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1591	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1603	SW_2225	COLLINS AVE	14TH ST	14th PLACE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1624	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1630	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1634	SW_2236	COLLINS AVE	14th PLACE	ESPANOLA WAY	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1650	SW_2661	COLLINS AVE	24TH ST	25TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1653	SW_2241	COLLINS AVE	ESPANOLA WAY	15TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1654	SW_2241	COLLINS AVE	ESPANOLA WAY	15TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1679	SW_1072	COLLINS AVE	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1681	SW_2241	COLLINS AVE	ESPANOLA WAY	15TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1716	SW_1082	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1717	SW_1335	COLLINS AVE	23RD ST	24TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1728	SW_1920	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1729	SW_1920	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1736	SW_1082	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1743	SW_1346	COLLINS AVE	23RD ST	24TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1755	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1763	SW_0187	COLLINS AVE	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1777	SW_2028	COLLINS AVE	32ND ST	33RD ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1780	SW_1090	COLLINS AVE	14TH ST	14th PLACE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1781	SW_1346	COLLINS AVE	23RD ST	24TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1817	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1825	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1859	SW_1098	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1860	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1868	SW_0187	COLLINS AVE	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1911	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_1914	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1933	SW_1111	COLLINS AVE	14th PLACE	ESPANOLA WAY	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1945	SW_2021	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1951	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1958	SW_2021	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1985	SW_0561	COLLINS AVE	73RD ST	74TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2036	SW_2157	COLLINS AVE	ESPANOLA WAY	15TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2046	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2056	SW_2157	COLLINS AVE	ESPANOLA WAY	15TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2057	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2059	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2060	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2086	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2087	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2106	SW_2157	COLLINS AVE	ESPANOLA WAY	15TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2107	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2120	SW_2088	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2121	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_2129	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2130	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2142	SW_2088	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2143	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2151	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2152	SW_1346	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2159	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2169	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2170	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2171	SW_1367	COLLINS AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2191	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2222	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2225	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2226	SW_1412	COLLINS AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2229	SW_0245	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2246	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2247	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2248	SW_1412	COLLINS AVE	20TH ST	21ST ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2251	SW_0245	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2256	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2275	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2276	SW_2144	COLLINS AVE	64TH ST	65TH ST	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_2281	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2282	SW_1412	COLLINS AVE	20TH ST	21ST ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2284	SW_0245	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2290	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2301	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2302	SW_1412	COLLINS AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2310	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2312	SW_2145	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2313	SW_0245	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2314	SW_0245	COLLINS AVE	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2324	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2329	SW_2144	COLLINS AVE	64TH ST	65TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2335	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2336	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2343	SW_0369	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2364	SW_2144	COLLINS AVE	64TH ST	65TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2367	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2386	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2390	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2397	SW_2225	COLLINS AVE	14TH ST	14th PLACE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2398	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2408	SW_2145	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2415	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2424	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2425	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2442	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2443	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2450	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2451	SW_1450	COLLINS AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2457	SW_0773	COLLINS AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2458	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2459	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2460	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2461	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2466	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2467	SW_1152	COLLINS AVE	15TH ST	16TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2468	SW_1450	COLLINS AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2477	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2478	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2479	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2481	SW_0276	COLLINS AVE	5TH ST	6TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2489	SW_1450	COLLINS AVE	22ND ST	23RD ST	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2491	SW_0276	COLLINS AVE	5TH ST	6TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2495	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2496	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2497	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2509	SW_0276	COLLINS AVE	5TH ST	6TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2516	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2524	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2527	SW_0276	COLLINS AVE	5TH ST	6TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2532	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2539	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2555	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2559	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2562	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2571	SW_2203	COLLINS AVE	BEACH ACCESS WALK	INDIAN CREEK DR	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2581	SW_1182	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2582	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2591	SW_2203	COLLINS AVE	BEACH ACCESS WALK	INDIAN CREEK DR	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2601	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2602	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2603	SW_2196	COLLINS AVE	INDIAN CREEK DR	60TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2604	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2609	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2610	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2611	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2612	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2627	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2628	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2630	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2631	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2632	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2641	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2645	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2647	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2660	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2661	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2666	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2667	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2681	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2689	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2704	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2712	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2721	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2727	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2735	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2743	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2759	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2760	SW_2281	COLLINS AVE	46TH ST	INDIAN CREEK DR	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2775	SW_2281	COLLINS AVE	46TH ST	INDIAN CREEK DR	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2785	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2795	SW_0811	COLLINS AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2804	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2812	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2813	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2839	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2840	SW_0875	COLLINS AVE	40TH ST	41ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2862	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2863	SW_2347	COLLINS AVE	46TH ST	INDIAN CREEK DR	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2864	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2865	SW_2348	COLLINS AVE	46TH ST	INDIAN CREEK DR	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2876	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_2877	SW_2347	COLLINS AVE	46TH ST	INDIAN CREEK DR	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2878	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2879	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2880	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2888	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2889	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2910	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2913	SW_1879	COLLINS AVE	34TH ST	35TH ST	Oceanfront A	Damaged	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_2922	SW_2348	COLLINS AVE	46TH ST	INDIAN CREEK DR	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2923	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2925	SW_1001	COLLINS AVE	39TH ST	40TH ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2927	SW_1834	COLLINS AVE	34TH ST	35TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2935	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2938	SW_1147	COLLINS AVE	38TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2939	SW_1001	COLLINS AVE	39TH ST	40TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2951	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2955	SW_1879	COLLINS AVE	34TH ST	35TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2970	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2972	SW_1147	COLLINS AVE	38TH ST	39TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2981	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2983	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2985	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2986	SW_1147	COLLINS AVE	38TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2987	SW_1879	COLLINS AVE	34TH ST	35TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2993	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2996	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3011	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3012	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3022	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3027	SW_2004	COLLINS AVE	33RD ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3034	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3037	SW_2004	COLLINS AVE	33RD ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3044	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3048	SW_2004	COLLINS AVE	33RD ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3054	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3066	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3067	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3069	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3070	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3072	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3084	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3086	SW_1177	COLLINS AVE	38TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3087	SW_1177	COLLINS AVE	38TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3102	SW_1187	COLLINS AVE	65TH ST	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3105	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3129	SW_1275	COLLINS AVE	37TH ST	38TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3155	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3157	SW_2004	COLLINS AVE	33RD ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3163	SW_1082	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3167	SW_2004	COLLINS AVE	33RD ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3177	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3185	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3194	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3195	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3197	SW_2004	COLLINS AVE	33RD ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3209	SW_2038	COLLINS AVE	32ND ST	33RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3215	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3217	SW_1373	COLLINS AVE	37TH ST	38TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3226	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3236	SW_2028	COLLINS AVE	32ND ST	33RD ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3251	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3274	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3276	SW_2038	COLLINS AVE	32ND ST	33RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3282	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3284	SW_2038	COLLINS AVE	32ND ST	33RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3291	SW_1523	COLLINS AVE	36TH ST	37TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3292	SW_2038	COLLINS AVE	32ND ST	33RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3300	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3312	SW_1523	COLLINS AVE	36TH ST	37TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3321	SW_2300	COLLINS AVE	60TH ST	63RD ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3323	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3324	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3325	SW_1523	COLLINS AVE	36TH ST	37TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3336	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3354	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3367	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3374	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_3384	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3396	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3399	SW_2167	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3404	SW_1098	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_3407	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3419	SW_2167	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3423	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3425	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3427	SW_2161	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3436	SW_1730	COLLINS AVE	35TH ST	36TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3442	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3445	SW_2167	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3450	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3452	SW_2161	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3460	SW_1730	COLLINS AVE	35TH ST	36TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3461	SW_2167	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3467	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3469	SW_1730	COLLINS AVE	35TH ST	36TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3470	SW_2167	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3479	SW_2161	COLLINS AVE	31ST ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3494	SW_2239	COLLINS AVE	30TH ST	31ST ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3495	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Not Adequate	Not Adequate	Not Adequate		$2,500
R_3497	SW_1730	COLLINS AVE	35TH ST	36TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3505	SW_2400	COLLINS AVE	46TH ST	53RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3511	SW_0312	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_3529	SW_1764	COLLINS AVE	35TH ST	36TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3544	SW_2282	COLLINS AVE	INDIAN CREEK DR	60TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3555	SW_2710	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3576	SW_2282	COLLINS AVE	INDIAN CREEK DR	60TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3582	SW_2282	COLLINS AVE	INDIAN CREEK DR	60TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3591	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3592	SW_2239	COLLINS AVE	30TH ST	31ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3612	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3616	SW_2229	COLLINS AVE	30TH ST	31ST ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3619	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3620	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3621	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3628	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3630	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3631	SW_2239	COLLINS AVE	30TH ST	31ST ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3636	SW_3185	COLLINS AVE	43RD ST	44TH ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3644	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3645	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3646	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3647	SW_0472	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3674	SW_0477	COLLINS AVE	42ND ST	43RD ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3679	SW_1688	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3681	SW_2293	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3725	SW_2293	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3726	SW_2349	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3727	SW_2349	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3728	SW_2349	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3737	SW_2293	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3740	SW_2349	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3741	SW_2349	COLLINS AVE	29TH ST	30TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3780	SW_0623	COLLINS AVE	42ND ST	43RD ST	Oceanfront A	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3789	SW_0626	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3790	SW_0623	COLLINS AVE	42ND ST	43RD ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3796	SW_1507	COLLINS AVE	23RD ST	24TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_3798	SW_0626	COLLINS AVE	43RD ST	44TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3832	SW_2444	COLLINS AVE	28TH ST	29TH ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3834	SW_2456	COLLINS AVE	28TH ST	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3851	SW_0638	COLLINS AVE	41ST ST	42ND ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3858	SW_0638	COLLINS AVE	41ST ST	42ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3865	SW_0638	COLLINS AVE	41ST ST	42ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3866	SW_2484	COLLINS AVE	27TH ST	28TH ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3904	SW_1105	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3924	SW_2543	COLLINS AVE	27TH ST	28TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3930	SW_0875	COLLINS AVE	40TH ST	41ST ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3943	SW_0875	COLLINS AVE	40TH ST	41ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3944	SW_2543	COLLINS AVE	27TH ST	28TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3983	SW_2609	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3985	SW_0312	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4003	SW_2609	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4004	SW_2609	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4009	SW_2609	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4010	SW_2609	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4011	SW_2609	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4012	SW_2617	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4033	SW_2645	COLLINS AVE	25TH ST	INDIAN CREEK DR	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4039	SW_2655	COLLINS AVE	24TH ST	25TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4043	SW_2655	COLLINS AVE	24TH ST	25TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4047	SW_2661	COLLINS AVE	24TH ST	25TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4052	SW_2661	COLLINS AVE	24TH ST	25TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4053	SW_2661	COLLINS AVE	24TH ST	25TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4054	SW_2661	COLLINS AVE	24TH ST	25TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4057	SW_1182	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4068	SW_1077	COLLINS AVE	25TH ST	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4073	SW_1077	COLLINS AVE	25TH ST	INDIAN CREEK DR	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4080	SW_1105	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_4089	SW_1105	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4090	SW_1105	COLLINS AVE	26TH ST	27TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4138	SW_0312	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4146	SW_1429	COLLINS AVE	INDIAN CREEK DR	46TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4155	SW_1182	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4158	SW_0312	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4178	SW_2196	COLLINS AVE	INDIAN CREEK DR	60TH ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4190	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4202	SW_2195	COLLINS AVE	60TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4203	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4205	SW_0003	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4215	SW_0003	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4220	SW_0003	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_4221	SW_0329	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4239	SW_0003	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4240	SW_0003	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4241	SW_0329	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4251	SW_1256	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4254	SW_0329	COLLINS AVE	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4262	SW_1213	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4274	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4290	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4291	SW_3112	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4294	SW_0354	COLLINS AVE	7TH ST	8TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4303	SW_3112	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4315	SW_2160	COLLINS AVE	63RD ST	64TH ST	North Shore F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4318	SW_0354	COLLINS AVE	7TH ST	8TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4346	SW_1213	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4351	SW_0354	COLLINS AVE	7TH ST	8TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4363	SW_1213	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4378	SW_0280	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4390	SW_2133	COLLINS AVE	65TH ST	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4403	SW_1213	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4405	SW_0280	COLLINS AVE	POINTE DR	1ST ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4407	SW_0311	COLLINS AVE	1ST ST	2ND ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4455	SW_0376	COLLINS AVE	7TH ST	8TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4464	SW_0311	COLLINS AVE	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4492	SW_0376	COLLINS AVE	7TH ST	8TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4499	SW_1233	COLLINS AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4512	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4525	SW_0696	COLLINS AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4544	SW_0391	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4545	SW_0391	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4555	SW_0391	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4573	SW_0391	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4607	SW_1842	COLLINS AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4624	SW_1842	COLLINS AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4625	SW_1842	COLLINS AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4639	SW_0408	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4640	SW_0408	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4649	SW_0353	COLLINS AVE	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4656	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4658	SW_0353	COLLINS AVE	1ST ST	2ND ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4660	SW_0408	COLLINS AVE	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4667	SW_0353	COLLINS AVE	1ST ST	2ND ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4684	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4685	SW_1233	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4696	SW_1233	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4704	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4705	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4708	SW_0353	COLLINS AVE	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4710	SW_0415	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4716	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4727	SW_0415	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4735	SW_0415	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4743	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4756	SW_1233	COLLINS AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4759	SW_0415	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4763	SW_1242	COLLINS AVE	15TH ST	16TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4766	SW_0369	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4780	SW_1052	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4781	SW_1052	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4786	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4789	SW_0369	COLLINS AVE	2ND ST	3RD ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4802	SW_1261	COLLINS AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4812	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4821	SW_0422	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4826	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4828	SW_0422	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4842	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4844	SW_0422	COLLINS AVE	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4849	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4857	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4858	SW_1261	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4864	SW_1261	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4877	SW_1261	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4885	SW_1261	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4886	SW_1261	COLLINS AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4901	SW_1252	COLLINS AVE	16TH ST	LINCOLN RD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4993	SW_1270	COLLINS AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_5035	SW_1141	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5045	SW_1327	COLLINS AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5049	SW_1082	COLLINS AVE	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5084	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_5089	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5115	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5132	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5144	SW_1279	COLLINS AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5189	SW_1052	COLLINS AVE	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5191	SW_1356	COLLINS AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0205	SW_0603	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0543	SW_0541	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0885	SW_0603	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0949	SW_0603	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0984	SW_0603	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1055	SW_0603	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2110	SW_0541	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5048	SW_0541	COMMERCE ST	WASHINGTON AVE	ALTON RD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0934	SW_2042	CONVENTION CENTER DR	17TH ST	18TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0963	SW_2042	CONVENTION CENTER DR	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0964	SW_2042	CONVENTION CENTER DR	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0987	SW_1083	CONVENTION CENTER DR	19TH ST	DADE BLVD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1004	SW_1099	CONVENTION CENTER DR	19TH ST	DADE BLVD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1102	SW_1121	CONVENTION CENTER DR	19TH ST	DADE BLVD	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1144	SW_1183	CONVENTION CENTER DR	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1197	SW_1183	CONVENTION CENTER DR	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1215	SW_1183	CONVENTION CENTER DR	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1258	SW_1623	CRESPI BLVD	85TH ST	86TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2940	SW_1843	CRESPI BLVD	80TH ST	81ST ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3355	SW_1550	CRESPI BLVD	84TH ST	85TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3368	SW_1635	CRESPI BLVD	80TH ST	81ST ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3377	SW_1635	CRESPI BLVD	80TH ST	81ST ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3451	SW_1703	CRESPI BLVD	79TH ST	79TH TER	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3468	SW_1744	CRESPI BLVD	HAWTHORNE AVE	79TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3487	SW_1744	CRESPI BLVD	HAWTHORNE AVE	79TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3488	SW_1755	CRESPI BLVD	HAWTHORNE AVE	79TH ST	Biscayne Point A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3517	SW_1744	CRESPI BLVD	HAWTHORNE AVE	79TH ST	Biscayne Point A	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3547	SW_1755	CRESPI BLVD	HAWTHORNE AVE	79TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0112	SW_2782	DADE BLVD	MICHIGAN AVE	18TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0513	SW_0094	DADE BLVD	PURDY AVE	VENETIAN WAY	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0521	SW_0158	DADE BLVD	PURDY AVE	VENETIAN WAY	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0528	SW_0209	DADE BLVD	ALTON RD	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0538	SW_0209	DADE BLVD	ALTON RD	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0678	SW_0593	DADE BLVD	MERIDIAN AVE	MICHIGAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0679	SW_0593	DADE BLVD	MERIDIAN AVE	MICHIGAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0737	SW_0209	DADE BLVD	ALTON RD	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0786	SW_0988	DADE BLVD	MERIDIAN AVE	MICHIGAN AVE	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1056	SW_1112	DADE BLVD	CONVENTION CENTER DR	MERIDIAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2108	SW_0102	DADE BLVD	ALTON RD	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2203	SW_0105	DADE BLVD	WEST AVE	BAY RD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2227	SW_0102	DADE BLVD	ALTON RD	WEST AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2253	SW_1751	DADE BLVD	23RD ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2271	SW_1751	DADE BLVD	23RD ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2417	SW_0121	DADE BLVD	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2418	SW_0121	DADE BLVD	BAY RD	PURDY AVE	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2741	SW_1751	DADE BLVD	23RD ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_3380	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3391	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3401	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3412	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3438	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3453	SW_2537	DADE BLVD	23RD ST	WASHINGTON AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3462	SW_2612	DADE BLVD	WASHINGTON AVE	CONVENTION CENTER DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3471	SW_2612	DADE BLVD	WASHINGTON AVE	CONVENTION CENTER DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3491	SW_2612	DADE BLVD	WASHINGTON AVE	CONVENTION CENTER DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3510	SW_2612	DADE BLVD	WASHINGTON AVE	CONVENTION CENTER DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3521	SW_2612	DADE BLVD	WASHINGTON AVE	CONVENTION CENTER DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3558	SW_2687	DADE BLVD	CONVENTION CENTER DR	MERIDIAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3598	SW_2687	DADE BLVD	CONVENTION CENTER DR	MERIDIAN AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_4957	SW_2782	DADE BLVD	MICHIGAN AVE	18TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4967	SW_2782	DADE BLVD	MICHIGAN AVE	18TH ST	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0081	SW_2082	DAYTONIA RD	NOREMAC AVE	FOWLER ST	Biscayne Point C	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0439	SW_2403	DAYTONIA RD	BISCAYNE POINT RD	HENEDON AVE	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0453	SW_2403	DAYTONIA RD	BISCAYNE POINT RD	HENEDON AVE	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0485	SW_2451	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0487	SW_2451	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0638	SW_2504	DAYTONIA RD	HENEDON AVE	BISCAYNE POINT CIR	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0651	SW_2583	DAYTONIA RD	BISCAYNE POINT RD	HENEDON AVE	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_5157	SW_1938	DAYTONIA RD	NOREMAC AVE	FOWLER ST	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0041	SW_0014	DELAWARE AVE	50TH ST	51ST ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_0237	SW_0237	DELAWARE AVE	49TH ST	50TH ST	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_2594	SW_2864	DI LIDO DR	VENETIAN DI LIDO WAY	5TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2739	SW_0587	DI LIDO DR	5TH DI LIDO TER	6TH DI LIDO TER	Venetian Islands A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2815	SW_2871	DI LIDO DR	6TH DI LIDO TER	7TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2873	SW_2875	DI LIDO DR	7TH DI LIDO TER	8TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2885	SW_2875	DI LIDO DR	7TH DI LIDO TER	8TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2905	SW_3091	DI LIDO DR	8TH DI LIDO TER	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3040	SW_0126	DI LIDO DR	7TH DI LIDO TER	8TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3051	SW_0126	DI LIDO DR	7TH DI LIDO TER	8TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3079	SW_2890	DI LIDO DR	6TH DI LIDO TER	7TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3113	SW_2896	DI LIDO DR	VENETIAN DI LIDO WAY	5TH DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3422	SW_2923	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3463	SW_2923	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3542	SW_2929	DI LIDO DR	2ND DI LIDO TER	3RD DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_3574	SW_2932	DI LIDO DR	1ST DI LIDO TER	2ND DI LIDO TER	Venetian Islands A	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3587	SW_2935	DI LIDO DR	DI LIDO DR	1ST DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3601	SW_2940	DI LIDO DR	2ND DI LIDO TER	3RD DI LIDO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3602	SW_2942	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3608	SW_3092	DI LIDO DR	4TH DI LIDO TER	VENETIAN DI LIDO WAY	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0175	SW_1222	DICKENS AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0227	SW_1274	DICKENS AVE	72ND ST	73RD ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_0414	SW_1428	DICKENS AVE	74TH ST	75TH ST	North Shore C	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0841	SW_1615	DICKENS AVE	77TH ST	78TH ST	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1824	SW_2175	DICKENS AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1897	SW_2238	DICKENS AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1944	SW_2243	DICKENS AVE	78TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2140	SW_2394	DICKENS AVE	75TH ST	76TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2199	SW_2411	DICKENS AVE	73RD ST	74TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3175	SW_2648	DICKENS AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3990	SW_2648	DICKENS AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3995	SW_2648	DICKENS AVE	71ST ST	72ND ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4002	SW_2648	DICKENS AVE	71ST ST	72ND ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4067	SW_1222	DICKENS AVE	71ST ST	72ND ST	North Shore D	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4819	SW_1274	DICKENS AVE	72ND ST	73RD ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1557	SW_1900	DREXEL AVE	LINCOLN LN	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1980	SW_1882	DREXEL AVE	16TH ST	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2014	SW_1865	DREXEL AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2243	SW_1865	DREXEL AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2263	SW_1874	DREXEL AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2486	SW_1848	DREXEL AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2599	SW_1857	DREXEL AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3414	SW_1848	DREXEL AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3415	SW_1847	DREXEL AVE	SOUTH END	ESPANOLA WAY	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4387	SW_1803	DREXEL AVE	13TH ST	14TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4605	SW_1784	DREXEL AVE	12TH ST	13TH ST	Flamingo/Lummus F	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4806	SW_1792	DREXEL AVE	12TH ST	13TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4870	SW_1792	DREXEL AVE	12TH ST	13TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4876	SW_1837	DREXEL AVE	SOUTH END	ESPANOLA WAY	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4883	SW_1882	DREXEL AVE	16TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4892	SW_3209	DREXEL AVE	LINCOLN RD	LINCOLN LN	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4908	SW_1899	DREXEL AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4916	SW_1900	DREXEL AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5012	SW_1803	DREXEL AVE	13TH ST	14TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5017	SW_1803	DREXEL AVE	13TH ST	14TH ST	Flamingo/Lummus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0301	SW_0727	ESPANOLA WAY	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0302	SW_0745	ESPANOLA WAY	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_1266	SW_2129	ESPANOLA WAY	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1286	SW_2148	ESPANOLA WAY	COLLINS AVE	COLLINS CT	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1314	SW_2172	ESPANOLA WAY	COLLINS AVE	COLLINS CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1338	SW_2199	ESPANOLA WAY	COLLINS CT	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1990	SW_2172	ESPANOLA WAY	COLLINS AVE	COLLINS CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2017	SW_2148	ESPANOLA WAY	COLLINS AVE	COLLINS CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4249	SW_1437	ESPANOLA WAY	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4260	SW_1456	ESPANOLA WAY	DREXEL AVE	PENNSYLVANIA AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4567	SW_1140	ESPANOLA WAY	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4578	SW_0727	ESPANOLA WAY	MERIDIAN AVE	JEFFERSON AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5033	SW_1109	ESPANOLA WAY	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5036	SW_1109	ESPANOLA WAY	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5037	SW_1119	ESPANOLA WAY	EUCLID AVE	MERIDIAN AVE	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5042	SW_1131	ESPANOLA WAY	PENNSYLVANIA AVE	EUCLID AVE	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0206	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0460	SW_0684	EUCLID AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0490	SW_1296	EUCLID AVE	LINCOLN LN	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0594	SW_0704	EUCLID AVE	LINCOLN LN	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0595	SW_0704	EUCLID AVE	LINCOLN LN	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0742	SW_1178	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0757	SW_1226	EUCLID AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0797	SW_0669	EUCLID AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0867	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1067	SW_0695	EUCLID AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_1224	SW_1288	EUCLID AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1299	SW_1149	EUCLID AVE	7TH ST	8TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1410	SW_1288	EUCLID AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1467	SW_1288	EUCLID AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1696	SW_1129	EUCLID AVE	8TH ST	9TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1978	SW_1107	EUCLID AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2231	SW_0856	EUCLID AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2259	SW_0856	EUCLID AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2342	SW_0856	EUCLID AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2377	SW_0866	EUCLID AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2430	SW_0866	EUCLID AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2445	SW_0888	EUCLID AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2446	SW_1088	EUCLID AVE	10TH ST	11TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2454	SW_0866	EUCLID AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2462	SW_1095	EUCLID AVE	10TH ST	11TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2471	SW_0951	EUCLID AVE	3RD ST	4TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2484	SW_1129	EUCLID AVE	8TH ST	9TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2501	SW_0888	EUCLID AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2502	SW_1118	EUCLID AVE	8TH ST	9TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2512	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2529	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2547	SW_0888	EUCLID AVE	3RD ST	4TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2548	SW_0888	EUCLID AVE	3RD ST	4TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2549	SW_1178	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2567	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2597	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2635	SW_0951	EUCLID AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4628	SW_1168	EUCLID AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4838	SW_0548	EUCLID AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4846	SW_0558	EUCLID AVE	12TH ST	13TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4899	SW_0582	EUCLID AVE	13TH ST	14TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4928	SW_1006	EUCLID AVE	13TH ST	14TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_5003	SW_0647	EUCLID AVE	14TH ST	14TH PL	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5021	SW_0647	EUCLID AVE	14TH ST	14TH PL	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5025	SW_1036	EUCLID AVE	14TH ST	14TH PL	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_5026	SW_0669	EUCLID AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5041	SW_0669	EUCLID AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5051	SW_1169	EUCLID AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0410	SW_0842	FAIRWAY DR	SHORE DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0421	SW_0842	FAIRWAY DR	SHORE DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0448	SW_0842	FAIRWAY DR	SHORE DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1103	SW_1527	FAIRWAY DR	SARAZEN ST	SHORE DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1164	SW_1206	FAIRWAY DR	MITCHELL ST	SARAZEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1198	SW_1527	FAIRWAY DR	SARAZEN ST	SHORE DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1473	SW_1206	FAIRWAY DR	MITCHELL ST	SARAZEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1526	SW_1264	FAIRWAY DR	VARDON ST	MITCHELL ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1611	SW_1264	FAIRWAY DR	VARDON ST	MITCHELL ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1656	SW_1330	FAIRWAY DR	FAIRWAY DR	VARDON ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1786	SW_2643	FLAMINGO DR	35TH ST	40TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1855	SW_2643	FLAMINGO DR	35TH ST	40TH ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1866	SW_2643	FLAMINGO DR	35TH ST	40TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1959	SW_2643	FLAMINGO DR	35TH ST	40TH ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2331	SW_1392	FLAMINGO DR	24TH TER	LAKE PANCOAST DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2351	SW_2248	FLAMINGO DR	24TH ST	24TH TER	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2368	SW_1427	FLAMINGO DR	24TH ST	SOUTH END	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2427	SW_2248	FLAMINGO DR	24TH ST	24TH TER	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2499	SW_2248	FLAMINGO DR	24TH ST	24TH TER	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2736	SW_2366	FLAMINGO DR	24TH TER	LAKE PANCOAST DR	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3028	SW_2572	FLAMINGO DR	25TH ST	26TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3256	SW_2670	FLAMINGO DR	26TH ST	28TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_4106	SW_2643	FLAMINGO DR	35TH ST	40TH ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2695	SW_2458	FLAMINGO PL	24TH TER	25TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2871	SW_2557	FLAMINGO PL	25TH ST	26TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1906	SW_0905	FLAMINGO WAY	WEST AVE	BAY RD	West Avenue and Bay Road A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2034	SW_0965	FLAMINGO WAY	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4997	SW_0656	FOUNTAIN ST	PALM MIDWAY	PALM AVE	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4999	SW_3193	FOUNTAIN ST	PALM AVE	MAC ARTHUR CSWY	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5199	SW_3192	FOUNTAIN ST	PALM AVE	PALM AVE	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5200	SW_3192	FOUNTAIN ST	PALM AVE	PALM AVE	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5201	SW_0656	FOUNTAIN ST	PALM MIDWAY	PALM AVE	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5204	SW_3195	FOUNTAIN ST	PALM AVE	FOUNTAIN ST	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5205	SW_3195	FOUNTAIN ST	PALM AVE	FOUNTAIN ST	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5206	SW_3195	FOUNTAIN ST	PALM AVE	FOUNTAIN ST	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0141	SW_2265	FOWLER ST	BISCAYNE POINT RD	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_5182	SW_1994	FOWLER ST	BISCAYNE POINT RD	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_5185	SW_1994	FOWLER ST	BISCAYNE POINT RD	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3919	SW_2652	GARDEN AVE	40TH ST	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3950	SW_0398	GARDEN AVE	39TH ST	40TH ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4939	SW_2778	GARDEN AVE	MERIDIAN AVE	BARRY ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4944	SW_2736	GARDEN AVE	BARRY ST	39TH ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4973	SW_2812	GARDEN AVE	39TH ST	40TH ST	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4979	SW_2812	GARDEN AVE	39TH ST	40TH ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_5127	SW_2812	GARDEN AVE	39TH ST	40TH ST	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5135	SW_2812	GARDEN AVE	39TH ST	40TH ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0123	SW_0718	HARDING AVE	67TH ST	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_0134	SW_0718	HARDING AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0160	SW_1030	HARDING AVE	85TH ST	84TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0184	SW_1020	HARDING AVE	86TH ST	85TH ST	North Shore A	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0211	SW_0756	HARDING AVE	86TH ST	85TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0239	SW_0756	HARDING AVE	86TH ST	85TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0269	SW_1032	HARDING AVE	85TH ST	84TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0350	SW_1100	HARDING AVE	84TH ST	83RD ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0412	SW_1136	HARDING AVE	84TH ST	83RD ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0434	SW_1032	HARDING AVE	85TH ST	84TH ST	North Shore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0481	SW_0896	HARDING AVE	NORTH END	87TH TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0531	SW_0934	HARDING AVE	NORTH END	87TH TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0545	SW_0958	HARDING AVE	NORTH END	87TH TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0565	SW_0958	HARDING AVE	NORTH END	87TH TER	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0673	SW_1281	HARDING AVE	82ND ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0808	SW_1348	HARDING AVE	81ST ST	80TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1002	SW_0882	HARDING AVE	87TH TER	87TH ST	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1051	SW_0934	HARDING AVE	NORTH END	87TH TER	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1403	SW_1155	HARDING AVE	78TH ST	77TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1559	SW_1255	HARDING AVE	77TH ST	76TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1597	SW_1463	HARDING AVE	81ST ST	80TH ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1669	SW_1453	HARDING AVE	82ND ST	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1711	SW_1349	HARDING AVE	76TH ST	75TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1797	SW_1479	HARDING AVE	75TH ST	74TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1811	SW_1453	HARDING AVE	82ND ST	81ST ST	North Shore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1878	SW_1511	HARDING AVE	80TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1924	SW_1528	HARDING AVE	80TH ST	79TH ST	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_2272	SW_1670	HARDING AVE	78TH ST	77TH ST	North Shore B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2494	SW_1740	HARDING AVE	77TH ST	76TH ST	North Shore C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2570	SW_1761	HARDING AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2693	SW_1861	HARDING AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2711	SW_1861	HARDING AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2720	SW_1861	HARDING AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2742	SW_1861	HARDING AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2751	SW_1869	HARDING AVE	75TH ST	74TH ST	North Shore C	Damaged	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_2783	SW_1861	HARDING AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_2784	SW_1869	HARDING AVE	75TH ST	74TH ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2896	SW_1934	HARDING AVE	74TH ST	73RD ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2908	SW_1934	HARDING AVE	74TH ST	73RD ST	North Shore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3484	SW_2242	HARDING AVE	71ST ST	72ND ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3643	SW_2316	HARDING AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3653	SW_2316	HARDING AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3661	SW_2316	HARDING AVE	69TH ST	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3788	SW_2368	HARDING AVE	67TH ST	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_4570	SW_0718	HARDING AVE	67TH ST	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4635	SW_1861	HARDING AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4723	SW_2316	HARDING AVE	69TH ST	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4871	SW_1546	HARDING AVE	74TH ST	73RD ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0551	SW_1369	HAWTHORNE AVE	84TH ST	85TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0675	SW_1197	HAWTHORNE AVE	83RD ST	STILLWATER DR	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0890	SW_1323	HAWTHORNE AVE	85TH ST	86TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0891	SW_1369	HAWTHORNE AVE	84TH ST	85TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1010	SW_1512	HAWTHORNE AVE	85TH ST	86TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_1885	SW_2151	HAWTHORNE AVE	83RD ST	STILLWATER DR	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_2441	SW_2151	HAWTHORNE AVE	83RD ST	STILLWATER DR	Biscayne Point A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2629	SW_2590	HAWTHORNE AVE	82ND ST	83RD ST	Biscayne Point A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3057	SW_1864	HAWTHORNE AVE	80TH ST	BISCAYNE POINT RD	Biscayne Point A	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_3410	SW_2136	HAWTHORNE AVE	79TH ST	79TH TER	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3606	SW_0418	HAWTHORNE AVE	80TH ST	BISCAYNE POINT RD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3639	SW_2197	HAWTHORNE AVE	CRESPI BLVD	79TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3662	SW_0479	HAWTHORNE AVE	79TH ST	79TH TER	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3690	SW_0573	HAWTHORNE AVE	CRESPI BLVD	79TH ST	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3693	SW_0584	HAWTHORNE AVE	BAYSIDE LN	CRESPI BLVD	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3543	SW_3082	I 195	I 195 RAMPOF	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3552	SW_3082	I 195	I 195 RAMPOF	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3560	SW_3082	I 195	I 195 RAMPOF	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0027	SW_1076	INDIAN CREEK DR	BONITA DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_0290	SW_2365	INDIAN CREEK DR	38TH ST	37TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_0338	SW_1980	INDIAN CREEK DR	37TH ST	36TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1676	SW_1827	INDIAN CREEK DR	29TH ST	28TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1749	SW_1888	INDIAN CREEK DR	32ND ST	31ST ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2177	SW_2716	INDIAN CREEK DR	28TH ST	27TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2186	SW_1980	INDIAN CREEK DR	37TH ST	36TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2293	SW_2728	INDIAN CREEK DR	29TH ST	28TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2899	SW_2330	INDIAN CREEK DR	39TH ST	38TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_2953	SW_2401	INDIAN CREEK DR	43RD ST	COLLINS AVE	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_2971	SW_1982	INDIAN CREEK DR	COLLINS AVE	43RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3009	SW_2401	INDIAN CREEK DR	43RD ST	COLLINS AVE	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3010	SW_2035	INDIAN CREEK DR	65TH ST	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3033	SW_2035	INDIAN CREEK DR	65TH ST	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3043	SW_2035	INDIAN CREEK DR	65TH ST	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3064	SW_2035	INDIAN CREEK DR	65TH ST	67TH ST	North Shore E	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3071	SW_2492	INDIAN CREEK DR	42ND ST	41ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3093	SW_2475	INDIAN CREEK DR	42ND ST	41ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3106	SW_2492	INDIAN CREEK DR	42ND ST	41ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3119	SW_2492	INDIAN CREEK DR	42ND ST	41ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3126	SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3141	SW_2112	INDIAN CREEK DR	63RD ST	65TH ST	North Shore F	Good	Adequate	Adequate	Adequate	Adequate		
R_3198	SW_1873	INDIAN CREEK DR	33RD ST	32ND ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3218	SW_1980	INDIAN CREEK DR	37TH ST	36TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3252	SW_2541	INDIAN CREEK DR	40TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3299	SW_0900	INDIAN CREEK DR	40TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3301	SW_0900	INDIAN CREEK DR	40TH ST	39TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3388	SW_1888	INDIAN CREEK DR	32ND ST	31ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3397	SW_1954	INDIAN CREEK DR	36TH ST	35TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3433	SW_2252	INDIAN CREEK DR	63RD ST	COLLINS AVE	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3441	SW_2252	INDIAN CREEK DR	63RD ST	COLLINS AVE	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3449	SW_2252	INDIAN CREEK DR	63RD ST	COLLINS AVE	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3475	SW_1855	INDIAN CREEK DR	30TH ST	29TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3514	SW_1963	INDIAN CREEK DR	35TH ST	34TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3524	SW_3080	INDIAN CREEK DR	34TH ST	33RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3533	SW_3081	INDIAN CREEK DR	32ND ST	31ST ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3537	SW_0832	INDIAN CREEK DR	41ST ST	40TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3700	SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3738	SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3744	SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3751	SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	Oceanfront B	Good	Adequate	Adequate	Adequate	Adequate		
R_3759	SW_2378	INDIAN CREEK DR	67TH ST	65TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3771	SW_2378	INDIAN CREEK DR	67TH ST	65TH ST	North Shore E	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3779	SW_2378	INDIAN CREEK DR	67TH ST	65TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3797	SW_2398	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3804	SW_2430	INDIAN CREEK DR	67TH ST	ABBOTT AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3812	SW_2398	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3821	SW_2422	INDIAN CREEK DR	INDIAN CREEK DR	67TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3828	SW_2462	INDIAN CREEK DR	BYRON AVE	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3845	SW_0645	INDIAN CREEK DR	43RD ST	COLLINS AVE	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3863	SW_2489	INDIAN CREEK DR	ABBOTT AVE	BYRON AVE	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3864	SW_2473	INDIAN CREEK DR	BYRON AVE	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3870	SW_2473	INDIAN CREEK DR	BYRON AVE	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3881	SW_2473	INDIAN CREEK DR	BYRON AVE	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3889	SW_2462	INDIAN CREEK DR	BYRON AVE	INDIAN CREEK DR	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3891	SW_1799	INDIAN CREEK DR	28TH ST	27TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_3896	SW_2473	INDIAN CREEK DR	BYRON AVE	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3929	SW_2514	INDIAN CREEK DR	BYRON AVE	69TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_3958	SW_2568	INDIAN CREEK DR	69TH ST	CARLYLE AVE	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3981	SW_2614	INDIAN CREEK DR	BONITA DR	71ST ST	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4050	SW_2706	INDIAN CREEK DR	71ST ST	NW END	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4051	SW_2706	INDIAN CREEK DR	71ST ST	NW END	North Shore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4097	SW_1576	INDIAN CREEK DR	27TH ST	26TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4104	SW_1576	INDIAN CREEK DR	27TH ST	26TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4334	SW_2343	INDIAN CREEK DR	65TH ST	63RD ST	Oceanfront B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4419	SW_2378	INDIAN CREEK DR	67TH ST	65TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4540	SW_2462	INDIAN CREEK DR	BYRON AVE	INDIAN CREEK DR	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4581	SW_2473	INDIAN CREEK DR	BYRON AVE	69TH ST	North Shore E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4675	SW_1076	INDIAN CREEK DR	BONITA DR	71ST ST	North Shore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5095	SW_1827	INDIAN CREEK DR	29TH ST	28TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5096	SW_1827	INDIAN CREEK DR	29TH ST	28TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5105	SW_1855	INDIAN CREEK DR	30TH ST	29TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_5118	SW_1888	INDIAN CREEK DR	32ND ST	31ST ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5124	SW_1873	INDIAN CREEK DR	33RD ST	32ND ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5145	SW_1907	INDIAN CREEK DR	34TH ST	33RD ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_5146	SW_1898	INDIAN CREEK DR	35TH ST	34TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5149	SW_1898	INDIAN CREEK DR	35TH ST	34TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5159	SW_1954	INDIAN CREEK DR	36TH ST	35TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5160	SW_1954	INDIAN CREEK DR	36TH ST	35TH ST	Oceanfront A	Good	Adequate	Adequate	Adequate	Adequate		
R_5161	SW_1954	INDIAN CREEK DR	36TH ST	35TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5167	SW_1954	INDIAN CREEK DR	36TH ST	35TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5173	SW_2378	INDIAN CREEK DR	67TH ST	65TH ST	North Shore E	Good	Adequate	Adequate	Adequate	Adequate		
R_5178	SW_1980	INDIAN CREEK DR	37TH ST	36TH ST	Oceanfront A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0756	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0798	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0827	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1223	SW_0224	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1241	SW_0224	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1336	SW_3176	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1353	SW_0224	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1424	SW_3176	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1425	SW_3176	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1435	SW_3176	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1479	SW_3176	ISLAND AVE	VENETIAN WAY	FARREY LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_3707	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3714	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3720	SW_2969	ISLAND AVE	HARBOR LN	VENETIAN WAY	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3721	SW_2969	ISLAND AVE	HARBOR LN	VENETIAN WAY	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3731	SW_2969	ISLAND AVE	HARBOR LN	VENETIAN WAY	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3732	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3734	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3763	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3764	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3765	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3770	SW_0118	ISLAND AVE	HARBOR LN	VENETIAN WAY	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3803	SW_0118	ISLAND AVE	HARBOR LN	VENETIAN WAY	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3827	SW_0127	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3842	SW_0127	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3843	SW_0127	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3848	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3856	SW_2974	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3862	SW_0127	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_3879	SW_0309	ISLAND AVE	VENETIAN WAY	HARBOR LN	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0462	SW_1957	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0509	SW_1957	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	City Center B	Damaged	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0657	SW_1973	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4929	SW_1973	JACKIE GLEASON DR	17TH ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0292	SW_1859	JAMES AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0343	SW_1423	JAMES AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1668	SW_1368	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1683	SW_1368	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1766	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1792	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1793	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1794	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1876	SW_1423	JAMES AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1895	SW_1423	JAMES AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3116	SW_1924	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4547	SW_1956	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4575	SW_1368	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4745	SW_1859	JAMES AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4757	SW_1859	JAMES AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4764	SW_1859	JAMES AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4787	SW_1859	JAMES AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4843	SW_1924	JAMES AVE	17TH ST	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4850	SW_1924	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4888	SW_1956	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4903	SW_1956	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4911	SW_1956	JAMES AVE	LINCOLN RD	17TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_5054	SW_1924	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5062	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5063	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5064	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_5067	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5070	SW_1924	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5072	SW_1410	JAMES AVE	17TH ST	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0233	SW_0614	JEFFERSON AVE	ALTON RD	COMMERCE CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0479	SW_0555	JEFFERSON AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0497	SW_0565	JEFFERSON AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0529	SW_0911	JEFFERSON AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0544	SW_0881	JEFFERSON AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0601	SW_0881	JEFFERSON AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0618	SW_0911	JEFFERSON AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0647	SW_0881	JEFFERSON AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0659	SW_0911	JEFFERSON AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0685	SW_0911	JEFFERSON AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0779	SW_0040	JEFFERSON AVE	41ST ST	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0807	SW_1029	JEFFERSON AVE	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0813	SW_0162	JEFFERSON AVE	41ST ST	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0917	SW_0614	JEFFERSON AVE	ALTON RD	COMMERCE CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0959	SW_0162	JEFFERSON AVE	41ST ST	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0978	SW_2837	JEFFERSON AVE	41ST ST	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0993	SW_0162	JEFFERSON AVE	41ST ST	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1022	SW_0614	JEFFERSON AVE	ALTON RD	COMMERCE CT	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1098	SW_0614	JEFFERSON AVE	ALTON RD	COMMERCE CT	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1341	SW_0749	JEFFERSON AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1667	SW_3054	JEFFERSON AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1746	SW_1034	JEFFERSON AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2655	SW_1504	JEFFERSON AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3259	SW_2999	JEFFERSON AVE	44TH CT	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3287	SW_2999	JEFFERSON AVE	44TH CT	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3295	SW_2973	JEFFERSON AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3306	SW_2973	JEFFERSON AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3750	SW_2973	JEFFERSON AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3757	SW_2973	JEFFERSON AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3778	SW_2971	JEFFERSON AVE	43RD CT	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3928	SW_2999	JEFFERSON AVE	44TH CT	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4140	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4141	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4150	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4151	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4161	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4194	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4208	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4218	SW_0992	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4245	SW_0992	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4282	SW_0992	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4369	SW_1024	JEFFERSON AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4371	SW_0554	JEFFERSON AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4383	SW_0555	JEFFERSON AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4384	SW_0554	JEFFERSON AVE	LINCOLN LN	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4385	SW_0565	JEFFERSON AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4386	SW_0565	JEFFERSON AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4401	SW_0602	JEFFERSON AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4413	SW_0602	JEFFERSON AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4425	SW_0602	JEFFERSON AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4456	SW_1024	JEFFERSON AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4459	SW_0682	JEFFERSON AVE	15TH ST	16TH ST	Flamingo/Lummus D	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4469	SW_0604	JEFFERSON AVE	15TH ST	16TH ST	Flamingo/Lummus D	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4481	SW_0970	JEFFERSON AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4483	SW_1467	JEFFERSON AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4484	SW_0682	JEFFERSON AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4485	SW_0700	JEFFERSON AVE	15TH ST	SOUTH END	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4494	SW_1034	JEFFERSON AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4496	SW_0700	JEFFERSON AVE	15TH ST	SOUTH END	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4562	SW_1467	JEFFERSON AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4577	SW_1458	JEFFERSON AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_4587	SW_1445	JEFFERSON AVE	10TH ST	11TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4630	SW_0881	JEFFERSON AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4631	SW_1467	JEFFERSON AVE	9TH ST	10TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4641	SW_1497	JEFFERSON AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4643	SW_1496	JEFFERSON AVE	6TH ST	7TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4650	SW_1504	JEFFERSON AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4651	SW_1496	JEFFERSON AVE	6TH ST	7TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4652	SW_1497	JEFFERSON AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4659	SW_1504	JEFFERSON AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4747	SW_1457	JEFFERSON AVE	10TH ST	11TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4760	SW_1457	JEFFERSON AVE	10TH ST	11TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5039	SW_0976	JEFFERSON AVE	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5053	SW_0447	JEFFERSON AVE	POINTE CT	ALTON RD	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_5057	SW_0447	JEFFERSON AVE	POINTE CT	ALTON RD	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_5059	SW_0447	JEFFERSON AVE	POINTE CT	ALTON RD	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0812	SW_2637	LA GORCE DR	PINE TREE DR	51ST ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_2084	SW_2697	LA GORCE DR	63RD ST	62ND ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_2350	SW_2722	LA GORCE DR	63RD ST	ALTON RD	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2426	SW_2722	LA GORCE DR	63RD ST	ALTON RD	La Gorce A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3316	SW_2529	LA GORCE DR	63RD ST	62ND ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3420	SW_2529	LA GORCE DR	63RD ST	62ND ST	La Gorce B	Good	Adequate	Adequate	Adequate	Adequate		
R_3429	SW_2547	LA GORCE DR	62ND ST	61ST ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3472	SW_2558	LA GORCE DR	62ND ST	61ST ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3480	SW_2586	LA GORCE DR	61ST ST	60TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3492	SW_2636	LA GORCE DR	60TH ST	59TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3499	SW_2586	LA GORCE DR	61ST ST	60TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3520	SW_2636	LA GORCE DR	60TH ST	59TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3531	SW_2630	LA GORCE DR	59TH ST	58TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3541	SW_2630	LA GORCE DR	59TH ST	58TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3564	SW_2675	LA GORCE DR	58TH ST	57TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3649	SW_0465	LA GORCE DR	56TH ST	55TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3650	SW_2460	LA GORCE DR	55TH ST	54TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3664	SW_0471	LA GORCE DR	56TH ST	55TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3683	SW_2460	LA GORCE DR	55TH ST	54TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3686	SW_2522	LA GORCE DR	54TH ST	53RD ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3712	SW_2522	LA GORCE DR	54TH ST	53RD ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3718	SW_2548	LA GORCE DR	53RD ST	52ND ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_3733	SW_2574	LA GORCE DR	53RD ST	52ND ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_2365	SW_2233	LAKE PANCOAST DR	LAKE PANCOAST DR	FLAMINGO DR	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2366	SW_1378	LAKE PANCOAST DR	COLLINS AVE	LAKE PANCOAST DR	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2387	SW_1378	LAKE PANCOAST DR	COLLINS AVE	LAKE PANCOAST DR	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2388	SW_1385	LAKE PANCOAST DR	FLAMINGO DR	LAKE PANCOAST DR	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0249	SW_0139	LAKEVIEW DR	CHEROKEE AVE	DELAWARE AVE	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_4025	SW_0217	LAKEVIEW DR	LAKEVIEW CT	CHEROKEE AVE	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_4029	SW_0503	LAKEVIEW DR	LAKEVIEW CT	LAKEVIEW CT	Lakeview A	Good	Adequate	Adequate	Adequate	Adequate		
R_4030	SW_0503	LAKEVIEW DR	LAKEVIEW CT	LAKEVIEW CT	Lakeview A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0072	SW_0031	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0094	SW_0031	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0111	SW_0019	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0220	SW_0074	LENOX AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0232	SW_0401	LENOX AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0430	SW_0011	LENOX AVE	15TH ST	16TH ST	Flamingo/Lummus E	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0458	SW_0019	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0506	SW_0031	LENOX AVE	14TH ST	15TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0612	SW_0042	LENOX AVE	13TH ST	14TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0655	SW_0049	LENOX AVE	13TH ST	14TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0694	SW_0042	LENOX AVE	13TH ST	14TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0723	SW_0055	LENOX AVE	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0755	SW_0049	LENOX AVE	13TH ST	14TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0818	SW_0060	LENOX AVE	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0847	SW_0055	LENOX AVE	12TH ST	13TH ST	Flamingo/Lummus E	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0868	SW_0060	LENOX AVE	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1160	SW_0401	LENOX AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1179	SW_0074	LENOX AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1180	SW_0390	LENOX AVE	5TH ST	6TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1208	SW_0401	LENOX AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1243	SW_0074	LENOX AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1520	SW_0385	LENOX AVE	6TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1639	SW_0382	LENOX AVE	6TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2113	SW_0553	LENOX AVE	16TH ST	LINCOLN LN	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2258	SW_0371	LENOX AVE	8TH ST	9TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2485	SW_0499	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2552	SW_0340	LENOX AVE	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2637	SW_0543	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2638	SW_0494	LENOX AVE	17TH ST	18TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_3168	SW_0478	LENOX AVE	17TH ST	18TH ST	City Center A	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3534	SW_0361	LENOX AVE	9TH ST	10TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4257	SW_0494	LENOX AVE	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4259	SW_0543	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4269	SW_3120	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4270	SW_0543	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4285	SW_3120	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4298	SW_0543	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4310	SW_0543	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4311	SW_0544	LENOX AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4312	SW_0551	LENOX AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4327	SW_0543	LENOX AVE	LINCOLN CT	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4331	SW_0551	LENOX AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4343	SW_0544	LENOX AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4344	SW_0551	LENOX AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4360	SW_0553	LENOX AVE	16TH ST	LINCOLN LN	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4451	SW_0348	LENOX AVE	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4531	SW_0390	LENOX AVE	5TH ST	6TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4599	SW_0401	LENOX AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0014	SW_1516	LIBERTY AVE	23RD ST	NORTH END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2041	SW_1509	LIBERTY AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2063	SW_1509	LIBERTY AVE	19TH ST	20TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2080	SW_1509	LIBERTY AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2270	SW_1556	LIBERTY AVE	20TH ST	21ST ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2563	SW_1500	LIBERTY AVE	23RD ST	NORTH END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2588	SW_1653	LIBERTY AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2642	SW_3126	LIBERTY AVE	23RD ST	NORTH END	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2738	SW_1516	LIBERTY AVE	23RD ST	NORTH END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2944	SW_1500	LIBERTY AVE	23RD ST	NORTH END	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2975	SW_1500	LIBERTY AVE	23RD ST	NORTH END	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2988	SW_1500	LIBERTY AVE	23RD ST	NORTH END	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4062	SW_1516	LIBERTY AVE	23RD ST	NORTH END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4168	SW_1516	LIBERTY AVE	23RD ST	NORTH END	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4204	SW_1516	LIBERTY AVE	23RD ST	NORTH END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4213	SW_1516	LIBERTY AVE	23RD ST	NORTH END	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4377	SW_1603	LIBERTY AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4706	SW_1793	LIBERTY AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4717	SW_1793	LIBERTY AVE	19TH ST	20TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4733	SW_1793	LIBERTY AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0834	SW_3098	LINCOLN CT	LICOLN RD	NORTH END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0935	SW_3097	LINCOLN CT	LICOLN RD	NORTH END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0969	SW_3097	LINCOLN CT	LICOLN RD	NORTH END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1069	SW_0474	LINCOLN CT	LICOLN RD	NORTH END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3432	SW_3098	LINCOLN CT	LICOLN RD	NORTH END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1326	SW_1234	LINCOLN LN	MERIDIAN CT	MERIDIAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1344	SW_1243	LINCOLN LN	PENNSYLVANIA AVE	MERIDIAN CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1361	SW_1243	LINCOLN LN	PENNSYLVANIA AVE	MERIDIAN CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1377	SW_1253	LINCOLN LN	PENNSYLVANIA AVE	MERIDIAN CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1440	SW_1299	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1454	SW_1319	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1472	SW_1319	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1509	SW_1319	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1525	SW_1319	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1541	SW_1299	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1570	SW_1328	LINCOLN LN	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5006	SW_1319	LINCOLN LN	DREXEL AVE	PENNSYLVANIA AVE	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0376	SW_2006	LINCOLN RD	JAMES AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0527	SW_0226	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0539	SW_0226	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0671	SW_0226	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0705	SW_0226	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0850	SW_0243	LINCOLN RD	BAY RD	LINCOLN CT	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0882	SW_2067	LINCOLN RD	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0914	SW_2110	LINCOLN RD	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0968	SW_0317	LINCOLN RD	ALTON CT	WEST AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0981	SW_2110	LINCOLN RD	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0999	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1003	SW_2110	LINCOLN RD	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1016	SW_2110	LINCOLN RD	BEACH WALK	COLLINS AVE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1017	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1039	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1070	SW_3099	LINCOLN RD	LINCOLN CT	WEST END	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1071	SW_0481	LINCOLN RD	LINCOLN CT	WEST END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1111	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1142	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1143	SW_3101	LINCOLN RD	BAY RD	LINCOLN CT	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1159	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1195	SW_3101	LINCOLN RD	BAY RD	LINCOLN CT	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1232	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1233	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1250	SW_0549	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1251	SW_0549	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1261	SW_0549	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1262	SW_0549	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1263	SW_0549	LINCOLN RD	WEST AVE	BAY RD	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1301	SW_0484	LINCOLN RD	BAY RD	LINCOLN CT	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1596	SW_1347	LINCOLN RD	JAMES AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1655	SW_1347	LINCOLN RD	JAMES AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1843	SW_1310	LINCOLN RD	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1844	SW_1310	LINCOLN RD	WASHINGTON AVE	DREXEL AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2472	SW_0307	LINCOLN RD	ALTON RD	LENOX AVE	City Center A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3455	SW_0476	LINCOLN RD	WEST AVE	ALTON CT	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4191	SW_1999	LINCOLN RD	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4212	SW_1974	LINCOLN RD	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4381	SW_3101	LINCOLN RD	BAY RD	LINCOLN CT	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4910	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4925	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4926	SW_1974	LINCOLN RD	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4930	SW_2121	LINCOLN RD	COLLINS AVE	BEACH WALK	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4931	SW_1999	LINCOLN RD	COLLINS AVE	JAMES AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4932	SW_2006	LINCOLN RD	JAMES AVE	WASHINGTON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4966	SW_3075	LINCOLN RD	ALTON CT	ALTON RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_5020	SW_2110	LINCOLN RD	BEACH WALK	COLLINS AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1322	SW_3102	LINCOLN TER	BAY RD	WEST END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_1356	SW_0691	LINCOLN TER	BAY RD	WEST END	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2560	SW_3043	MAC ARTHUR CSWY	ALTON RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2678	SW_3044	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2686	SW_3044	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2698	SW_3026	MAC ARTHUR CSWY	BRIDGE RD	FOUNTAIN ST	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2826	SW_3087	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2834	SW_3087	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	BRIDGE RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2848	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2894	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2906	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2931	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2932	SW_3060	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	MAC ARTHUR RAMPOF	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2946	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2963	SW_3048	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	MAC ARTHUR RAMPOF	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_2978	SW_3059	MAC ARTHUR CSWY	BRIDGE RD	FISHER ISLAND FERRY RD	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2980	SW_3048	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	MAC ARTHUR RAMPOF	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_3007	SW_3048	MAC ARTHUR CSWY	FISHER ISLAND FERRY RD	MAC ARTHUR RAMPOF	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_4801	SW_1312	MAC ARTHUR CSWY	MAC ARTHUR RAMPOF	ALTON RD	Flamingo/Lummus C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4811	SW_1312	MAC ARTHUR CSWY	MAC ARTHUR RAMPOF	ALTON RD	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4972	SW_0662	MAC ARTHUR CSWY	FOUNTAIN ST	NW END	Star and Terminal Island A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4992	SW_2705	MAC ARTHUR CSWY	NW END	FOUNTAIN ST	Star and Terminal Island A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4995	SW_2705	MAC ARTHUR CSWY	NW END	FOUNTAIN ST	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_4996	SW_2705	MAC ARTHUR CSWY	NW END	FOUNTAIN ST	Star and Terminal Island A	Good	Adequate	Adequate	Adequate	Adequate		
R_3724	SW_2319	MAIMONIDES ST	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3729	SW_2364	MAIMONIDES ST	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3755	SW_2364	MAIMONIDES ST	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3761	SW_2364	MAIMONIDES ST	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0337	SW_0568	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1572	SW_2074	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1574	SW_2074	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1598	SW_2074	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1628	SW_2074	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1657	SW_2074	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1784	SW_2187	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1823	SW_2187	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1852	SW_2045	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1881	SW_2187	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1899	SW_2045	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1987	SW_2045	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2240	SW_2134	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2311	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2409	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2535	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2569	SW_1787	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2592	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2607	SW_1787	MARSEILLE DR	BAY DR	RUE VERSAILLES	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2646	SW_2183	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2702	SW_1840	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2703	SW_1840	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2774	SW_1840	MARSEILLE DR	RUE VERSAILLES	RUE NOTRE DAME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2898	SW_1116	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2954	SW_1116	MARSEILLE DR	RUE GRANVILLE	VERDUN DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2966	SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2984	SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3165	SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3243	SW_2363	MARSEILLE DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3937	SW_0731	MARSEILLE DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0234	SW_0796	MERIDIAN AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0365	SW_0762	MERIDIAN AVE	LINCOLN LN	MERIDIAN AVE	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0377	SW_0755	MERIDIAN AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0408	SW_0790	MERIDIAN AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0420	SW_0800	MERIDIAN AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0431	SW_1054	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0432	SW_1054	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0459	SW_1054	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0712	SW_1066	MERIDIAN AVE	17TH ST	18TH ST	City Center A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0745	SW_0986	MERIDIAN AVE	19TH ST	DADE BLVD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0772	SW_0986	MERIDIAN AVE	19TH ST	DADE BLVD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0782	SW_2795	MERIDIAN AVE	41ST ST	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0806	SW_1019	MERIDIAN AVE	19TH ST	DADE BLVD	Bayshore B	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0819	SW_1019	MERIDIAN AVE	19TH ST	DADE BLVD	Bayshore B	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0820	SW_1019	MERIDIAN AVE	19TH ST	DADE BLVD	Bayshore B	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0830	SW_2032	MERIDIAN AVE	MERIDIAN AVE	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0839	SW_1053	MERIDIAN AVE	19TH ST	DADE BLVD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0862	SW_2795	MERIDIAN AVE	41ST ST	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0870	SW_1054	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0875	SW_2787	MERIDIAN AVE	41ST ST	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0898	SW_2024	MERIDIAN AVE	LINCOLN LN	17TH ST	City Center A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0902	SW_1054	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0909	SW_2865	MERIDIAN AVE	47TH ST	47TH CT	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0920	SW_1054	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0931	SW_0796	MERIDIAN AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0950	SW_1066	MERIDIAN AVE	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0951	SW_1066	MERIDIAN AVE	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0960	SW_0796	MERIDIAN AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0965	SW_2032	MERIDIAN AVE	MERIDIAN AVE	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0966	SW_2043	MERIDIAN AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0967	SW_2051	MERIDIAN AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0996	SW_2043	MERIDIAN AVE	LINCOLN LN	LINCOLN RD	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1024	SW_1091	MERIDIAN AVE	17TH ST	18TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1235	SW_1192	MERIDIAN AVE	18TH ST	18TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1246	SW_0834	MERIDIAN AVE	6TH ST	7TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1253	SW_1204	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1274	SW_1204	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1275	SW_1204	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1291	SW_1204	MERIDIAN AVE	18TH ST	19TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1355	SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1522	SW_0889	MERIDIAN AVE	7TH ST	8TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1580	SW_0370	MERIDIAN AVE	43RD CT	44TH CT	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1732	SW_0330	MERIDIAN AVE	46TH ST	47TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1774	SW_0952	MERIDIAN AVE	8TH ST	9TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1870	SW_0764	MERIDIAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1872	SW_0952	MERIDIAN AVE	8TH ST	9TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2002	SW_0962	MERIDIAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2030	SW_1004	MERIDIAN AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2050	SW_0980	MERIDIAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2051	SW_1004	MERIDIAN AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2071	SW_0414	MERIDIAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2074	SW_1004	MERIDIAN AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2075	SW_1004	MERIDIAN AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2317	SW_1060	MERIDIAN AVE	10TH ST	11TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2429	SW_0444	MERIDIAN AVE	1ST ST	2ND ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2444	SW_0444	MERIDIAN AVE	1ST ST	2ND ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2528	SW_0901	MERIDIAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2596	SW_0901	MERIDIAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_2622	SW_1210	MERIDIAN AVE	5TH ST	6TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2650	SW_2865	MERIDIAN AVE	47TH ST	47TH CT	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2669	SW_2865	MERIDIAN AVE	47TH ST	47TH CT	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2677	SW_2865	MERIDIAN AVE	47TH ST	47TH CT	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2685	SW_2865	MERIDIAN AVE	47TH ST	47TH CT	Nautilus F	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2731	SW_0755	MERIDIAN AVE	16TH ST	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3008	SW_0926	MERIDIAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3117	SW_1210	MERIDIAN AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3590	SW_0926	MERIDIAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_3623	SW_2723	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3624	SW_2723	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3625	SW_2723	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3641	SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_3656	SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3657	SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3671	SW_2392	MERIDIAN AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3756	SW_0405	MERIDIAN AVE	40TH ST	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3836	SW_2461	MERIDIAN AVE	40TH ST	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3841	SW_2461	MERIDIAN AVE	40TH ST	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_3847	SW_2461	MERIDIAN AVE	40TH ST	41ST ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4007	SW_0926	MERIDIAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4026	SW_3022	MERIDIAN AVE	41ST ST	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4031	SW_3022	MERIDIAN AVE	41ST ST	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4034	SW_0298	MERIDIAN AVE	BARRY ST	39TH ST	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4037	SW_3038	MERIDIAN AVE	41ST ST	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4048	SW_2762	MERIDIAN AVE	BARRY ST	GARDEN AVE	Bayshore D	Good	Adequate	Adequate	Adequate	Adequate		
R_4152	SW_1210	MERIDIAN AVE	5TH ST	6TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4163	SW_0962	MERIDIAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4183	SW_0980	MERIDIAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4199	SW_0405	MERIDIAN AVE	40TH ST	41ST ST	Bayshore D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4233	SW_0980	MERIDIAN AVE	3RD ST	4TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4246	SW_1287	MERIDIAN AVE	6TH ST	7TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4247	SW_1287	MERIDIAN AVE	6TH ST	7TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4284	SW_1287	MERIDIAN AVE	6TH ST	7TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4358	SW_1309	MERIDIAN AVE	7TH ST	8TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4442	SW_1353	MERIDIAN AVE	8TH ST	9TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4508	SW_0724	MERIDIAN AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4521	SW_0852	MERIDIAN AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4535	SW_0754	MERIDIAN AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4536	SW_0735	MERIDIAN AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4548	SW_1408	MERIDIAN AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4561	SW_0724	MERIDIAN AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4590	SW_0742	MERIDIAN AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4603	SW_0759	MERIDIAN AVE	14TH ST	14TH PL	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4619	SW_1419	MERIDIAN AVE	10TH ST	11TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4632	SW_0766	MERIDIAN AVE	14TH ST	14TH PL	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4653	SW_0777	MERIDIAN AVE	13TH ST	14TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4661	SW_0787	MERIDIAN AVE	13TH ST	14TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4692	SW_0797	MERIDIAN AVE	12TH ST	13TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4712	SW_0806	MERIDIAN AVE	12TH ST	13TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4720	SW_0797	MERIDIAN AVE	12TH ST	13TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4728	SW_0825	MERIDIAN AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4749	SW_0816	MERIDIAN AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4761	SW_0825	MERIDIAN AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4837	SW_0414	MERIDIAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4853	SW_0764	MERIDIAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_5004	SW_0420	MERIDIAN AVE	1ST ST	2ND ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5027	SW_0444	MERIDIAN AVE	1ST ST	2ND ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_5040	SW_1066	MERIDIAN AVE	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5055	SW_0444	MERIDIAN AVE	1ST ST	2ND ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0758	SW_1987	MERIDIAN CT	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0759	SW_1998	MERIDIAN CT	LINCOLN LN	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0799	SW_1998	MERIDIAN CT	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0800	SW_1998	MERIDIAN CT	LINCOLN LN	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0828	SW_1998	MERIDIAN CT	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_2304	SW_1659	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2391	SW_1659	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4302	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4335	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4347	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4364	SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4391	SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4404	SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4420	SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4432	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4463	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4475	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4500	SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4513	SW_1652	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4608	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_4626	SW_1643	MIAMI BEACH DR	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0020	SW_0004	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0043	SW_0004	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0058	SW_0010	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0071	SW_0010	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0085	SW_0010	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0106	SW_0004	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0326	SW_0010	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_0347	SW_3115	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0348	SW_3115	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0362	SW_0769	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0363	SW_0769	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0364	SW_0769	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_0514	SW_0871	MICHIGAN AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0530	SW_0864	MICHIGAN AVE	16TH ST	LINCOLN LN	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0564	SW_0871	MICHIGAN AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0666	SW_0035	MICHIGAN AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0707	SW_0035	MICHIGAN AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0740	SW_0035	MICHIGAN AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0795	SW_0035	MICHIGAN AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0986	SW_0075	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1019	SW_3128	MICHIGAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1124	SW_3128	MICHIGAN AVE	4TH ST	5TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1320	SW_0133	MICHIGAN AVE	13TH ST	14TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1372	SW_0069	MICHIGAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1438	SW_0108	MICHIGAN AVE	5TH ST	6TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1439	SW_0108	MICHIGAN AVE	5TH ST	6TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1521	SW_0722	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1586	SW_0722	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1608	SW_0722	MICHIGAN AVE	2ND ST	3RD ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1620	SW_0190	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1638	SW_0190	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1663	SW_0190	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1694	SW_0190	MICHIGAN AVE	14TH ST	MICHIGAN CT	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_1721	SW_0152	MICHIGAN AVE	6TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1840	SW_0776	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1873	SW_0249	MICHIGAN AVE	15TH ST	16TH ST	Flamingo/Lummus E	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_1893	SW_0776	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_1913	SW_2873	MICHIGAN AVE	47TH ST	47TH CT	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_1965	SW_0249	MICHIGAN AVE	15TH ST	16TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2184	SW_0289	MICHIGAN AVE	16TH ST	LINCOLN LN	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2210	SW_0301	MICHIGAN AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2262	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2318	SW_0301	MICHIGAN AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2379	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2400	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2432	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2447	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2463	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2550	SW_0332	MICHIGAN AVE	17TH ST	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2652	SW_0278	MICHIGAN AVE	9TH ST	10TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2807	SW_3034	MICHIGAN AVE	43RD ST	43RD CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2929	SW_2901	MICHIGAN AVE	46TH ST	47TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_2947	SW_0278	MICHIGAN AVE	9TH ST	10TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2991	SW_2898	MICHIGAN AVE	46TH ST	47TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3082	SW_1216	MICHIGAN AVE	5TH ST	6TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3132	SW_1216	MICHIGAN AVE	5TH ST	6TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_3139	SW_0770	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	-	-	-	-	Under Construction		
R_3151	SW_0770	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	-	-	-	-	Under Construction		
R_3162	SW_2901	MICHIGAN AVE	46TH ST	47TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3183	SW_0770	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	-	-	-	-	Under Construction		
R_3192	SW_0770	MICHIGAN AVE	12TH ST	13TH ST	Flamingo/Lummus E	-	-	-	-	Under Construction		
R_3317	SW_2917	MICHIGAN AVE	42ND ST	43RD ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3348	SW_2917	MICHIGAN AVE	42ND ST	43RD ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3361	SW_2917	MICHIGAN AVE	42ND ST	43RD ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3373	SW_0776	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3392	SW_2917	MICHIGAN AVE	42ND ST	43RD ST	Nautilus G	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_4022	SW_0393	MICHIGAN AVE	17TH ST	18TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_4081	SW_2816	MICHIGAN AVE	ALTON RD	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4087	SW_2816	MICHIGAN AVE	ALTON RD	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4094	SW_0218	MICHIGAN AVE	19TH ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4095	SW_0685	MICHIGAN AVE	19TH ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4101	SW_0393	MICHIGAN AVE	17TH ST	18TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4136	SW_2780	MICHIGAN AVE	19TH ST	ALTON RD	Lower North Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4137	SW_2780	MICHIGAN AVE	19TH ST	ALTON RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4142	SW_1216	MICHIGAN AVE	5TH ST	6TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4172	SW_0315	MICHIGAN AVE	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4223	SW_1249	MICHIGAN AVE	6TH ST	7TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4297	SW_1294	MICHIGAN AVE	7TH ST	8TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4441	SW_3069	MICHIGAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4491	SW_0776	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4501	SW_0776	MICHIGAN AVE	3RD ST	4TH ST	South Pointe D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4504	SW_3069	MICHIGAN AVE	4TH ST	5TH ST	South Pointe D	Good	Adequate	Adequate	Adequate	Adequate		
R_4506	SW_1382	MICHIGAN AVE	9TH ST	10TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4534	SW_1409	MICHIGAN AVE	10TH ST	11TH ST	Flamingo/Lummus C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4563	SW_1409	MICHIGAN AVE	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_3172	SW_2905	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3182	SW_2905	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3191	SW_0314	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3202	SW_2906	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3231	SW_2909	MOUNT SINAI HOSPITAL PR	43RD ST	ED SULLIVAN DR	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3258	SW_2912	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3270	SW_2912	MOUNT SINAI HOSPITAL PR	I 195-ALTON RAMPON	43RD ST	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3553	SW_3085	MOUNT SINAI HOSPITAL PR	MOUNT SINAI HOSPITAL PR	ED SULLIVAN DR	Nautilus E	Good	Adequate	Adequate	Adequate	Adequate		
R_3581	SW_3086	MOUNT SINAI HOSPITAL PR	MOUNT SINAI HOSPITAL PR	ED SULLIVAN DR	Nautilus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3975	SW_3023	NAUTILUS CT	NAUTILUS DR	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3989	SW_3025	NAUTILUS CT	NAUTILUS DR	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3993	SW_3025	NAUTILUS CT	NAUTILUS DR	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0555	SW_2790	NAUTILUS DR	ALTON RD	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1080	SW_2797	NAUTILUS DR	ALTON RD	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1092	SW_2797	NAUTILUS DR	ALTON RD	42ND ST	Nautilus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1109	SW_2797	NAUTILUS DR	ALTON RD	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1119	SW_2797	NAUTILUS DR	ALTON RD	42ND ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1151	SW_2836	NAUTILUS DR	42ND ST	43RD ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2822	SW_2881	NAUTILUS DR	43RD ST	44TH CT	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3029	SW_2887	NAUTILUS DR	42ND ST	43RD ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3393	SW_2887	NAUTILUS DR	42ND ST	43RD ST	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3941	SW_3008	NAUTILUS DR	44TH CT	NAUTILUS CT	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3961	SW_3017	NAUTILUS DR	NAUTILUS CT	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_3971	SW_3020	NAUTILUS DR	NAUTILUS CT	46TH ST	Nautilus F	Good	Adequate	Adequate	Adequate	Adequate		
R_0051	SW_2039	NOREMAC AVE	BISCAYNE POINT RD	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3704	SW_2329	NOREMAC AVE	BISCAYNE POINT RD	DAYTONIA RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3747	SW_2356	NOREMAC AVE	DAYTONIA RD	CLEVELAND RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_3883	SW_2494	NOREMAC AVE	CLEVELAND RD	BISCAYNE POINT RD	Biscayne Point C	Good	Adequate	Adequate	Adequate	Adequate		
R_0017	SW_0495	NORMANDY DR	79TH CSWY	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0018	SW_0854	NORMANDY DR	VERDUN DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0034	SW_0495	NORMANDY DR	79TH CSWY	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0035	SW_0884	NORMANDY DR	GRANVILLE CT	VERDUN DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0048	SW_1165	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0063	SW_0884	NORMANDY DR	GRANVILLE CT	VERDUN DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0102	SW_0923	NORMANDY DR	RUE GRANVILLE	GRANVILLE CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0103	SW_1165	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0119	SW_1246	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0174	SW_0560	NORMANDY DR	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0185	SW_0560	NORMANDY DR	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0187	SW_1246	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0201	SW_1331	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0272	SW_0585	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0318	SW_1331	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0319	SW_0585	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0352	SW_1331	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0382	SW_1396	NORMANDY DR	VERSAILLES CT	VICHY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0437	SW_1396	NORMANDY DR	VERSAILLES CT	VICHY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0484	SW_1522	NORMANDY DR	RUE VENDOME	VERSAILLES CT	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0567	SW_1522	NORMANDY DR	RUE VENDOME	VERSAILLES CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0621	SW_1223	NORMANDY DR	BIARRITZ DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0674	SW_1572	NORMANDY DR	RUE VENDOME	VERSAILLES CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0700	SW_1572	NORMANDY DR	RUE VENDOME	VERSAILLES CT	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0747	SW_1572	NORMANDY DR	RUE VENDOME	VERSAILLES CT	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0809	SW_1624	NORMANDY DR	71ST ST	RUE VENDOME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0823	SW_1624	NORMANDY DR	71ST ST	RUE VENDOME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1442	SW_1624	NORMANDY DR	71ST ST	RUE VENDOME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1737	SW_1624	NORMANDY DR	71ST ST	RUE VENDOME	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1957	SW_2309	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2926	SW_2047	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2933	SW_1951	NORMANDY DR	RUE NOTRE DAME	RUE BORDEAUX	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2994	SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3128	SW_0585	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3303	SW_2047	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3313	SW_2047	NORMANDY DR	VICHY DR	RUE NOTRE DAME	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3385	SW_2552	NORMANDY DR	RUE BORDEAUX	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3459	SW_2063	NORMANDY DR	VERSAILLES CT	VICHY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3478	SW_2063	NORMANDY DR	VERSAILLES CT	VICHY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3710	SW_0591	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3715	SW_0591	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3723	SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3736	SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3745	SW_0630	NORMANDY DR	TROUVILLE ESPLANADE	RUE GRANVILLE	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5077	SW_0854	NORMANDY DR	VERDUN DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_5196	SW_0854	NORMANDY DR	VERDUN DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0251	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0258	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0328	SW_0017	OCEAN DR	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0330	SW_0017	OCEAN DR	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0541	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0769	SW_0839	OCEAN DR	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0836	SW_0839	OCEAN DR	12TH ST	13TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0884	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0930	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_0983	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1020	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1021	SW_0081	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1174	SW_0116	OCEAN DR	5TH ST	6TH ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1177	SW_0116	OCEAN DR	5TH ST	6TH ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1228	SW_0909	OCEAN DR	11TH ST	12TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1269	SW_0116	OCEAN DR	5TH ST	6TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_1399	SW_1760	OCEAN DR	6TH ST	7TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1537	SW_0984	OCEAN DR	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1551	SW_0160	OCEAN DR	5TH ST	6TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1569	SW_0984	OCEAN DR	10TH ST	11TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1601	SW_1018	OCEAN DR	9TH ST	10TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1623	SW_1028	OCEAN DR	8TH ST	9TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1637	SW_0160	OCEAN DR	5TH ST	6TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1652	SW_1065	OCEAN DR	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1831	SW_0179	OCEAN DR	4TH ST	5TH ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1890	SW_0179	OCEAN DR	4TH ST	5TH ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1993	SW_0179	OCEAN DR	4TH ST	5TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2132	SW_0220	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2617	SW_1065	OCEAN DR	6TH ST	7TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2749	SW_1760	OCEAN DR	6TH ST	7TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2750	SW_1767	OCEAN DR	7TH ST	8TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2757	SW_1767	OCEAN DR	7TH ST	8TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2766	SW_1776	OCEAN DR	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2773	SW_1776	OCEAN DR	8TH ST	9TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2781	SW_1786	OCEAN DR	9TH ST	10TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2793	SW_1786	OCEAN DR	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2802	SW_1786	OCEAN DR	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2810	SW_1786	OCEAN DR	9TH ST	10TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2817	SW_1794	OCEAN DR	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2828	SW_1794	OCEAN DR	10TH ST	11TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2836	SW_1794	OCEAN DR	10TH ST	11TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2849	SW_1805	OCEAN DR	11TH ST	12TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2859	SW_1805	OCEAN DR	11TH ST	12TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_2860	SW_1813	OCEAN DR	12TH ST	13TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2875	SW_1813	OCEAN DR	12TH ST	13TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2886	SW_1823	OCEAN DR	13TH ST	14TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2895	SW_1860	OCEAN DR	14TH ST	14th PLACE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2907	SW_1860	OCEAN DR	14TH ST	14th PLACE	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2919	SW_1860	OCEAN DR	14TH ST	14th PLACE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_3363	SW_1191	OCEAN DR	14TH ST	14th PLACE	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4219	SW_0310	OCEAN DR	1ST ST	POINTE DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4301	SW_1219	OCEAN DR	14th PLACE	15TH ST	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4433	SW_0304	OCEAN DR	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4434	SW_0304	OCEAN DR	1ST ST	2ND ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4435	SW_0304	OCEAN DR	1ST ST	2ND ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4436	SW_0304	OCEAN DR	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4437	SW_0328	OCEAN DR	1ST ST	2ND ST	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4450	SW_0304	OCEAN DR	1ST ST	2ND ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4454	SW_0328	OCEAN DR	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4476	SW_0304	OCEAN DR	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4478	SW_1028	OCEAN DR	8TH ST	9TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4514	SW_0328	OCEAN DR	1ST ST	2ND ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4554	SW_0337	OCEAN DR	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4583	SW_0337	OCEAN DR	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4596	SW_0337	OCEAN DR	2ND ST	3RD ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4629	SW_1028	OCEAN DR	8TH ST	9TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4637	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4638	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4668	SW_1018	OCEAN DR	9TH ST	10TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4698	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4699	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4707	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4725	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4746	SW_0362	OCEAN DR	3RD ST	4TH ST	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_5092	SW_0739	OCEAN DR	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5112	SW_0739	OCEAN DR	13TH ST	14TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0480	SW_1634	OCEAN TER	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0568	SW_1634	OCEAN TER	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0662	SW_1634	OCEAN TER	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0790	SW_1565	OCEAN TER	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0842	SW_1565	OCEAN TER	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1184	SW_1565	OCEAN TER	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1185	SW_1565	OCEAN TER	73RD ST	74TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1278	SW_1634	OCEAN TER	74TH ST	75TH ST	North Shore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5202	SW_3194	PALM AVE	FOUNTAIN ST	FOUNTAIN ST	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5203	SW_3194	PALM AVE	FOUNTAIN ST	FOUNTAIN ST	Palm and Hibiscus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1214	SW_1676	PARK AVE	21ST ST	22ND ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1983	SW_1620	PARK AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2117	SW_1598	PARK AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2383	SW_1598	PARK AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2404	SW_1613	PARK AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2422	SW_1613	PARK AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2456	SW_1620	PARK AVE	19TH ST	20TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2474	SW_1620	PARK AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2493	SW_1708	PARK AVE	22ND ST	23RD ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2533	SW_1644	PARK AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2679	SW_1708	PARK AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2688	SW_1708	PARK AVE	22ND ST	23RD ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2708	SW_1726	PARK AVE	22ND ST	23RD ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2717	SW_1726	PARK AVE	22ND ST	23RD ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2718	SW_1726	PARK AVE	22ND ST	23RD ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2719	SW_1726	PARK AVE	22ND ST	23RD ST	City Center B	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_4489	SW_1676	PARK AVE	21ST ST	22ND ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4490	SW_1676	PARK AVE	21ST ST	22ND ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4541	SW_1676	PARK AVE	21ST ST	22ND ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_0026	SW_1948	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0096	SW_1964	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0113	SW_1964	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0295	SW_1262	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0345	SW_1948	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0390	SW_1948	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0442	SW_1964	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0461	SW_1964	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0560	SW_1964	PENNSYLVANIA AVE	LINCOLN LN	17TH ST	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_0696	SW_1217	PENNSYLVANIA AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0897	SW_1217	PENNSYLVANIA AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_1248	SW_1268	PENNSYLVANIA AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Good	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_1386	SW_1277	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1389	SW_1289	PENNSYLVANIA AVE	LINCOLN RD	LINCOLN LN	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1402	SW_1280	PENNSYLVANIA AVE	LINCOLN RD	LINCOLN LN	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1450	SW_1277	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1465	SW_0867	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_1489	SW_1289	PENNSYLVANIA AVE	LINCOLN RD	LINCOLN LN	City Center A	Good	Adequate	Adequate	Adequate	Adequate		
R_1964	SW_0993	PENNSYLVANIA AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_2033	SW_1333	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2077	SW_1333	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2148	SW_1344	PENNSYLVANIA AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2353	SW_1399	PENNSYLVANIA AVE	15TH ST	16TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_2448	SW_1399	PENNSYLVANIA AVE	15TH ST	16TH ST	Flamingo/Lummus D	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2504	SW_1399	PENNSYLVANIA AVE	15TH ST	16TH ST	Flamingo/Lummus D	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_3350	SW_1433	PENNSYLVANIA AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_4271	SW_1475	PENNSYLVANIA AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4299	SW_1475	PENNSYLVANIA AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4313	SW_1498	PENNSYLVANIA AVE	14TH ST	14TH PL	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4415	SW_1533	PENNSYLVANIA AVE	13TH ST	14TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4482	SW_1344	PENNSYLVANIA AVE	16TH ST	LINCOLN LN	Flamingo/Lummus D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4673	SW_1642	PENNSYLVANIA AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4679	SW_1774	PENNSYLVANIA AVE	8TH ST	9TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4681	SW_1642	PENNSYLVANIA AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4690	SW_0993	PENNSYLVANIA AVE	9TH ST	10TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4762	SW_1674	PENNSYLVANIA AVE	10TH ST	11TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4816	SW_0868	PENNSYLVANIA AVE	11TH ST	12TH ST	Flamingo/Lummus F	Good	Adequate	Adequate	Adequate	Adequate		
R_4817	SW_1716	PENNSYLVANIA AVE	9TH ST	10TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4824	SW_1737	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4831	SW_1716	PENNSYLVANIA AVE	9TH ST	10TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4832	SW_1774	PENNSYLVANIA AVE	8TH ST	9TH ST	Flamingo/Lummus G	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4839	SW_1737	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4840	SW_1737	PENNSYLVANIA AVE	PENNSYLVANIA AVE	NORTH END	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4863	SW_1774	PENNSYLVANIA AVE	8TH ST	9TH ST	Flamingo/Lummus G	Good	Adequate	Adequate	Adequate	Adequate		
R_4900	SW_3207	PENNSYLVANIA AVE	LINCOLN LN	LINCOLN RD	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5015	SW_1016	PENNSYLVANIA AVE	14TH ST	14TH PL	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5031	SW_1087	PENNSYLVANIA AVE	14TH PL	ESPANOLA WAY	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_5047	SW_1150	PENNSYLVANIA AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus D	Good	Adequate	Adequate	Adequate	Adequate		
R_0179	SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0189	SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0236	SW_0520	PINE TREE DR	61ST ST	63RD ST	La Gorce D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0248	SW_0575	PINE TREE DR	47TH ST	46TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0322	SW_0511	PINE TREE DR	46TH XOVR	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0356	SW_0531	PINE TREE DR	46TH ST	46TH XOVR	Nautilus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0400	SW_0531	PINE TREE DR	46TH ST	46TH XOVR	Nautilus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0454	SW_0575	PINE TREE DR	47TH ST	46TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0569	SW_1931	PINE TREE DR	51ST ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0587	SW_1931	PINE TREE DR	51ST ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0626	SW_1997	PINE TREE DR	51ST ST	47TH ST	Nautilus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0691	SW_2095	PINE TREE DR	51ST ST	52ND ST	La Gorce D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0718	SW_2065	PINE TREE DR	51ST ST	47TH ST	La Gorce D	Good	Adequate	Adequate	Adequate	Adequate		
R_0732	SW_2095	PINE TREE DR	51ST ST	52ND ST	La Gorce D	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0767	SW_2117	PINE TREE DR	LA GORCE DR	51ST ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0777	SW_2117	PINE TREE DR	LA GORCE DR	51ST ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0793	SW_2117	PINE TREE DR	LA GORCE DR	51ST ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0844	SW_2135	PINE TREE DR	51ST ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0861	SW_2058	PINE TREE DR	51ST ST	47TH ST	Nautilus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1107	SW_1734	PINE TREE DR	42ND ST	41ST ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1130	SW_1734	PINE TREE DR	42ND ST	41ST ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1202	SW_1971	PINE TREE DR	44TH ST	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1222	SW_3181	PINE TREE DR	45TH ST	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1367	SW_2311	PINE TREE DR	42ND ST	44TJ ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1460	SW_2311	PINE TREE DR	42ND ST	44TJ ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1547	SW_2372	PINE TREE DR	41ST ST	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1632	SW_2396	PINE TREE DR	41ST ST	42ND ST	Nautilus C	Good	Adequate	Adequate	Adequate	Adequate		
R_1741	SW_2372	PINE TREE DR	41ST ST	42ND ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1912	SW_2582	PINE TREE DR	40TH ST	FLAMINGO DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1928	SW_2582	PINE TREE DR	40TH ST	FLAMINGO DR	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2012	SW_2657	PINE TREE DR	41ST ST	40TH CT	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2026	SW_2657	PINE TREE DR	41ST ST	40TH CT	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2048	SW_2657	PINE TREE DR	41ST ST	40TH CT	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2480	SW_1460	PINE TREE DR	DADE BLVD	24TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2540	SW_2279	PINE TREE DR	24TH ST	24TH TER	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2541	SW_2279	PINE TREE DR	24TH ST	24TH TER	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2648	SW_2313	PINE TREE DR	24TH TER	25TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2856	SW_3189	PINE TREE DR	37TH ST	35TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2902	SW_2528	PINE TREE DR	25TH ST	26TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3099	SW_2208	PINE TREE DR	SHERIDAN AVE	25TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3147	SW_2628	PINE TREE DR	26TH ST	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3159	SW_2628	PINE TREE DR	26TH ST	SHERIDAN AVE	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3161	SW_2208	PINE TREE DR	SHERIDAN AVE	25TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3170	SW_2649	PINE TREE DR	40TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3171	SW_2208	PINE TREE DR	SHERIDAN AVE	25TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3180	SW_2649	PINE TREE DR	40TH ST	37TH ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3199	SW_2667	PINE TREE DR	SHERIDAN AVE	28TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3210	SW_2668	PINE TREE DR	28TH ST	PINE TREE DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3211	SW_2314	PINE TREE DR	25TH ST	24TH TER	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3229	SW_2668	PINE TREE DR	28TH ST	PINE TREE DR	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3230	SW_2314	PINE TREE DR	25TH ST	24TH TER	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3238	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3247	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3257	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3269	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3305	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3328	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3339	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_3347	SW_2499	PINE TREE DR	24TH ST	DADE BLVD	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_0069	SW_0016	POINTE DR	COLLINS CT	WASHINGTON AVE	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0276	SW_0008	POINTE DR	COLLINS AVE	COLLINS CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0279	SW_0512	POINTE DR	WASHINGTON AVE	JEFFERSON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0327	SW_0008	POINTE DR	COLLINS AVE	COLLINS CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2021	SW_3051	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2583	SW_0199	POINTE DR	COLLINS CT	POINTE DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2584	SW_0194	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2585	SW_0199	POINTE DR	COLLINS CT	POINTE DR	South Pointe A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2586	SW_0202	POINTE DR	POINTE DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2605	SW_0194	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2615	SW_0194	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2616	SW_0199	POINTE DR	COLLINS CT	POINTE DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2756	SW_3052	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2779	SW_0199	POINTE DR	COLLINS CT	POINTE DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2780	SW_3051	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2790	SW_3051	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2791	SW_3051	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2827	SW_0202	POINTE DR	POINTE DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_2858	SW_3053	POINTE DR	JEFFERSON AVE	WASHINGTON AVE	South Pointe D	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3349	SW_3111	POINTE DR	OCEAN DR	BEACH SVRD	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_3351	SW_3111	POINTE DR	OCEAN DR	BEACH SVRD	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_3481	SW_0227	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_3486	SW_0202	POINTE DR	POINTE DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_3869	SW_0202	POINTE DR	POINTE DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3873	SW_0202	POINTE DR	POINTE DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3948	SW_0202	POINTE DR	POINTE DR	OCEAN CT	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4075	SW_0222	POINTE DR	OCEAN DR	BEACH SVRD	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4148	SW_0222	POINTE DR	OCEAN DR	BEACH SVRD	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4192	SW_0666	POINTE DR	OCEAN DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4216	SW_0227	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4217	SW_0227	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4228	SW_0227	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4229	SW_0227	POINTE DR	BEACH SVRD	OCEAN DR	South Pointe A	Good	Adequate	Adequate	Adequate	Adequate		
R_4449	SW_0666	POINTE DR	OCEAN DR	OCEAN CT	South Pointe A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5060	SW_0512	POINTE DR	WASHINGTON AVE	JEFFERSON AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0029	SW_2510	POST AVE	42ND ST	43RD ST	Nautilus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0188	SW_2510	POST AVE	42ND ST	43RD ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0552	SW_2608	POST AVE	45TH ST	46TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0625	SW_2571	POST AVE	46TH ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0010	SW_2048	PRAIRIE AVE	41ST ST	41ST CT	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0038	SW_2048	PRAIRIE AVE	41ST ST	41ST CT	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0129	SW_2105	PRAIRIE AVE	41ST CT	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0165	SW_2105	PRAIRIE AVE	41ST CT	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0166	SW_2105	PRAIRIE AVE	41ST CT	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0177	SW_2105	PRAIRIE AVE	41ST CT	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0402	SW_0462	PRAIRIE AVE	23RD ST	PRAIRIE AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0418	SW_0242	PRAIRIE AVE	23RD ST	PRAIRIE AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0455	SW_0463	PRAIRIE AVE	23RD ST	PRAIRIE AVE	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0475	SW_3167	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_0504	SW_0486	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0523	SW_3167	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_0586	SW_2479	PRAIRIE AVE	46TH ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0826	SW_2256	PRAIRIE AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1014	SW_2256	PRAIRIE AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1045	SW_2256	PRAIRIE AVE	40TH ST	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1118	SW_2287	PRAIRIE AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1170	SW_2287	PRAIRIE AVE	40TH ST	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1238	SW_2287	PRAIRIE AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1321	SW_0519	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2178	SW_2234	PRAIRIE AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2241	SW_2305	PRAIRIE AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2277	SW_2234	PRAIRIE AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2349	SW_2234	PRAIRIE AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2593	SW_2305	PRAIRIE AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3293	SW_2521	PRAIRIE AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3315	SW_0504	PRAIRIE AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3329	SW_2521	PRAIRIE AVE	34TH ST	37TH ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3330	SW_2521	PRAIRIE AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3389	SW_0504	PRAIRIE AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3411	SW_0504	PRAIRIE AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3446	SW_2109	PRAIRIE AVE	31ST ST	34TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3540	SW_2664	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3549	SW_2664	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3557	SW_0519	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3698	SW_0519	PRAIRIE AVE	DADE BLVD	23RD ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3792	SW_0419	PRAIRIE AVE	30TH ST	31ST ST	Bayshore B	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_3802	SW_2109	PRAIRIE AVE	31ST ST	34TH ST	Bayshore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4105	SW_2048	PRAIRIE AVE	41ST ST	41ST CT	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_4107	SW_2081	PRAIRIE AVE	41ST ST	41ST CT	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5122	SW_2350	PRAIRIE AVE	CHASE AVE	45TH ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5153	SW_2221	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5154	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5162	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5165	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5172	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5176	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5177	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5180	SW_2105	PRAIRIE AVE	41ST CT	42ND ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5192	SW_1970	PRAIRIE AVE	42ND ST	44TH ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0114	SW_0043	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0250	SW_0045	PURDY AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0392	SW_0034	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0403	SW_0034	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0404	SW_0043	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0510	SW_0071	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0511	SW_0071	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0512	SW_0095	PURDY AVE	18TH ST	DADE BLVD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0561	SW_0071	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0579	SW_0071	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0616	SW_0095	PURDY AVE	18TH ST	DADE BLVD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0656	SW_0071	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0658	SW_0095	PURDY AVE	18TH ST	DADE BLVD	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0962	SW_0043	PURDY AVE	20TH ST	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1063	SW_3173	PURDY AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1078	SW_3173	PURDY AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1079	SW_0095	PURDY AVE	18TH ST	DADE BLVD	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2228	SW_3172	PURDY AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2249	SW_3172	PURDY AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0373	SW_1113	RAY ST	SE END	SHORE DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1757	SW_2754	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Venetian Islands A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1772	SW_0569	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1932	SW_2861	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1947	SW_2843	RIVO ALTO DR	VENETIAN RIVO ALTO WAY	3RD RIVO ALTO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2028	SW_2850	RIVO ALTO DR	3RD RIVO ALTO TER	4TH RIVO ALTO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2242	SW_2856	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_2294	SW_2855	RIVO ALTO DR	4TH RIVO ALTO TER	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3626	SW_2945	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3658	SW_2964	RIVO ALTO DR	2ND RIVO ALTO TER	VENETIAN RIVO ALTO WAY	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3688	SW_2961	RIVO ALTO DR	RIVO ALTO DR	1ST RIVO ALTO TER	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_0121	SW_2090	ROYAL PALM AVE	42ND ST	43RD ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0130	SW_0671	ROYAL PALM AVE	42ND ST	43RD ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0142	SW_0646	ROYAL PALM AVE	43RD ST	44TH ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0228	SW_2303	ROYAL PALM AVE	43RD ST	44TH ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0417	SW_0613	ROYAL PALM AVE	46TH ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0503	SW_0613	ROYAL PALM AVE	46TH ST	47TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1221	SW_0671	ROYAL PALM AVE	42ND ST	43RD ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1365	SW_0621	ROYAL PALM AVE	44TH ST	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1394	SW_2340	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1407	SW_2340	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1459	SW_2340	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1496	SW_2340	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1576	SW_2404	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1616	SW_2404	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1672	SW_2404	ROYAL PALM AVE	40TH ST	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2682	SW_2342	ROYAL PALM AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2696	SW_2367	ROYAL PALM AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2706	SW_2333	ROYAL PALM AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2713	SW_2342	ROYAL PALM AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2728	SW_2342	ROYAL PALM AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2745	SW_2439	ROYAL PALM AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2787	SW_2439	ROYAL PALM AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3221	SW_2333	ROYAL PALM AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_4129	SW_1747	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5103	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5106	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5113	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5116	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5119	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5123	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5129	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5136	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5141	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_5150	SW_1916	ROYAL PALM AVE	41ST ST	ROYAL PALM AVE	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1007	SW_1762	RUE BORDEAUX	BIARRITZ DR	71ST ST	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1074	SW_1762	RUE BORDEAUX	BIARRITZ DR	71ST ST	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2850	SW_0400	RUE BORDEAUX	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_5038	SW_0400	RUE BORDEAUX	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_5056	SW_0448	RUE BORDEAUX	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_5073	SW_0448	RUE BORDEAUX	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1512	SW_1962	RUE GRANVILLE	BIARRITZ DR	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3466	SW_2262	RUE GRANVILLE	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3503	SW_2262	RUE GRANVILLE	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3527	SW_2262	RUE GRANVILLE	BAY DR	BIARRITZ DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4131	SW_2750	RUE GRANVILLE	BAY DR	BIARRITZ DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0062	SW_0482	RUE NOTRE DAME	BAY DR	BIARRITZ DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0200	SW_2126	RUE NOTRE DAME	EVERGLADES CT	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1926	SW_2217	RUE NOTRE DAME	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2818	SW_2104	RUE NOTRE DAME	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2861	SW_2217	RUE NOTRE DAME	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3437	SW_2126	RUE NOTRE DAME	EVERGLADES CT	NORMANDY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3489	SW_2179	RUE NOTRE DAME	71ST ST	EVERGLADES CT	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5093	SW_0475	RUE NOTRE DAME	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0381	SW_0822	RUE VENDOME	BIARRITZ CT	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0413	SW_0844	RUE VENDOME	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0436	SW_0873	RUE VENDOME	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_0450	SW_0873	RUE VENDOME	BREST ESPLANADE	BIARRITZ CT	Normandy Isles A	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0469	SW_0883	RUE VENDOME	BIARRITZ CT	71ST ST	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0483	SW_3153	RUE VENDOME	BIARRITZ CT	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0006	SW_0855	RUE VERSAILLES	BIARRITZ CT	71ST ST	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0137	SW_0950	RUE VERSAILLES	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0149	SW_0559	RUE VERSAILLES	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1685	SW_2124	RUE VERSAILLES	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1712	SW_2124	RUE VERSAILLES	NORMANDY DR	MARSEILLE DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2590	SW_1769	RUE VERSAILLES	SOUTH END	BAY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0168	SW_0451	SHERIDAN AVE	44TH ST	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0190	SW_0505	SHERIDAN AVE	45TH ST	46TH XOVR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0208	SW_0505	SHERIDAN AVE	45TH ST	46TH XOVR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0265	SW_0528	SHERIDAN AVE	46TH XOVR	46TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0274	SW_0528	SHERIDAN AVE	46TH XOVR	46TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0399	SW_0528	SHERIDAN AVE	46TH XOVR	46TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0401	SW_0505	SHERIDAN AVE	45TH ST	46TH XOVR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1030	SW_1665	SHERIDAN AVE	41ST ST	41ST CT	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1047	SW_1666	SHERIDAN AVE	41ST CT	42ND ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1061	SW_1666	SHERIDAN AVE	41ST CT	42ND ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1167	SW_1846	SHERIDAN AVE	41ST ST	41ST CT	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1298	SW_0451	SHERIDAN AVE	44TH ST	45TH ST	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1331	SW_0377	SHERIDAN AVE	43RD ST	44TH ST	Nautilus B	Good	Adequate	Adequate	Adequate	Adequate		
R_1443	SW_0505	SHERIDAN AVE	45TH ST	46TH XOVR	Nautilus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1770	SW_2535	SHERIDAN AVE	40TH CT	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1826	SW_2535	SHERIDAN AVE	40TH CT	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1853	SW_2578	SHERIDAN AVE	40TH CT	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_1900	SW_2578	SHERIDAN AVE	40TH CT	41ST ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1929	SW_2578	SHERIDAN AVE	40TH CT	41ST ST	Bayshore C	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1946	SW_2578	SHERIDAN AVE	40TH CT	41ST ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2729	SW_2040	SHERIDAN AVE	PINE TREE DR	28TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2737	SW_2040	SHERIDAN AVE	PINE TREE DR	28TH ST	Bayshore A	Good	Adequate	Adequate	Adequate	Adequate		
R_2777	SW_2249	SHERIDAN AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2788	SW_2154	SHERIDAN AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2867	SW_2512	SHERIDAN AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2942	SW_2585	SHERIDAN AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2956	SW_2512	SHERIDAN AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_2976	SW_2154	SHERIDAN AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3002	SW_1917	SHERIDAN AVE	31ST ST	34TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3003	SW_1917	SHERIDAN AVE	31ST ST	34TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3038	SW_2585	SHERIDAN AVE	37TH ST	40TH ST	Bayshore C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3059	SW_1921	SHERIDAN AVE	28TH ST	29TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3078	SW_2040	SHERIDAN AVE	PINE TREE DR	28TH ST	Bayshore A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3097	SW_2585	SHERIDAN AVE	37TH ST	40TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3098	SW_2040	SHERIDAN AVE	PINE TREE DR	28TH ST	Bayshore A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3111	SW_2041	SHERIDAN AVE	31ST ST	34TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3134	SW_2041	SHERIDAN AVE	31ST ST	34TH ST	Bayshore B	Good	Adequate	Adequate	Adequate	Adequate		
R_3160	SW_2249	SHERIDAN AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3200	SW_2249	SHERIDAN AVE	34TH ST	37TH ST	Bayshore C	Good	Adequate	Adequate	Adequate	Adequate		
R_3482	SW_1673	SHERIDAN AVE	41ST CT	42ND ST	Nautilus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0016	SW_0967	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0033	SW_0967	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0135	SW_0967	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0136	SW_0998	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0147	SW_0793	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0148	SW_0998	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0159	SW_1093	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0161	SW_0998	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0173	SW_0998	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0224	SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0241	SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0284	SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0285	SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0304	SW_0793	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0332	SW_0793	SHORE DR	BAY DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0334	SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0370	SW_1092	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0372	SW_1212	SHORE DR	RAY ST	HAGEN ST	Normandy Shores A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0394	SW_1093	SHORE DR	BAY DR	RAY ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0422	SW_1172	SHORE DR	RAY ST	HAGEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0517	SW_1172	SHORE DR	RAY ST	HAGEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0532	SW_1229	SHORE DR	HAGEN ST	JONES ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0584	SW_1212	SHORE DR	RAY ST	HAGEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0602	SW_1338	SHORE DR	HAGEN ST	JONES ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0648	SW_1229	SHORE DR	HAGEN ST	JONES ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0660	SW_1291	SHORE DR	JONES ST	BIARRITZ DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0726	SW_1291	SHORE DR	JONES ST	BIARRITZ DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0773	SW_1338	SHORE DR	HAGEN ST	JONES ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0788	SW_1403	SHORE DR	JONES ST	BIARRITZ DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0821	SW_1403	SHORE DR	JONES ST	BIARRITZ DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0840	SW_1403	SHORE DR	JONES ST	BIARRITZ DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1041	SW_1469	SHORE DR	BIARRITZ DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1059	SW_1470	SHORE DR	BIARRITZ DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1073	SW_1469	SHORE DR	BIARRITZ DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1087	SW_1470	SHORE DR	BIARRITZ DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1114	SW_1470	SHORE DR	BIARRITZ DR	FAIRWAY DR	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1182	SW_1510	SHORE DR	FAIRWAY DR	SARAZEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1216	SW_1144	SHORE DR	MITCHELL ST	SARAZEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1378	SW_1144	SHORE DR	MITCHELL ST	SARAZEN ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1390	SW_1194	SHORE DR	VARDON ST	MITCHELL ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_1455	SW_1194	SHORE DR	VARDON ST	MITCHELL ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1490	SW_1236	SHORE DR	FAIRWAY DR	VARDON ST	Normandy Shores A	Good	Adequate	Adequate	Adequate	Adequate		
R_0245	SW_0527	STILLWATER DR	86TH ST	STILLWATER DR	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_0810	SW_1284	STILLWATER DR	86TH ST	STILLWATER DR	Biscayne Point A	Good	Adequate	Adequate	Adequate	Adequate		
R_3112	SW_3166	SULLIVAN DR	ALTON RD	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_3125	SW_3166	SULLIVAN DR	ALTON RD	ALTON RD	Nautilus G	Good	Adequate	Adequate	Adequate	Adequate		
R_0734	SW_2764	SUNSET DR	BAY RD	21ST ST	Sunset Islands C	Good	Adequate	Adequate	Adequate	Adequate		
R_0780	SW_2801	SUNSET DR	22ND ST	23RD ST	Sunset Islands C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0781	SW_2801	SUNSET DR	22ND ST	23RD ST	Sunset Islands C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5174	SW_0622	SUNSET DR	20TH ST	BAY RD	Lower North Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0889	SW_1679	TATUM WATERWAY DR	77TH ST	78TH ST	North Shore B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0941	SW_1679	TATUM WATERWAY DR	77TH ST	78TH ST	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1027	SW_2087	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	North Shore A	Good	Adequate	Adequate	Adequate	Adequate		
R_1060	SW_1779	TATUM WATERWAY DR	77TH ST	78TH ST	North Shore B	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_1146	SW_1841	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1199	SW_1841	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1237	SW_1833	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1255	SW_1833	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1277	SW_2113	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1379	SW_1904	TATUM WATERWAY DR	CARLYLE AVE	81ST ST	North Shore A	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_1727	SW_2113	TATUM WATERWAY DR	DICKENS AVE	CARLYLE AVE	North Shore B	Good	Adequate	Adequate	Adequate	Adequate		
R_1883	SW_2201	TATUM WATERWAY DR	78TH ST	DICKENS AVE	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5194	SW_1679	TATUM WATERWAY DR	77TH ST	78TH ST	North Shore B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0036	SW_0563	TROUVILLE ESPLANADE	71ST ST	NORMANDY DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0904	SW_0292	TROUVILLE ESPLANADE	BAY DR	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0922	SW_1851	TROUVILLE ESPLANADE	BIARRITZ DR	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1183	SW_1851	TROUVILLE ESPLANADE	BIARRITZ DR	71ST ST	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1217	SW_1851	TROUVILLE ESPLANADE	BIARRITZ DR	71ST ST	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1293	SW_1862	TROUVILLE ESPLANADE	71ST ST	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1310	SW_1862	TROUVILLE ESPLANADE	71ST ST	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_1328	SW_1862	TROUVILLE ESPLANADE	71ST ST	BIARRITZ DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2255	SW_2426	TROUVILLE ESPLANADE	CALAIS DR	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2934	SW_2426	TROUVILLE ESPLANADE	CALAIS DR	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2950	SW_0292	TROUVILLE ESPLANADE	BAY DR	BIARRITZ DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3068	SW_2449	TROUVILLE ESPLANADE	MARSEILLE DR	NORMANDY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3083	SW_2070	TROUVILLE ESPLANADE	CALAIS DR	TROUVILLE ESPLANADE	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3637	SW_0563	TROUVILLE ESPLANADE	71ST ST	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3654	SW_0563	TROUVILLE ESPLANADE	71ST ST	NORMANDY DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_3212	SW_0347	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3223	SW_0639	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3372	SW_2397	VENETIAN CSWY	VENETIAN SAN MARINO WAY	WEST END	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3403	SW_2523	VENETIAN CSWY	VENETIAN DI LIDO WAY	SAN MARINO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3115	SW_2900	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3133	SW_2900	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3135	SW_2900	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3137	SW_2900	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3149	SW_2900	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3439	SW_2943	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3447	SW_2943	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3603	SW_2943	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3614	SW_2943	VENETIAN DI LIDO WAY	DI LIDO DR	DI LIDO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1801	SW_2755	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1815	SW_2755	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1960	SW_2755	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3627	SW_2952	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3633	SW_2952	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3651	SW_2952	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3652	SW_2952	VENETIAN RIVO ALTO WAY	RIVO ALTO DR	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3222	SW_0545	VENETIAN SAN MARINO WAY	SAN MARINO DR	SAN MARINO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3239	SW_0545	VENETIAN SAN MARINO WAY	SAN MARINO DR	SAN MARINO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3381	SW_2919	VENETIAN SAN MARINO WAY	SAN MARINO DR	SAN MARINO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3413	SW_2919	VENETIAN SAN MARINO WAY	SAN MARINO DR	SAN MARINO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1408	SW_3095	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1531	SW_3095	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1532	SW_3095	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1578	SW_3096	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1593	SW_3096	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_1618	SW_0497	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1633	SW_3096	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1689	SW_2783	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_1705	SW_2783	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3642	SW_2966	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3706	SW_2966	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3713	SW_2966	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3719	SW_2966	VENETIAN WAY	ISLAND AVE	RIVO ALTO DR	Venetian Islands A	Good	Adequate	Adequate	Adequate	Adequate		
R_3766	SW_2990	VENETIAN WAY	DADE BLVD	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_3767	SW_2977	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_3776	SW_2977	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_3786	SW_2977	VENETIAN WAY	ISLAND AVE	ISLAND AVE	Venetian Islands B	Good	Adequate	Adequate	Adequate	Adequate		
R_0379	SW_2062	VERDUN DR	VERDUN CT	MARSEILLE DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_0396	SW_1145	VERDUN DR	MARSEILLE DR	CALAIS DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1280	SW_1720	VERDUN DR	MARSEILLE DR	CALAIS DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1350	SW_1720	VERDUN DR	MARSEILLE DR	CALAIS DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1364	SW_1720	VERDUN DR	MARSEILLE DR	CALAIS DR	Normandy Isles A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1380	SW_1720	VERDUN DR	MARSEILLE DR	CALAIS DR	Normandy Isles A	Good	Adequate	Adequate	Adequate	Adequate		
R_2122	SW_2062	VERDUN DR	VERDUN CT	MARSEILLE DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3815	SW_2427	VICHY DR	MAIMONIDES ST	NORMANDY DR	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_3824	SW_2450	VICHY DR	71ST ST	MAIMONIDES ST	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3825	SW_2450	VICHY DR	71ST ST	MAIMONIDES ST	Normandy Isles A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0021	SW_0524	WASHINGTON AVE	POINTE CT	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0022	SW_0436	WASHINGTON AVE	6TH ST	7TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0057	SW_0436	WASHINGTON AVE	6TH ST	7TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0087	SW_0440	WASHINGTON AVE	5TH ST	6TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0090	SW_0029	WASHINGTON AVE	POINTE DR	COMMERCE ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0108	SW_0440	WASHINGTON AVE	5TH ST	6TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0156	SW_0038	WASHINGTON AVE	COMMERCE ST	1ST ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0157	SW_0130	WASHINGTON AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0158	SW_0204	WASHINGTON AVE	3RD ST	2ND ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0252	SW_0062	WASHINGTON AVE	2ND ST	3RD ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0280	SW_0524	WASHINGTON AVE	POINTE CT	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0329	SW_0029	WASHINGTON AVE	POINTE DR	COMMERCE ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0340	SW_0436	WASHINGTON AVE	6TH ST	7TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0341	SW_0524	WASHINGTON AVE	POINTE CT	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0446	SW_2052	WASHINGTON AVE	16TH ST	LINCOLN RD	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0489	SW_2025	WASHINGTON AVE	16TH ST	LINCOLN RD	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0492	SW_0038	WASHINGTON AVE	COMMERCE ST	1ST ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0572	SW_2025	WASHINGTON AVE	16TH ST	LINCOLN RD	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0573	SW_0130	WASHINGTON AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0593	SW_2052	WASHINGTON AVE	16TH ST	LINCOLN RD	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0609	SW_0251	WASHINGTON AVE	COMMERCE CT	COMMERCE ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0611	SW_0750	WASHINGTON AVE	PENNSYLVANIA AVE	5TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_0645	SW_0053	WASHINGTON AVE	1ST ST	2ND ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0672	SW_0818	WASHINGTON AVE	12TH ST	13TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0681	SW_0053	WASHINGTON AVE	1ST ST	2ND ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0738	SW_0818	WASHINGTON AVE	12TH ST	13TH ST	Flamingo/Lummus B	Good	Adequate	Adequate	Adequate	Adequate		
R_0915	SW_2091	WASHINGTON AVE	15TH ST	16TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0947	SW_2091	WASHINGTON AVE	15TH ST	16TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1034	SW_0815	WASHINGTON AVE	7TH ST	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1052	SW_2091	WASHINGTON AVE	15TH ST	16TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1064	SW_0815	WASHINGTON AVE	7TH ST	PENNSYLVANIA AVE	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1083	SW_0880	WASHINGTON AVE	11TH ST	12TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1094	SW_2099	WASHINGTON AVE	ESPANOLA WAY	15TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1123	SW_2091	WASHINGTON AVE	15TH ST	16TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1273	SW_0177	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1370	SW_0130	WASHINGTON AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1427	SW_2191	WASHINGTON AVE	14TH ST	ESPANOLA WAY	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1461	SW_2191	WASHINGTON AVE	14TH ST	ESPANOLA WAY	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1470	SW_0975	WASHINGTON AVE	10TH ST	11TH ST	Flamingo/Lummus B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1482	SW_0130	WASHINGTON AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1538	SW_0975	WASHINGTON AVE	10TH ST	11TH ST	Flamingo/Lummus B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_1588	SW_1358	WASHINGTON AVE	LINCOLN LN	17TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1610	SW_1358	WASHINGTON AVE	LINCOLN LN	17TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1626	SW_1358	WASHINGTON AVE	LINCOLN LN	17TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1643	SW_1358	WASHINGTON AVE	LINCOLN LN	17TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1710	SW_1386	WASHINGTON AVE	17TH ST	JACKIE GLEASON DR	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1751	SW_1402	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1752	SW_1402	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1782	SW_1402	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1796	SW_1422	WASHINGTON AVE	18TH ST	19TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1819	SW_1422	WASHINGTON AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1833	SW_1422	WASHINGTON AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1874	SW_1311	WASHINGTON AVE	LINCOLN RD	16TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1903	SW_1311	WASHINGTON AVE	LINCOLN RD	16TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_1907	SW_1431	WASHINGTON AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1923	SW_1468	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1942	SW_1461	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1970	SW_1431	WASHINGTON AVE	18TH ST	19TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_1994	SW_1468	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2006	SW_1468	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2023	SW_1508	WASHINGTON AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2042	SW_1508	WASHINGTON AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2054	SW_1365	WASHINGTON AVE	16TH ST	15TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2097	SW_1508	WASHINGTON AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2136	SW_1508	WASHINGTON AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2149	SW_1365	WASHINGTON AVE	16TH ST	15TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2164	SW_0823	WASHINGTON AVE	4TH ST	3RD ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2173	SW_1508	WASHINGTON AVE	20TH ST	21ST ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2182	SW_0814	WASHINGTON AVE	5TH ST	4TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2187	SW_1365	WASHINGTON AVE	16TH ST	15TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2193	SW_1526	WASHINGTON AVE	21ST ST	WASHINGTON CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2205	SW_0251	WASHINGTON AVE	COMMERCE CT	COMMERCE ST	Flamingo/Lummus A	Damaged	Adequate	Not Adequate	Not Adequate	Not Adequate		$2,500
R_2207	SW_0814	WASHINGTON AVE	5TH ST	4TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2235	SW_1543	WASHINGTON AVE	WASHINGTON CT	DADE BLVD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2236	SW_1543	WASHINGTON AVE	WASHINGTON CT	DADE BLVD	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2315	SW_0823	WASHINGTON AVE	4TH ST	3RD ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2344	SW_1590	WASHINGTON AVE	20TH ST	21ST ST	City Center B	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2346	SW_1580	WASHINGTON AVE	21ST ST	WASHINGTON CT	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2376	SW_0823	WASHINGTON AVE	4TH ST	3RD ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2395	SW_0823	WASHINGTON AVE	4TH ST	3RD ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2402	SW_1604	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2403	SW_1604	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2412	SW_0130	WASHINGTON AVE	3RD ST	4TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2420	SW_1604	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2421	SW_1604	WASHINGTON AVE	19TH ST	20TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2508	SW_0177	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2520	SW_1407	WASHINGTON AVE	15TH ST	ESPANOLA WAY	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2526	SW_0178	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2564	SW_0178	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2639	SW_1407	WASHINGTON AVE	15TH ST	ESPANOLA WAY	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2726	SW_0177	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2740	SW_0177	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2748	SW_0178	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2772	SW_0178	WASHINGTON AVE	WASHINGTON AVE	POINTE DR	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3173	SW_1466	WASHINGTON AVE	ESPANOLA WAY	14TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3296	SW_0996	WASHINGTON AVE	9TH ST	10TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3297	SW_0996	WASHINGTON AVE	9TH ST	10TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3307	SW_1013	WASHINGTON AVE	8TH ST	9TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3319	SW_1013	WASHINGTON AVE	8TH ST	9TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3320	SW_0985	WASHINGTON AVE	7TH ST	8TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_3332	SW_0985	WASHINGTON AVE	7TH ST	8TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4337	SW_0053	WASHINGTON AVE	1ST ST	2ND ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4579	SW_1587	WASHINGTON AVE	13TH ST	12TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4591	SW_1587	WASHINGTON AVE	13TH ST	12TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4654	SW_1627	WASHINGTON AVE	12TH ST	11TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4682	SW_1651	WASHINGTON AVE	11TH ST	10TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4713	SW_1651	WASHINGTON AVE	11TH ST	10TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4721	SW_1651	WASHINGTON AVE	11TH ST	10TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4738	SW_1667	WASHINGTON AVE	10TH ST	9TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4740	SW_1667	WASHINGTON AVE	10TH ST	9TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4741	SW_1667	WASHINGTON AVE	10TH ST	9TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4753	SW_1683	WASHINGTON AVE	9TH ST	8TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4771	SW_1683	WASHINGTON AVE	9TH ST	8TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4785	SW_1697	WASHINGTON AVE	8TH ST	7TH ST	Flamingo/Lummus A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4799	SW_1697	WASHINGTON AVE	8TH ST	7TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_4923	SW_1909	WASHINGTON AVE	LINCOLN LN	17TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_5043	SW_1386	WASHINGTON AVE	17TH ST	JACKIE GLEASON DR	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5044	SW_1402	WASHINGTON AVE	JACKIE GLEASON DR	18TH ST	City Center B	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5083	SW_0726	WASHINGTON AVE	13TH ST	14TH ST	Flamingo/Lummus A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_5094	SW_0726	WASHINGTON AVE	13TH ST	14TH ST	Flamingo/Lummus A	Good	Adequate	Adequate	Adequate	Adequate		
R_2307	SW_1570	WASHINGTON CT	22ND ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2325	SW_1691	WASHINGTON CT	22ND ST	WASHINGTON AVE	City Center B	Good	Adequate	Adequate	Adequate	Adequate		
R_2852	SW_0831	WAYNE AVE	BRUCE ST	MICHAEL ST	Biscayne Point B	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_2890	SW_0938	WAYNE AVE	RAYMOND ST	73RD ST	Biscayne Point B	Not Present	Not Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_2936	SW_0978	WAYNE AVE	RAYMOND ST	73RD ST	Biscayne Point B	Not Present	Adequate	Not Adequate	Adequate	Not Adequate		$2,500
R_0089	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_0229	SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_0494	SW_0869	WEST AVE	14TH ST	14TH TER	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0617	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0632	SW_0191	WEST AVE	LINCOLN RD	17TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0641	SW_0191	WEST AVE	LINCOLN RD	17TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_0667	SW_0191	WEST AVE	LINCOLN RD	17TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0669	SW_0191	WEST AVE	LINCOLN RD	17TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0785	SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_0936	SW_1542	WEST AVE	LINCOLN RD	17TH ST	City Center A	Damaged	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1206	SW_0643	WEST AVE	15TH TER	16TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1360	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_1411	SW_0709	WEST AVE	15TH ST	15TH TER	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1518	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1536	SW_0738	WEST AVE	15TH TER	16TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1550	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1568	SW_0752	WEST AVE	FLAMINGO WAY	15TH ST	Flamingo/Lummus E	Not Present	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_1581	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1604	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1605	SW_0080	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1789	SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1790	SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1807	SW_0869	WEST AVE	14TH ST	14TH TER	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1829	SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1867	SW_0056	WEST AVE	18TH ST	20TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_1948	SW_0904	WEST AVE	FLAMINGO WAY	15TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Not Adequate	Not Adequate		$2,500
R_1992	SW_0084	WEST AVE	DADE BLVD	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2019	SW_0088	WEST AVE	DADE BLVD	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2038	SW_0088	WEST AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2055	SW_0955	WEST AVE	14TH CT	FLAMINGO WAY	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2062	SW_0088	WEST AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2078	SW_0974	WEST AVE	14TH TER	14TH CT	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2088	SW_0084	WEST AVE	DADE BLVD	18TH ST	Sunset Harbor A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2126	SW_1009	WEST AVE	12TH ST	13TH ST	Flamingo/Lummus E	Good	Adequate	Adequate	Adequate	Adequate		
R_2153	SW_0088	WEST AVE	DADE BLVD	18TH ST	Sunset Harbor A	Good	Adequate	Adequate	Adequate	Adequate		
R_2168	SW_1009	WEST AVE	12TH ST	13TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2245	SW_1039	WEST AVE	MONAD TER	14TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2264	SW_1061	WEST AVE	14TH ST	14TH TER	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2265	SW_1061	WEST AVE	14TH ST	14TH TER	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2266	SW_1063	WEST AVE	11TH ST	12TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2299	SW_1039	WEST AVE	MONAD TER	14TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2332	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_2333	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2334	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2354	SW_1061	WEST AVE	14TH ST	14TH TER	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_2359	SW_1042	WEST AVE	13TH ST	MONAD TER	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2360	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2361	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2381	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2382	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2394	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2414	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2433	SW_1081	WEST AVE	12TH ST	13TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2465	SW_1089	WEST AVE	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2476	SW_1089	WEST AVE	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2487	SW_1097	WEST AVE	11TH ST	12TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2505	SW_1097	WEST AVE	11TH ST	12TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2523	SW_1097	WEST AVE	11TH ST	12TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2531	SW_1097	WEST AVE	11TH ST	12TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2557	SW_1089	WEST AVE	10TH ST	11TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_2579	SW_1097	WEST AVE	11TH ST	12TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2600	SW_1110	WEST AVE	10TH ST	11TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2640	SW_1097	WEST AVE	11TH ST	12TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_2659	SW_1110	WEST AVE	10TH ST	11TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3091	SW_1318	WEST AVE	ALTON RD	6TH ST	Flamingo/Lummus C	-	-	-	-	Under Construction		
R_3318	SW_1089	WEST AVE	10TH ST	11TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_3352	SW_1110	WEST AVE	10TH ST	11TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4114	SW_1110	WEST AVE	10TH ST	11TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4193	SW_1251	WEST AVE	ALTON RD	6TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4207	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4225	SW_1160	WEST AVE	9TH ST	10TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4244	SW_1181	WEST AVE	8TH ST	9TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4255	SW_1334	WEST AVE	8TH ST	9TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4261	SW_1181	WEST AVE	8TH ST	9TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4287	SW_1160	WEST AVE	9TH ST	10TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4288	SW_1181	WEST AVE	8TH ST	9TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4345	SW_1181	WEST AVE	8TH ST	9TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4354	SW_0738	WEST AVE	15TH TER	16TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4362	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4374	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4375	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4388	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4402	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4410	SW_0191	WEST AVE	LINCOLN RD	17TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4417	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4430	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4446	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4461	SW_1218	WEST AVE	6TH ST	8TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		

Ramp ID	Sidewalk ID	Street	Street From	Street To	Neighborhood	Detectable Warning	Turning/Landing Area	Ramp Slope	Ramp Transition	Overall	Detectable Warning Replacement Cost	Not Adequate Ramp Replacement Cost
R_4487	SW_1251	WEST AVE	ALTON RD	6TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4539	SW_1269	WEST AVE	ALTON RD	6TH ST	West Avenue and Bay Road A	Good	Adequate	Adequate	Adequate	Adequate		
R_4551	SW_1318	WEST AVE	ALTON RD	6TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4592	SW_1334	WEST AVE	8TH ST	9TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4600	SW_1334	WEST AVE	8TH ST	9TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4634	SW_1334	WEST AVE	8TH ST	9TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4703	SW_1391	WEST AVE	6TH ST	8TH ST	Flamingo/Lummus C	Good	Adequate	Adequate	Adequate	Adequate		
R_4715	SW_3108	WEST AVE	6TH ST	8TH ST	Flamingo/Lummus C	Good	Not Adequate	Adequate	Adequate	Not Adequate		$2,500
R_4722	SW_1391	WEST AVE	6TH ST	8TH ST	Flamingo/Lummus C	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4890	SW_1039	WEST AVE	MONAD TER	14TH ST	West Avenue and Bay Road A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4898	SW_0917	WEST AVE	MONAD TER	14TH ST	Flamingo/Lummus E	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4968	SW_1542	WEST AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4970	SW_1542	WEST AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4971	SW_1542	WEST AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4976	SW_1542	WEST AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	
R_4985	SW_1542	WEST AVE	LINCOLN RD	17TH ST	City Center A	Not Present	Adequate	Adequate	Adequate	Not Adequate	$350	