

## **Submittal Data Sheet**

Project Name:	PLYMOUTH HOTEL
Location:	
Engineer:	Ivan Velez, P.E.
Submitted to:	ESBER/ABEL
Submitted by:	
Reference:	ESI

pproval:	
ate:	1/9/2014
construction:	
Init #:	
rawing #:	
rawing #:	



## RXYQ120PBTJ

Std U.S. Warranty: 7yrs Compressor, 1yrs Parts



Rated Heating Capacity (Btu/hr): Nom Heating Capacity (Btu/hr): Heating Input Power (kW):

Heating COP (Btu/hr / Btu/hr): Heating COP 17F (Btu/hr / Btu/hr):

Daikin AC TRL Generated Submittal Data

## **Submittal Data Sheet**

Project Name:	PLYMOUTH HOTEL	
Location:	TETMOOTHTTOTEE	Approva
Engineer:	Ivan Velez, P.E.	Date:
Submitted to:	ESBER/ABEL	Constru
Submitted by:		Unit #:
Reference:	ESI	Drawing
Performance Outdoor Unit Model No:	RXYQ72PBTJ	Conden
Type:		
Rated Cooling Capacity (Btu/hr):	69000	Unit Cor
Nom Cooling Capacity (Btu/hr):	72000	
Cooling Input Power (kW):	5.39	Datado
SEER:	N/A	Rated C

Condensing Unit Type:	6-Ton VRV-III Heat Pump
Unit Combination:	
5	Indoor: 80°F DB/67°F WB
9	Outdoor: 95°F DB/75°F WB
Conditions	
	Indoor: 70°F DB/60°F WB
0	Outdoor: 47°F DB/43°F WB
Conditions	
Rated Piping Length (ft)	50 / 25
	0

Condensing Unit Details	
Power Supply (V/Hz/Ph):	208-230/60/3ph
Power Supply Connections:	L1, L2, L3 Ground
Min. Circuit Amps MCA (A):	30
Max. Overcurrent Protection (MOP)(A):	35
Max. Starting Current MSC(A):	-
Rated Load Amps RLA (A):	14.2
Dimensions Height (Inch):	66-1/8
Dimensions Width (Inch):	36-5/8
Dimensions Depth (Inch):	30-1/8
Net Weight (lbs):	420

Compressor Type.	IIIVEILEI
Capacity Control Range (%):	20 - 100
Capacity Index Limit:	36 - 93.6 (130%)
Airflow Rate (CFM):	6530
Gas Pipe Connection (inch):	3/4
Liquid Pipe Connection (inch):	3/8
H/L Pressure Connection (inch):	
H/L Equalizing Connection (inch):	
Sound Pressure Level (dBA):	57
Sound Power Level (dBA):	
Max. No. of Indoor Units:	12

R-410A
16.5
install data
-
164 ft (295 ft) / 295 ft
):

Cooling Range w/Baffle (°F):	
Heating Operation Range (°F):	0 - 77 / (-4) - 60
Heating Range w/Baffle (°F):	

Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006

Page 3 of 27

Daikin AC TRL Generated Submittal Data

Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006

Page 4 of 27

CHECKED BY: A8.01

REVISIONS / SUBMISSIONS

1323

CUT SHEETS
PLYMOUTH HOTEL

PLYMOUTH 336 21ST STREET MIAMI BEACH, FL 33139

MECHANICAL EQUIPMENT CUT SHEETS